

Local Law 78 Injury/Fatality Incident Report July 2024

Incident Unique ID	Incident Number	Incident Date & Time	BNY	House Number	Street Name	Borough	ZIP Code	Incident Reported By	Person Reporting Phone Number	Type of Person Reporting Incident	Organization of Person Reporting	Person in Control of Site	Name of Construction	Person Reporting License Number	Name of Site Owner	Number of Active Permits/Hours	Site Union Info	Construction Worker Notified Flag	Incident Description Details	Injury/Fatality Count	Fatality Count	Injury/Fatality Date	Injury/Fatality Hours Worked	Injury/Fatality Date of Employment	Number of Worker Union Member Flag	Number of Violations	Site Total Square Footage	Site New Building Type	Site Existing Number of Stories	Site Existing Height	Site Proposed Number of Stories	Site Proposed Height	Active Permits Number
100004301	0391204942	7/31/24 13:35	1022678	1211 6th Avenue	Manhattan	10036	General Contractor	5163507648	Individual		On Site management			39225	FOX	1	Union	Y	At approximately 12PM an alarm sounded by Adam Gorman (Sons Scandaglia) that John had received an electrical shock while installing split CT's in a low voltage amp distribution located in the 8th floor mechanical room. Steve had already called 911 and an ambulance was on its way. John's work partner, Gerard Cornejo, stated that John's left arm came in contact with the C Drive while his right arm was touching the metal enclosure. John fell back off his ladder and was caught by Gerard, but sustained his arms and neck flexor during his fall.	1	0	8/2/2024	6	6/1/2024	Y	1	3,000	N	45	502			M00820317
100004304		7/31/24 8:35	2130757	1351 Jerome Ave	Brooklyn	10452	General Contractor	9176240389	Business	CC Star management LLC				GC-621805	Sarah Rubin	1	Non-Union	N	Two pieces of sheetrock fell from the boom lift hitting the scaffolding brace and falling on street level. No one was hurt from this incident. Worker was laid off at 12:00 am on the morning and took to come back in the afternoon for his shift. At 8:40 am I got a call that an ambulance was here and took to that someone was hurt in the cellar. I went to the cellar with my S.S. Manager and there was someone laying on a steel beam holding his stomach. We tried talking with him but he wouldn't talk the ambulance took him to the Hospital. OGB was called immediately and OGB Inspector Kelly Budge @2773 came down and walked the site and spoke with S.S. Manager Arnon On. No violations were issued.	1	0	8/5/2024	0	1/0/2000	0	2	37,000	Y			14	140	M00728830-GC
100004316		7/30/24 8:45	1091791	205 East 110th Street	Manhattan	10029	General Contractor	7187583331	Business	Robak Development		KCF Services	JC-624238	205-209 3rd Ave OGB LLC	18	Non-Union	Y			1	0	8/7/2024	1	5/1/2024	N	0	238,086	Y		18	232	15-PN	