



**September  
2018**

# **City of New York Municipal Solar-Readiness Assessment**

**Prepared in compliance with Local Law 24 of 2016**

# City of New York

## Municipal Solar-Readiness Assessment

### Prepared in Compliance with Local Law 24 of 2016

#### Overview

The Department of Citywide Administrative Services (DCAS) Division of Energy Management (DEM) is submitting this assessment on September 1, 2018 in compliance with Local Law 24 (LL24) of 2016. Local Law 24 requires DCAS to assess all City-owned buildings for solar-readiness, which is defined as a building that is 10,000 or more gross building square feet, has a roof that is less than or equal to 10 years old or newer, and is in good structural condition. For buildings that are found to be solar-ready, DCAS estimates the potential solar photovoltaic (PV) system size in kilowatts (kW), the estimated annual energy generation in kilowatt-hours (kWh), and the estimated annual greenhouse gas emissions reduced.

For systems that have been completed or are in-progress to-date, DCAS provides: (1) the final installed and estimated system size in kilowatts (kW), respectively; (2) percentage of the maximum peak power the system provides; (3) estimated annual energy generation in kilowatt-hours (kWh); (4) percentage of the maximum energy consumption the system provides; (5) installation date; (6) total system cost; (7) how the system was financed; (8) estimated annual energy cost savings from the system; and (9) estimated annual greenhouse gas emissions reduced.

#### Results

To-date, the City has 10.51 MW of solar installed across 57 municipal buildings. In the inaugural LL24 report, DCAS outlined its strategy to achieve the goal of installing 100 MW of solar PV capacity by 2025. Since the last report in 2016, DCAS has initiated onsite solar feasibility assessments at nearly 100 buildings. These assessments include professional roof, structural, and electrical inspection to confirm future project viability. Based on these results, as well as the results from this year's compliance reporting, the results are as follows:

<b>Current Projects</b>		<b>Buildings</b>	<b>MW</b>
	Completed	57	10.51 MW
	In-Progress	125	18.38 MW
	<b>Total</b>	<b>182</b>	<b>28.90 MW</b>

<b>LL24 Assessment Results</b>		<b>Buildings</b>	<b>MW</b>
	Solar-Ready	413	30.35 MW
	Non-Solar-Ready	1477	N/A
	<b>Total</b>	<b>1890</b>	<b>30.35 MW</b>

# Completed Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Installation date	Installed Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Social Cost of Carbon Value**	Estimated Annual Energy Savings***	Upfront Project Cost	Financing Mechanism
1	DCAS	City Hall	City Hall Park	Manhattan		4/17/2015	10.0 kW	0.1%	11,738 kWh	0.1%	3 MT CO2	\$403	\$1,229	\$1,297	Capital
1	DOE	M276	55 Battery Place	Manhattan		7/1/2010	50.0 kW	6%	58,692 kWh	3%	15 MT CO2	\$2,017	\$5,765	\$231,500	Capital
1	DOT	Whitehall Ferry Terminal	4 South St	Manhattan		7/1/2005	59.0 kW	6%	69,257 kWh	2%	18 MT CO2	\$2,380	\$6,803	\$236,000	Capital
1	CUNY	BMCC Chambers St. Building	199 Chambers St	Manhattan		11/29/2017	307.0 kW	5%	360,369 kWh	2%	94 MT CO2	\$12,386	\$34,486	\$4,200,000	Capital
2	DOE	M022 - NEST	111 Columbia St	Manhattan	EJZ	7/1/2014	125.0 kW	20%	146,730 kWh	17%	38 MT CO2	\$5,043	\$13,305	\$905,386	Capital
3	DOE	M070	333 West 17th St	Manhattan		4/21/2016	159.2 kW	24%	186,887 kWh	24%	49 MT CO2	\$6,424	\$16,946	\$650,690	Capital
6	DOE	M470	145 West 84th Street	Manhattan		7/1/2012	46.7 kW	3%	54,818 kWh	2%	14 MT CO2	\$1,884	\$5,738	\$392,500	Capital
8	DPR	Five Borough Administrative Building	20 Bronx Shore Rd	Manhattan	EJZ	6/5/2015	46.2 kW	12%	54,196 kWh	6%	14 MT CO2	\$1,863	\$5,673	\$108,836	Capital
9	DOE	M154	250 West 127th Street	Manhattan	EJZ	4/28/2014	125.9 kW	30%	147,775 kWh	26%	38 MT CO2	\$5,079	\$13,400	\$578,750	Capital
10	DOE	X475	99 Terrace View Ave	Bronx	EJZ	7/15/2014	117.0 kW	9%	137,339 kWh	5%	36 MT CO2	\$4,721	(\$34,571)	\$0	PPA
11	DOE	X445	75 West 205th St	Bronx		10/1/2005	36.0 kW	3%	42,258 kWh	2%	11 MT CO2	\$1,452	\$4,423	\$166,680	Capital
12	DOE	X425	800 East Gun Hill Rd	Bronx	EJZ	1/13/2016	131.8 kW	14%	154,665 kWh	8%	40 MT CO2	\$5,316	\$14,025	\$570,186	Capital
13	DOE	X192	650 Hollywood Ave	Bronx		3/15/2016	137.3 kW	25%	161,110 kWh	19%	42 MT CO2	\$5,538	\$14,609	\$571,895	Capital
13	DOE	X144	2545 Gunther Ave	Bronx	EJZ	4/8/2016	192.2 kW	31%	225,553 kWh	24%	59 MT CO2	\$7,753	\$20,452	\$800,653	Capital
13	DOE	X405	3000 East Tremont Avenue	Bronx	EJZ	7/15/2014	247.0 kW	16%	289,938 kWh	8%	76 MT CO2	\$9,966	(\$72,984)	\$0	PPA
15	NYPD	48th Precinct	450 Cross Bronx Expwy	Bronx	EJZ	3/30/2012	31.7 kW	8%	37,211 kWh	3%	10 MT CO2	\$1,279	\$3,895	\$352,987	Capital

# Completed Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Installation date	Installed Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Social Cost of Carbon Value**	Estimated Annual Energy Savings***	Upfront Project Cost	Financing Mechanism
17	DOE	X184	778 Forest Ave / 756 East 158 St	Bronx	EJZ	4/8/2016	248.9 kW	29%	292,110 kWh	28%	76 MT CO2	\$10,040	\$26,488	\$943,255	Capital
18	DOE	X131	885 Bolton Ave	Bronx	EJZ	3/15/2016	200.8 kW	31%	235,707 kWh	26%	61 MT CO2	\$8,102	\$21,373	\$833,696	Capital
20	DCLA	Queens Botanical Garden	43-50 Main Street	Queens	EJZ	3/7/2007	18.0 kW	8%	21,129 kWh	4%	6 MT CO2	\$726	\$2,212	\$83,340	Capital
20	DOE	Q237	46-21 Colden St	Queens	EJZ	4/13/2016	247.0 kW	29%	289,938 kWh	34%	76 MT CO2	\$9,966	\$26,291	\$907,435	Capital
21	DCLA	NY Hall of Science	47-01 111th St	Queens		10/1/2005	15.0 kW	1%	17,608 kWh	1%	5 MT CO2	\$605	\$1,843	\$155,598	Capital
21	NYPD	115th Precinct	92-15 Northern Blvd	Queens	EJZ	3/30/2012	49.7 kW	24%	58,340 kWh	11%	15 MT CO2	\$2,005	\$6,107	\$536,633	Capital
22	NYPD	114th Precinct	34-16 Astoria Blvd	Queens		3/30/2012	37.4 kW	18%	43,902 kWh	7%	11 MT CO2	\$1,509	\$4,595	\$409,808	Capital
24	DOE	Q505	160-05 Highland Ave / 87-01 Parsons Blvd	Queens	EJZ	4/6/2016	367.8 kW	27%	431,774 kWh	19%	112 MT CO2	\$14,841	\$36,354	\$1,589,608	Capital
26	FDNY	Transportation Repair Shop	48-67 34th St	Queens		3/27/2012	31.7 kW	4%	37,211 kWh	1%	10 MT CO2	\$1,279	\$3,895	\$393,729	Capital
26	DOE	Q204	36-41 28th St	Queens	EJZ	4/6/2016	159.2 kW	33%	186,887 kWh	28%	49 MT CO2	\$6,424	\$16,946	\$663,398	Capital
26	DOE	Q445	48-10 31st Ave	Queens	EJZ	4/6/2016	199.9 kW	27%	234,621 kWh	18%	61 MT CO2	\$8,064	\$21,275	\$792,584	Capital
28	DOE	Q226	121-10 Rockaway Blvd / 116-30 122 St	Queens	EJZ	4/13/2016	135.9 kW	19%	159,466 kWh	11%	42 MT CO2	\$5,481	\$14,460	\$499,089	Capital
28	DOE	Q072	133-25 Guy R. Brewer Blvd	Queens	EJZ	4/13/2016	248.9 kW	37%	292,110 kWh	32%	76 MT CO2	\$10,040	\$26,488	\$943,255	Capital
31	DSNY	Queens East 13J District Garage	153-67 146th Ave	Queens	EJZ	3/27/2012	49.7 kW	28%	58,340 kWh	12%	15 MT CO2	\$2,005	\$6,107	\$524,323	Capital
31	DOE	Q215	535 BRIAR PLACE	Queens	EJZ	6/1/2018	159.5 kW	33%	187,227 kWh	37%	49 MT CO2	\$6,435	\$16,977	\$2,798,825	Capital
32	DOT	Sunrise Yard	88-20 Pitkin Ave	Queens	EJZ	2/22/2012	49.7 kW	30%	58,340 kWh	27%	15 MT CO2	\$2,005	\$6,107	\$517,382	Capital

# Completed Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Installation date	Installed Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Social Cost of Carbon Value**	Estimated Annual Energy Savings***	Upfront Project Cost	Financing Mechanism
33	DPR	Bushwick Inlet Park Community Center and District Headquarters	86 Kent Ave	Brooklyn		10/1/2013	66.2 kW	32%	77,650 kWh	25%	20 MT CO2	\$2,669	\$7,627	\$264,600	Capital
33	DOE	K380	370 Marcy Ave	Brooklyn	EJZ	3/12/2016	104.3 kW	17%	122,443 kWh	16%	32 MT CO2	\$4,209	\$11,103	\$434,640	Capital
33	BNY	Brooklyn Navy Yard	36 Flushing Ave	Brooklyn		9/26/2016	993.0 kW		1,165,623 kWh		304 MT CO2	\$40,064		Agency Funded	Agency Funded
36	DCLA	Brooklyn Children's Museum	145 Brooklyn Avenue	Brooklyn	EJZ	9/16/2009	26.5 kW	6%	31,107 kWh	2%	8 MT CO2	\$1,069	\$3,256	\$247,283	Capital
36	DOE	K324	800 Gates Ave	Brooklyn	EJZ	9/24/2015	120.8 kW	14%	141,922 kWh	8%	37 MT CO2	\$4,878	\$12,869	\$545,104	Capital
36	DOE	K455	1700 Fulton Street	Brooklyn	EJZ	10/23/2015	505.1 kW	31%	592,883 kWh	17%	154 MT CO2	\$20,378	\$47,978	\$2,114,467	Capital
37	DOE	K302	350 Linwood St	Brooklyn	EJZ	9/22/2015	137.3 kW	24%	161,275 kWh	16%	42 MT CO2	\$5,543	\$14,624	\$616,767	Capital
38	DPR	Red Hook Recreation Center	155 Bay St	Brooklyn	EJZ	11/1/2014	36.6 kW	13%	42,963 kWh	8%	11 MT CO2	\$1,477	\$4,497	\$75,000	Capital
38	EDC	Brooklyn Army Terminal	80 58th St.	Brooklyn		9/9/2013	100.0 kW		117,384 kWh		31 MT CO2	\$4,035	n/a	n/a	Agency Funded
39	DOE	K032	317 Hoyt St	Brooklyn		7/1/2012	47.6 kW	12%	55,875 kWh	9%	15 MT CO2	\$1,921	\$5,849	\$341,670	Capital
42	DOE	K224	755 Wortman Ave	Brooklyn	EJZ	9/24/2015	98.8 kW	17%	116,118 kWh	15%	30 MT CO2	\$3,991	\$11,406	\$449,555	Capital
44	DOE	K505	5800 20th Ave	Brooklyn	EJZ	9/18/2015	362.3 kW	37%	425,329 kWh	31%	111 MT CO2	\$14,619	\$35,811	\$1,516,875	Capital
45	DSNY	Brooklyn South 14 District Garage	1397 Ralph Ave	Brooklyn		3/22/2012	49.7 kW	29%	58,340 kWh	11%	15 MT CO2	\$2,005	\$6,107	\$511,334	Capital
46	DOE	K278	1925 Stuart St	Brooklyn		4/12/2016	120.8 kW	21%	141,922 kWh	18%	37 MT CO2	\$4,878	\$12,869	\$503,268	Capital
46	DOE	K515	6565 Flatlands Ave	Brooklyn	EJZ	4/12/2016	590.2 kW	36%	692,800 kWh	33%	180 MT CO2	\$23,813	\$56,063	\$2,617,082	Capital
49	DOE	R013	191 Vermont Avenue	Staten Island	EJZ	9/1/2005	4.0 kW	1%	4,695 kWh	1%	1 MT CO2	\$161	\$491	\$18,520	Capital

# Completed Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Installation date	Installed Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Social Cost of Carbon Value**	Estimated Annual Energy Savings***	Upfront Project Cost	Financing Mechanism
49	DOE	R014	100 Tompkins Ave	Staten Island	EJZ	12/1/2006	4.0 kW	1%	4,695 kWh	1%	1 MT CO2	\$161	\$491	\$18,520	Capital
49	DOE	R445	85 St. Joseph's Avenue	Staten Island		4/15/2016	120.8 kW	12%	141,776 kWh	8%	37 MT CO2	\$4,873	\$12,856	\$545,104	Capital
49	DOT	St. George Ferry Terminal	1 Bay St.	Staten Island	EJZ	12/30/2014	219.4 kW	15%	257,540 kWh	4%	67 MT CO2	\$8,852	(\$64,829)	\$0	PPA
49	DEP	Port Richmond WWTP	1801 Richmond Ter	Staten Island	EJZ	6/1/2015	1,264.3 kW	21%	1,484,027 kWh	5%	386 MT CO2	\$51,009	(\$379,021)	\$0	PPA
51	FDNY	Engine Co. 168	1100 Rossville Ave	Staten Island	EJZ	3/22/2012	34.6 kW	30%	40,615 kWh	16%	11 MT CO2	\$1,396	\$4,251	\$441,503	Capital
51	DOE	R075	455 Huguenot Avenue	Staten Island		4/15/2016	129.7 kW	15%	152,218 kWh	15%	40 MT CO2	\$5,232	\$13,803	\$568,796	Capital
51	DOE	R069	144 Keating Pl	Staten Island		4/20/2015	203.1 kW	29%	238,442 kWh	36%	62 MT CO2	\$8,196	\$21,621	\$905,386	Capital
51	DOE	R455	100 Luten Ave	Staten Island		4/15/2016	532.5 kW	32%	625,105 kWh	22%	163 MT CO2	\$21,486	\$50,585	\$2,218,953	Capital
51	DOE	R062 - NET ZERO	644 Bloomingdale Road	Staten Island		9/1/2015	600.0 kW	56%	704,304 kWh	87%	183 MT CO2	\$24,208	\$56,994	\$2,778,000	Capital

\*Environmental Justice Zone: as defined by Local Law 64 of 2017, a low-income community or minority community, as determined by U.S. Census Bureau, 2011 – 2015 American Community Survey.

\*\*Estimated Social Cost of Carbon Value: as defined in Local Law 6 of 2016, assigns a dollar value per metric ton (MT) of carbon dioxide equivalent (CO<sub>2</sub>e). For 2018, the social cost of carbon value is \$132 per MT of CO<sub>2</sub>e.

\*\*\*Estimated Annual Energy Savings: updated avoided cost of solar energy (\$/kWh) estimated value per electricity rate Service Classifications, accounting for supply and demand values offset by solar. Analysis conducted by the National Renewable Energy Laboratory (NREL).

# In Progress Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Estimated Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Cost of Carbon Value**	Estimated Annual Energy Savings***	Financing Mechanism
1	DOE	M025	145 Stanton St	Manhattan		147.70 kW	22%	194,400 kWh	16%	51 MT CO2	\$6,682	(\$16,392)	PPA
1	DOE	M020	166 Essex St	Manhattan	EJZ	169.40 kW	59%	223,100 kWh	53%	58 MT CO2	\$7,668	(\$18,812)	PPA
1	DCAS	100 Gold Street	100 Gold Street	Manhattan		259.80 kW	7%	338,300 kWh	3%	88 MT CO2	\$11,628	(\$26,828)	PPA
2	DOE	M188	442 East Houston St	Manhattan	EJZ	109.70 kW	25%	143,100 kWh	19%	37 MT CO2	\$4,919	(\$12,067)	PPA
2	DOE	M064	600 East 6th St	Manhattan	EJZ	153.20 kW	39%	197,700 kWh	28%	51 MT CO2	\$6,795	(\$16,671)	PPA
3	DOE	M440	351 West 18th St	Manhattan		38.60 kW	7%	50,440 kWh	3%	13 MT CO2	\$1,734	(\$3,547)	PPA
4	HHC	Bellevue Hospital (Main Building)	462 First Ave	Manhattan	EJZ	83.50 kW	1%	107,600 kWh	0.2%	28 MT CO2	\$3,698	(\$6,347)	PPA
4	DOE	M167	220 East 76th St	Manhattan		186.00 kW	41%	244,200 kWh	41%	64 MT CO2	\$8,394	(\$20,592)	PPA
5	FDNY	Special Operations Command	750 Main St	Manhattan	EJZ	27.00 kW	26%	31,694 kWh	11%	8 MT CO2	\$1,089	\$3,317	Capital
5	DOE	M645	320 East 96th St	Manhattan		73.20 kW	35%	85,925 kWh	22%	22 MT CO2	\$2,953	\$8,440	Capital
5	HHC	Coler Rehabilitation & Nursing Care Center Bldg A	900 Main St	Manhattan	EJZ	89.40 kW	3%	113,500 kWh	1%	30 MT CO2	\$3,901	(\$6,695)	PPA
5	HHC	Coler Rehabilitation & Nursing Care Center Bldg C	900 Main St	Manhattan	EJZ	138.30 kW	4%	168,700 kWh	2%	44 MT CO2	\$5,799	(\$11,848)	PPA
5	HHC	Coler Rehabilitation & Nursing Care Center Bldg B	900 Main St	Manhattan	EJZ	204.60 kW	7%	244,100 kWh	3%	64 MT CO2	\$8,390	(\$17,143)	PPA
6	DOE	M485	100 Amsterdam Ave	Manhattan	EJZ	150.10 kW	8%	194,800 kWh	4%	51 MT CO2	\$6,696	(\$13,681)	PPA
7	DOE	M028	475 West 155th St	Manhattan	EJZ	155.30 kW	47%	201,600 kWh	36%	52 MT CO2	\$6,929	(\$17,000)	PPA
8	HHC	Metro - OPD Building	1901 First Ave	Manhattan	EJZ	14.40 kW	0.2%	16,903 kWh	0.1%	4 MT CO2	\$581	(\$843)	PPA
8	HHC	Metro - Mental Health Building	1901 First Ave	Manhattan	EJZ	16.90 kW	0.3%	22,150 kWh	0.1%	6 MT CO2	\$761	(\$1,104)	PPA
8	HHC	Metro - Main Building	1901 First Ave	Manhattan	EJZ	34.80 kW	1%	45,950 kWh	0.2%	12 MT CO2	\$1,579	(\$2,291)	PPA
8	DOE	X655	455 Southern Blvd	Bronx	EJZ	101.80 kW	16%	120,800 kWh	12%	31 MT CO2	\$4,152	(\$10,186)	PPA
8	DOE	X018	502 Morris Ave	Bronx	EJZ	150.80 kW	53%	196,700 kWh	37%	51 MT CO2	\$6,761	(\$16,586)	PPA
8	DOE	M206	508 East 120th St	Manhattan	EJZ	161.80 kW	29%	210,000 kWh	25%	55 MT CO2	\$7,218	(\$17,708)	PPA
8	DOE	X139	345 Brook Ave	Bronx	EJZ	230.10 kW	57%	297,000 kWh	40%	77 MT CO2	\$10,208	(\$25,044)	PPA

# In Progress Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Estimated Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Cost of Carbon Value**	Estimated Annual Energy Savings***	Financing Mechanism
9	DOE	M092	222 West 134th St	Manhattan	EJZ	140.40 kW	42%	185,100 kWh	34%	48 MT CO2	\$6,362	(\$15,608)	PPA
9	DOE	M144	134 West 122nd St	Manhattan	EJZ	223.90 kW	88%	292,000 kWh	70%	76 MT CO2	\$10,037	(\$24,622)	PPA
9	DOE	M501	2005 Madison Ave	Manhattan	EJZ	274.60 kW	56%	358,200 kWh	26%	93 MT CO2	\$12,312	(\$32,526)	PPA
10	DOT	Harlem River Bridge Shop	300 West 206th St	Manhattan	EJZ	70.20 kW	48%	82,404 kWh	25%	21 MT CO2	\$2,832	\$8,094	Capital
10	DOE	M143	511 West 182 St	Manhattan	EJZ	88.00 kW	24%	115,100 kWh	16%	30 MT CO2	\$3,956	(\$8,836)	PPA
11	DOE	X007	3201 Kingsbridge Ave	Bronx	EJZ	54.90 kW	14%	71,552 kWh	19%	19 MT CO2	\$2,459	\$7,028	Capital
11	DOE	X094	3530 Kings College Pl	Bronx	EJZ	61.00 kW	27%	79,827 kWh	22%	21 MT CO2	\$2,744	\$7,841	Capital
11	DOE	X024	660 West 236th St	Bronx		192.50 kW	86%	251,300 kWh	56%	65 MT CO2	\$8,638	(\$21,190)	PPA
11	DOE	X440	100 West Mosholu Parkway South	Bronx	EJZ	310.50 kW	46%	375,900 kWh	20%	98 MT CO2	\$12,920	(\$34,133)	PPA
12	DOE	X181	650-850 Baychester Ave	Bronx		562.40 kW	11%	718,000 kWh	6%	187 MT CO2	\$24,679	(\$59,881)	PPA
13	DOT	DOT Bronx Borough Commissioners Office	1400 Willamsbridge Rd	Bronx	EJZ	37.20 kW	33%	43,667 kWh	18%	11 MT CO2	\$1,501	\$4,571	Capital
13	NYPL	Westchester Square Branch Library	2527 Glebe Ave	Bronx	EJZ	39.00 kW	46%	45,780 kWh	23%	12 MT CO2	\$1,574	\$4,792	Capital
13	DOE	X135	2441 Wallace Ave	Bronx	EJZ	152.10 kW	39%	200,500 kWh	30%	52 MT CO2	\$6,892	(\$16,907)	PPA
13	DOE	X415	925 Astor Ave	Bronx	EJZ	198.70 kW	29%	259,900 kWh	16%	68 MT CO2	\$8,933	(\$21,916)	PPA
14	DOE	X117	1865 Morris Ave	Bronx	EJZ	142.10 kW	41%	185,100 kWh	27%	48 MT CO2	\$6,362	(\$15,608)	PPA
14	DOE	X026	1930 Andrews Ave	Bronx	EJZ	171.50 kW	42%	209,300 kWh	26%	55 MT CO2	\$7,194	(\$17,649)	PPA
16	DCAS	Bronx Hall of Justice	265 East 161st St	Bronx	EJZ	139.00 kW	5%	182,800 kWh	2%	48 MT CO2	\$6,283	(\$12,838)	PPA
16	DOE	X166	250 East 164th St	Bronx	EJZ	252.50 kW	51%	306,500 kWh	38%	80 MT CO2	\$10,535	(\$27,831)	PPA
17	DOE	X092	700 East 179th St	Bronx	EJZ	70.20 kW	36%	91,461 kWh	23%	24 MT CO2	\$3,144	\$8,984	Capital
17	CUNY	Hostos Community College: A Building / Allied Health & Sciences Building	450 Grand Concourse	Bronx	EJZ	81.92 kW	2%	96,161 kWh	1%	25 MT CO2	\$3,305	(\$7,382)	PPA
17	DOE	X052	681 Kelly St	Bronx	EJZ	96.90 kW	30%	122,800 kWh	17%	32 MT CO2	\$4,221	(\$9,428)	PPA



# In Progress Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Estimated Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Cost of Carbon Value**	Estimated Annual Energy Savings***	Financing Mechanism
17	DOE	X134	1330 Bristow St	Bronx	EJZ	103.20 kW	38%	136,800 kWh	28%	36 MT CO2	\$4,702	(\$11,535)	PPA
17	CUNY	Hostos Community College: C Building / East Academic Complex	475 Grand Concourse	Bronx	EJZ	305.00 kW	7%	398,200 kWh	3%	104 MT CO2	\$13,687	(\$36,158)	PPA
18	DOE	X125	1111 Pugsley Ave	Bronx	EJZ	204.60 kW	64%	267,200 kWh	43%	70 MT CO2	\$9,184	(\$22,531)	PPA
19	DOE	Q021	147-36 26th Ave	Queens	EJZ	124.20 kW	35%	145,791 kWh	22%	38 MT CO2	\$5,011	(\$12,294)	PPA
19	DOE	Q067	51-60 Marathon Parkway	Queens		128.34 kW	33%	150,669 kWh	27%	39 MT CO2	\$5,179	(\$12,705)	PPA
19	DOE	Q025	34-65 192nd St	Queens	EJZ	213.21 kW	41%	250,274 kWh	30%	65 MT CO2	\$8,602	(\$21,104)	PPA
19	DOE	Q405	32-24 Corp Kennedy St	Queens		456.78 kW	80%	587,748 kWh	42%	153 MT CO2	\$20,202	(\$53,370)	PPA
21	DCLA	Queens Museum (of Art)	Flushing Meadows Corona Park	Queens		93.15 kW	12%	119,858 kWh	5%	31 MT CO2	\$4,120	(\$9,202)	PPA
22	DOE	Q010	45-11 31st Ave	Queens		83.90 kW	38%	110,607 kWh	24%	29 MT CO2	\$3,802	\$10,865	Capital
22	DOE	Q141	37-11 21st Ave	Queens		91.50 kW	37%	117,855 kWh	30%	31 MT CO2	\$4,051	\$11,577	Capital
23	DOE	Q046	64-45 218th St	Queens	EJZ	79.30 kW	28%	102,916 kWh	28%	27 MT CO2	\$3,537	\$10,109	Capital
23	DOE	Q074	61-15 Oceania St	Queens	EJZ	143.52 kW	36%	184,670 kWh	33%	48 MT CO2	\$6,347	(\$15,572)	PPA
23	DOE	Q018	86-35 235th Court	Queens	EJZ	161.46 kW	76%	189,528 kWh	76%	49 MT CO2	\$6,514	(\$15,982)	PPA
24	HHC	Queens Hospital N Building	161-25 Grand Central Pkwy	Queens	EJZ	13.80 kW	0.3%	17,757 kWh	0.1%	5 MT CO2	\$610	(\$1,249)	PPA
24	HHC	Queens Hospital Main Hospital	82-68 164th Street	Queens	EJZ	51.75 kW	1%	66,588 kWh	0.3%	17 MT CO2	\$2,289	(\$5,112)	PPA
24	HHC	Queens Hospital Pavilion	82-50 164th Street	Queens	EJZ	110.72 kW	2%	142,466 kWh	1%	37 MT CO2	\$4,897	(\$12,013)	PPA
24	DOE	Q620	165-65 84TH AVE.	Queens	EJZ	526.80 kW	87%	677,844 kWh	64%	177 MT CO2	\$23,299	(\$63,770)	PPA
25	HHC	Elmhurst Hospital Center - H BLDG	79-01 Broadway	Queens	EJZ	143.36 kW	2%	184,464 kWh	1%	48 MT CO2	\$6,340	(\$12,955)	PPA
26	FDNY	Engine Company 260	11-15 37th Ave	Queens	EJZ	16.00 kW	48%	18,781 kWh	21%	5 MT CO2	\$646	\$1,966	Capital
26	DOE	Q450	28-01 41st Ave	Queens	EJZ	79.30 kW	13%	93,086 kWh	12%	24 MT CO2	\$3,200	\$9,144	Capital
26	DOE	Q600	37-02 47th Ave	Queens	EJZ	97.60 kW	13%	114,567 kWh	6%	30 MT CO2	\$3,938	\$11,254	Capital
27	DOE	Q015	121-15 Lucas St	Queens	EJZ	58.00 kW	20%	76,828 kWh	14%	20 MT CO2	\$2,641	\$7,547	Capital
27	DOE	Q008	108-35 167th St	Queens	EJZ	236.67 kW	67%	277,813 kWh	25%	72 MT CO2	\$9,549	(\$23,426)	PPA

# In Progress Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Estimated Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Cost of Carbon Value**	Estimated Annual Energy Savings***	Financing Mechanism
27	DOE	Q192	109-89 204th St	Queens	EJZ	306.36 kW	97%	394,200 kWh	47%	103 MT CO2	\$13,549	(\$35,795)	PPA
27	DOE	Q490	207-01 116th Ave	Queens	EJZ	386.40 kW	101%	497,189 kWh	42%	129 MT CO2	\$17,089	(\$45,147)	PPA
28	FDNY	Engine Company 302	143-15 Rockaway Blvd	Queens	EJZ	7.00 kW	13%	8,217 kWh	5%	2 MT CO2	\$282	\$860	Capital
29	DOE	Q139	93-06 63rd Drive	Queens	EJZ	82.88 kW	40%	106,643 kWh	24%	28 MT CO2	\$3,666	(\$8,187)	PPA
29	DOE	Q157	63-55 102nd St	Queens		207.00 kW	51%	266,351 kWh	35%	69 MT CO2	\$9,155	(\$22,460)	PPA
30	FDNY	Engine Company 291	56-07 Metropolitan Ave	Queens		5.00 kW	10%	5,869 kWh	4%	2 MT CO2	\$202	\$614	Capital
30	FDNY	EMS 45	58-65 52nd Rd	Queens		97.00 kW	49%	113,862 kWh	16%	30 MT CO2	\$3,914	\$11,185	Capital
30	DOE	Q229	67-25 51st Rd	Queens	EJZ	169.60 kW	34%	218,228 kWh	20%	57 MT CO2	\$7,501	(\$18,402)	PPA
31	DOE	Q183	2-45 Beach 79th St	Queens	EJZ	100.50 kW	56%	129,315 kWh	30%	34 MT CO2	\$4,445	(\$10,904)	PPA
32	QPL	Peninsula (ALC) Community Library	92-25 Rockaway Beach Blvd	Queens		54.90 kW	57%	64,444 kWh	43%	17 MT CO2	\$2,215	\$6,330	Capital
32	QPL	Howard Beach Branch Library	92-06 156th Avenue	Queens		90.00 kW	126%	105,646 kWh	69%	28 MT CO2	\$3,631	\$10,377	Capital
32	DOE	Q210	93-11 101 Ave	Queens	EJZ	246.33 kW	64%	316,958 kWh	35%	83 MT CO2	\$10,894	(\$26,727)	PPA
32	DOE	Q410	100-00 Beach Channel Drive	Queens		695.52 kW	90%	894,939 kWh	46%	233 MT CO2	\$30,761	(\$84,194)	PPA
34	DOE	K196	207 Bushwick Ave	Brooklyn	EJZ	73.20 kW	24%	85,925 kWh	17%	22 MT CO2	\$2,953	\$8,440	Capital
35	DOE	K221	791 Empire Blvd	Brooklyn	EJZ	67.10 kW	24%	78,765 kWh	17%	21 MT CO2	\$2,707	\$7,737	Capital
36	DOE	K044	432 Monroe St	Brooklyn	EJZ	108.00 kW	88%	144,800 kWh	40%	38 MT CO2	\$4,977	(\$12,210)	PPA
36	DOE	K335	130 Rochester Ave	Brooklyn	EJZ	109.40 kW	70%	145,600 kWh	27%	38 MT CO2	\$5,005	(\$12,277)	PPA
36	DOE	K057	125 Stuyvesant Ave	Brooklyn	EJZ	193.00 kW	73%	226,551 kWh	33%	59 MT CO2	\$7,787	\$20,543	Capital
36	DOE	K026	1014 Lafayette Ave	Brooklyn	EJZ	263.20 kW	99%	316,700 kWh	61%	82 MT CO2	\$10,886	(\$28,758)	PPA
37	FDNY	Engine Company 236	998 Liberty Ave	Brooklyn	EJZ	5.00 kW	15%	5,869 kWh	7%	2 MT CO2	\$202	\$614	Capital
37	FDNY	Engine Co. 332 & Ladder Co. 175	165 Bradford St	Brooklyn	EJZ	37.00 kW	65%	43,432 kWh	23%	11 MT CO2	\$1,493	\$4,546	Capital
37	DOE	K214	2944 Pitkin Ave	Brooklyn	EJZ	70.20 kW	30%	82,404 kWh	16%	21 MT CO2	\$2,832	\$8,094	Capital
37	DOE	K298	85 Watkins St	Brooklyn	EJZ	163.20 kW	116%	203,200 kWh	59%	53 MT CO2	\$6,984	(\$17,134)	PPA
38	DOE	K094	5010 6th Ave	Brooklyn	EJZ	64.10 kW	23%	83,789 kWh	15%	22 MT CO2	\$2,880	\$8,230	Capital
38	DOE	K001	309 47th St	Brooklyn	EJZ	93.50 kW	27%	112,600 kWh	18%	29 MT CO2	\$3,870	(\$8,644)	PPA

# In Progress Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Estimated Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Cost of Carbon Value**	Estimated Annual Energy Savings***	Financing Mechanism
39	DOE	K058	330 Smith St	Brooklyn		116.60 kW	42%	154,500 kWh	49%	40 MT CO2	\$5,310	(\$13,028)	PPA
40	HHC	Kings County E Building	541 Clarkson Ave	Brooklyn	EJZ	20.70 kW	0.2%	27,810 kWh	0.1%	7 MT CO2	\$956	(\$1,386)	PPA
40	HHC	Kings County D Building	471 Clarkson Ave	Brooklyn	EJZ	34.20 kW	0.3%	45,670 kWh	0.1%	12 MT CO2	\$1,570	(\$2,277)	PPA
40	HHC	Kings County R Building	410 Winthrop St	Brooklyn	EJZ	67.30 kW	0.5%	87,690 kWh	0.2%	23 MT CO2	\$3,014	(\$5,173)	PPA
40	HHC	Kings County S Building	489 Clarkson Ave	Brooklyn	EJZ	178.70 kW	1%	235,600 kWh	0.4%	61 MT CO2	\$8,098	(\$16,546)	PPA
41	DOE	K235	525 Lenox Rd	Brooklyn	EJZ	67.10 kW	31%	78,765 kWh	15%	21 MT CO2	\$2,707	\$7,737	Capital
41	DOE	K398	60 East 94th St	Brooklyn	EJZ	104.30 kW	36%	105,400 kWh	15%	27 MT CO2	\$3,623	(\$8,888)	PPA
42	DOE	K174	574 Dumont Ave	Brooklyn	EJZ	64.10 kW	47%	83,512 kWh	28%	22 MT CO2	\$2,870	\$8,203	Capital
42	DOE	K273	923 Jerome St	Brooklyn	EJZ	144.60 kW	116%	190,200 kWh	68%	50 MT CO2	\$6,537	(\$16,038)	PPA
42	DOE	K041	411 Thatford Ave	Brooklyn	EJZ	218.00 kW	99%	288,300 kWh	63%	75 MT CO2	\$9,909	(\$24,310)	PPA
42	DOE	K166	800 Van Sicklen Ave	Brooklyn	EJZ	252.50 kW	65%	306,500 kWh	34%	80 MT CO2	\$10,535	(\$27,831)	PPA
43	DOE	K445	1601 80th St	Brooklyn	EJZ	141.50 kW	15%	183,900 kWh	9%	48 MT CO2	\$6,321	(\$15,507)	PPA
45	FDNY	EMS 58	420 East 83rd St	Brooklyn		66.00 kW	84%	77,473 kWh	27%	20 MT CO2	\$2,663	\$7,610	Capital
45	DOE	K152	2310 Glenwood Road	Brooklyn	EJZ	70.00 kW	12%	87,160 kWh	6%	23 MT CO2	\$2,996	(\$6,691)	PPA
45	DOE	K269	1957 Nostrand Ave	Brooklyn	EJZ	121.10 kW	52%	160,600 kWh	34%	42 MT CO2	\$5,520	(\$13,542)	PPA
46	FDNY	Engine Company 309	1851 East 48th St	Brooklyn	EJZ	15.00 kW	40%	17,608 kWh	14%	5 MT CO2	\$605	\$1,843	Capital
46	BPL	Gerritsen Beach Branch Library	2808 Gerritsen Ave	Brooklyn		20.00 kW	23%	23,477 kWh	15%	6 MT CO2	\$807	\$2,457	Capital
46	BPL	Mill Basin	2385 Ralph Ave	Brooklyn	EJZ	20.00 kW	28%	23,477 kWh	22%	6 MT CO2	\$807	\$2,457	Capital
46	DOE	K115	1500 East 92nd St	Brooklyn	EJZ	131.80 kW	19%	160,200 kWh	17%	42 MT CO2	\$5,506	(\$13,509)	PPA
46	DOE	K251	1037 East 54th St	Brooklyn	EJZ	191.80 kW	80%	254,400 kWh	65%	66 MT CO2	\$8,744	(\$21,452)	PPA
47	FDNY	Engine Company 254	901 Avenue U	Brooklyn		9.00 kW	19%	10,565 kWh	8%	3 MT CO2	\$363	\$1,106	Capital
47	BPL	Coney Island Branch Library and Learning Ctr.	1901 Mermaid Ave	Brooklyn	EJZ	20.00 kW	28%	23,477 kWh	13%	6 MT CO2	\$807	\$2,457	Capital
47	DOE	K329	2929 West 30th St	Brooklyn	EJZ	143.90 kW	49%	191,100 kWh	38%	50 MT CO2	\$6,568	(\$16,114)	PPA
48	BPL	Kings Highway Branch Library	2115 Ocean Ave	Brooklyn	EJZ	4.05 kW	2%	4,754 kWh	1%	1 MT CO2	\$163	\$498	Capital

# In Progress Installations

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Estimated Capacity	Percentage of Max Peak Demand	Estimated Annual Production	Percentage of Annual Electricity Consumption	Estimated Annual Emissions Reduction	Estimated Cost of Carbon Value**	Estimated Annual Energy Savings***	Financing Mechanism
48	DOE	K234	1875 East 17th St	Brooklyn		142.10 kW	36%	189,700 kWh	23%	49 MT CO2	\$6,520	(\$15,996)	PPA
48	DOE	K425	3787 Bedford Ave	Brooklyn		153.90 kW	33%	203,700 kWh	13%	53 MT CO2	\$7,002	(\$17,177)	PPA
48	DOE	K014	2424 Batchelder St	Brooklyn		174.60 kW	45%	233,600 kWh	39%	61 MT CO2	\$8,029	(\$19,698)	PPA
48	DOE	K043	1401 Emmons Ave	Brooklyn		221.10 kW	44%	274,900 kWh	31%	72 MT CO2	\$9,449	(\$23,180)	PPA
48	CUNY	Kingsborough Community College: P-Central Services	2007 Oriental Blvd	Brooklyn		236.30 kW	3%	313,900 kWh	1%	82 MT CO2	\$10,789	(\$26,469)	PPA
48	DOE	K495	3000 Ave X	Brooklyn		513.70 kW	92%	651,100 kWh	44%	170 MT CO2	\$22,379	(\$61,254)	PPA
49	DOE	R045	58 Lawrence Ave	Staten Island		104.70 kW	33%	122,901 kWh	21%	32 MT CO2	\$4,224	\$11,144	Capital
50	DPR	Ocean Breeze	625 Father Capodanno Blvd	Staten Island	EJZ	864.60 kW	105%	1,144,000 kWh	33%	298 MT CO2	\$39,321	(\$110,096)	PPA
51	DOE	R003	80 South Goff Ave	Staten Island		223.90 kW	95%	295,300 kWh	66%	77 MT CO2	\$10,150	(\$24,901)	PPA
51	DOE	R007	1270 Huguenot Ave	Staten Island		253.60 kW	69%	336,200 kWh	64%	88 MT CO2	\$11,556	(\$30,528)	PPA

\* Environmental Justice Zone: as defined by Local Law 64 of 2017, a low-income community or minority community, as determined by U.S. Census Bureau, 2011 – 2015 American Community Survey.

\*\*Estimated Social Cost of Carbon Value: as defined in Local Law 6 of 2016, assigns a dollar value per metric ton (MT) of carbon dioxide equivalent (CO<sub>2</sub>e). For 2018, the social cost of carbon value is \$132 per MT of CO<sub>2</sub>e.

\*\*\*Estimated Annual Energy Savings: updated avoided cost of solar energy (\$/kWh) estimated value per electricity rate Service Classifications, accounting for supply and demand values offset by solar. Analysis conducted by the National Renewable Energy Laboratory (NREL).

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
1	CUNY	BMCC Fiterman Hall	245 Greenwich St	Manhattan			0.61 kW	716 kWh	0.2 MT CO2
1	NYPL	Chatham Square Branch Library	33 East Broadway	Manhattan	EJZ		1.83 kW	2,148 kWh	1 MT CO2
1	NYPD	5th Precinct	19 Elizabeth St	Manhattan	EJZ		3.05 kW	3,580 kWh	1 MT CO2
1	DOE	M477	345 CHAMBERS ST.	Manhattan			12.20 kW	14,321 kWh	4 MT CO2
1	DCAS	Court Square Building	2 Lafayette St	Manhattan			14.60 kW	17,142 kWh	4 MT CO2
1	DOE	M520	411 PEARL ST	Manhattan	EJZ		18.90 kW	22,186 kWh	6 MT CO2
1	DOE	M445	350 GRAND ST.	Manhattan	EJZ	Yes	40.60 kW	51,015 kWh	13 MT CO2
1	DHS	Catherine Life Family Shelter	78 Catherine St	Manhattan	EJZ		48.80 kW	57,283 kWh	15 MT CO2
1	CUNY	BMCC Auditorium	199 Chambers St	Manhattan			51.90 kW	139,301 kWh	36 MT CO2
2	DHS	George Daly House Residence	269 East 4th St	Manhattan	EJZ		6.10 kW	7,160 kWh	2 MT CO2
2	DOE	M844	400 1ST AVENUE	Manhattan			7.30 kW	8,569 kWh	2 MT CO2
2	DHS	Kenton Hotel Shelter	333 Bowery	Manhattan	EJZ		18.30 kW	21,481 kWh	6 MT CO2
2	DHS	Manhattan Bowery Shelter	8 East 3rd St	Manhattan	EJZ		21.40 kW	25,120 kWh	7 MT CO2
2	DOE	M015	333 EAST 4 STREET	Manhattan	EJZ		43.30 kW	50,827 kWh	13 MT CO2
2	DOE	M060	420 EAST 12 STREET	Manhattan			62.10 kW	82,921 kWh	22 MT CO2
3	DOE	M011	320 WEST 21 STREET	Manhattan			0.00 kW	0 kWh	0 MT CO2
3	DOE	M035	317 WEST 52 STREET	Manhattan			0.00 kW	0 kWh	0 MT CO2
3	DPR	Chelsea Recreation Center	430 West 25th St	Manhattan			0.00 kW	0 kWh	0 MT CO2
3	DSNY	Manhattan Community Districts 1, 2 and 5	353 Spring St	Manhattan			0.00 kW	0 kWh	0 MT CO2
3	DPR	High Line Maintenance and Operations Building	820 Washington St	Manhattan			1.53 kW	1,796 kWh	0.5 MT CO2
3	NYPL	Muhlenberg Branch Library	209 West 23rd St	Manhattan	EJZ		8.20 kW	9,625 kWh	3 MT CO2
3	DPR	Tony Dapolito Recreation Center	3 Clarkson St	Manhattan			11.00 kW	12,912 kWh	3 MT CO2
3	DOE	M600	225 W. 24 STREET	Manhattan			91.50 kW	107,406 kWh	28 MT CO2
4	DCLA	Carnegie Hall	881 7th Ave	Manhattan			0.00 kW	0 kWh	0 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
4	DCLA	New York City Center	131 W 55 St.	Manhattan			0.00 kW	0 kWh	0 MT CO2
4	NYPL	96th Street Branch Library	112 East 96th St	Manhattan			2.44 kW	2,864 kWh	1 MT CO2
4	DCLA	The Met Breuer	945 Madison Avenue	Manhattan			15.30 kW	17,964 kWh	5 MT CO2
4	DPR	Recreation Center 54	348 East 54th St	Manhattan			36.60 kW	42,963 kWh	11 MT CO2
4	NYPL	Central Library - Stephen A. Schwartzman Building	476 5th Ave	Manhattan			250.10 kW	293,577 kWh	76 MT CO2
5	DOE	M151	1763 1ST AVENUE	Manhattan			0.00 kW	0 kWh	0 MT CO2
5	DOE	M816	323 East 91st St	Manhattan			0.00 kW	0 kWh	0 MT CO2
5	DCLA	Metropolitan Museum of Art Storage	438-440 East 91st St	Manhattan			1.22 kW	1,432 kWh	0.4 MT CO2
5	DOE	M114	331 EAST 91ST STREET	Manhattan			24.40 kW	28,642 kWh	7 MT CO2
5	DOE	M271	645 MAIN ST.	Manhattan			58.90 kW	69,139 kWh	18 MT CO2
5	DOE	M158	1458 YORK AVENUE	Manhattan			116.00 kW	133,042 kWh	35 MT CO2
6	DOE	M166	132 WEST 89 STREET	Manhattan			15.60 kW	18,312 kWh	5 MT CO2
6	DCLA	Samuel B. & David Rose Building	70 Lincoln Center Plz	Manhattan			22.00 kW	25,830 kWh	7 MT CO2
6	NYPD	22nd Precinct	190 86th St Transverse Rd	Manhattan	EJZ		24.40 kW	28,642 kWh	7 MT CO2
6	DOE	M191	210 WEST 61 STREET	Manhattan			51.90 kW	60,922 kWh	16 MT CO2
6	DOE	M075	735 WEST END AVENUE	Manhattan			85.40 kW	100,246 kWh	26 MT CO2
6	DCLA	Metropolitan Opera House	Lincoln Center Plaza	Manhattan			157.40 kW	184,805 kWh	48 MT CO2
6	DSNY	Manhattan 4, 4A, 7 District Garage; Salt	650 West 57th St	Manhattan		Yes	398.00 kW	426,367 kWh	111 MT CO2
7	NYPD	Shop 9	675 West 158th St	Manhattan	EJZ		0.00 kW	0 kWh	0 MT CO2
7	DOE	M004	500 WEST 160 STREET	Manhattan	EJZ		26.00 kW	34,266 kWh	9 MT CO2
7	HHC	Lower Washington Heights NFCC Clinic	1721 Amsterdam Ave	Manhattan	EJZ		52.80 kW	61,979 kWh	16 MT CO2
7	DOE	M036	123 MORNINGSIDE DRIVE	Manhattan	EJZ		102.50 kW	137,395 kWh	36 MT CO2
7	DOE	M145	150 WEST 105 STREET	Manhattan	EJZ	Yes	115.80 kW	143,985 kWh	37 MT CO2
8	DOE	M171	19 EAST 103 STREET	Manhattan			0.00 kW	0 kWh	0 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
8	DOE	M646	321 E. 96 ST.	Manhattan	EJZ		0.00 kW	0 kWh	0 MT CO2
8	DPR	Mill Pond Park Power House	1 East 150th Street	Bronx	EJZ		0.00 kW	0 kWh	0 MT CO2
8	DHS	Jennie A. Clarke Residence	179 East 100th St	Manhattan	EJZ		3.05 kW	3,580 kWh	1 MT CO2
8	NYPL	125th Street Branch Library	224 East 125th St	Manhattan	EJZ		6.10 kW	7,160 kWh	2 MT CO2
8	DHS	Jackson Family Residence	691 East 138th St	Bronx	EJZ		12.20 kW	14,321 kWh	4 MT CO2
8	NYPD	Randall's Island Street Crime Unit	1 Randall's Island	Manhattan	EJZ		13.30 kW	17,646 kWh	5 MT CO2
8	DHS	Emergency Assistance Unit (EAU)	151 East 151st St	Bronx	EJZ		18.30 kW	21,481 kWh	6 MT CO2
8	DFTA	Leonardo Coverio Senior Center	312 East 109th St	Manhattan	EJZ		21.40 kW	25,120 kWh	7 MT CO2
8	DPR	Thomas Jefferson Recreation Center	2180 1st Ave	Manhattan			27.50 kW	32,281 kWh	8 MT CO2
8	DPR	St. Mary's Recreation Center and Indoor Pool	450 St Anns Ave	Bronx	EJZ		36.60 kW	42,963 kWh	11 MT CO2
8	DHS	University Avenue Family Residences	1041 University Ave	Bronx	EJZ		42.70 kW	50,123 kWh	13 MT CO2
8	DOE	M099	410 EAST 100 STREET	Manhattan	EJZ		73.20 kW	85,925 kWh	22 MT CO2
8	DOE	M117	240 EAST 109 STREET	Manhattan	EJZ	Yes	245.20 kW	270,578 kWh	70 MT CO2
9	DPR	Marcus Garvey Park Pool	124th St at 5th Ave	Manhattan			0.00 kW	0 kWh	0 MT CO2
9	NYPL	Schomburg Center/Research in Black Culture	515 Malcolm X Blvd	Manhattan	EJZ		6.10 kW	7,160 kWh	2 MT CO2
9	DHS	East 119th Street Veterans Residence	22 East 119th St	Manhattan	EJZ		12.20 kW	14,321 kWh	4 MT CO2
9	NYPL	Schomburg Black History Library	103 West 135th St	Manhattan	EJZ		12.20 kW	14,321 kWh	4 MT CO2
9	DPR	Hansborough Pool and Recreation Center	35 West 134th St	Manhattan	EJZ		14.00 kW	16,434 kWh	4 MT CO2
9	HHC	Henry J. Carter Hospital	1879 Madison Ave	Manhattan	EJZ		25.60 kW	30,050 kWh	8 MT CO2
9	DOE	M081	212 W. 120TH ST	Manhattan	EJZ	Yes	55.40 kW	68,778 kWh	18 MT CO2
9	DOE	M197	2230 5TH AVENUE	Manhattan			85.40 kW	100,246 kWh	26 MT CO2
9	DOE	M136	6 EDGECOMBE AVENUE	Manhattan	EJZ		94.60 kW	111,045 kWh	29 MT CO2
9	DOE	M079	55 EAST 120 STREET	Manhattan	EJZ	Yes	118.60 kW	139,217 kWh	36 MT CO2
9	DOE	M123	301 WEST 140 STREET	Manhattan	EJZ	Yes	137.30 kW	161,168 kWh	42 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
9	DOE	M208	20 WEST 112 STREET	Manhattan	EJZ		186.60 kW	250,335 kWh	65 MT CO2
9	DOE	M175	175 WEST 134 STREET	Manhattan	EJZ		232.00 kW	310,768 kWh	81 MT CO2
10	DOE	M528	180 WADSWORTH AVENUE	Manhattan	EJZ		0.00 kW	0 kWh	0 MT CO2
10	DOE	M263	202 SHERMAN AVENUE	Manhattan	EJZ		3.05 kW	3,580 kWh	1 MT CO2
10	DPR	J Hood Wright Park Recreation Center	351 Fort Washington Ave	Manhattan	EJZ		11.60 kW	13,617 kWh	4 MT CO2
10	DOE	M876	2120 AMSTERDAM AVE.	Manhattan	EJZ		13.70 kW	16,082 kWh	4 MT CO2
10	DOE	M005	3703 10TH AVE.	Manhattan	EJZ		15.30 kW	17,960 kWh	5 MT CO2
10	DOE	M178	12-18 ELLWOOD STREET	Manhattan	EJZ	Yes	23.70 kW	28,412 kWh	7 MT CO2
10	DPR	Highbridge Recreation Center	2275 Amsterdam Ave	Manhattan			42.70 kW	50,123 kWh	13 MT CO2
10	DOE	M128	560 WEST 169 STREET	Manhattan	EJZ	Yes	105.90 kW	122,856 kWh	32 MT CO2
11	NYPL	Kingsbridge Library	291 West 231 St	Bronx	EJZ		0.00 kW	0 kWh	0 MT CO2
11	NYPD	52nd Precinct	3016 Webster Ave	Bronx	EJZ		12.20 kW	14,321 kWh	4 MT CO2
11	DOE	X056	341 EAST 207 STREET	Bronx	EJZ		37.70 kW	49,826 kWh	13 MT CO2
11	DOE	X095	3961 HILLMAN AVENUE	Bronx	EJZ		90.90 kW	106,702 kWh	28 MT CO2
12	NYPL	Wakefield Branch Library	4100 Lowerre Pl	Bronx	EJZ		12.20 kW	14,321 kWh	4 MT CO2
12	DOE	X169	3500 EDSON AVENUE	Bronx	EJZ		22.00 kW	25,824 kWh	7 MT CO2
12	DOE	X103	4125 CARPENTER AVENUE	Bronx	EJZ		63.70 kW	86,156 kWh	22 MT CO2
12	DOE	X087	1935 BUSSING AVENUE	Bronx	EJZ		74.10 kW	86,982 kWh	23 MT CO2
12	DOE	X112	1925 SCHIEFELIN AVENUE	Bronx	EJZ	Yes	93.80 kW	106,376 kWh	28 MT CO2
12	DOE	X021	715 EAST 225 STREET	Bronx	EJZ	Yes	98.90 kW	121,324 kWh	32 MT CO2
13	DOE	X498	1640 BRONXDALE AVE.	Bronx			23.20 kW	27,233 kWh	7 MT CO2
13	DOE	X014	3041 BRUCKNER BOULEVARD	Bronx			51.90 kW	60,922 kWh	16 MT CO2
13	DOE	X097	1375 MACE AVENUE	Bronx			57.00 kW	66,909 kWh	17 MT CO2
13	DOE	X072	2951 DEWEY AVENUE	Bronx		Yes	108.00 kW	126,775 kWh	33 MT CO2



# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
13	DOE	X121	2750 THROOP AVENUE	Bronx	EJZ	Yes	109.82 kW	128,911 kWh	34 MT CO2
13	DOE	X089	980 MACE AVENUE	Bronx	EJZ	Yes	131.80 kW	162,708 kWh	42 MT CO2
13	DCAS	Public Safety Answering Center II	350 Marconi St	Bronx	EJZ		154.40 kW	209,193 kWh	54 MT CO2
14	CUNY	South Hall	187 W 180th St	Bronx			0.00 kW	0 kWh	0 MT CO2
14	DHS	Mount Eden Avenue SRO Residence	50 Mt Eden Ave West	Bronx	EJZ		0.00 kW	0 kWh	0 MT CO2
14	DOE	X204	1780 DR. MARTIN LUTHER KING JR.	Bronx	EJZ		0.00 kW	0 kWh	0 MT CO2
14	DOE	X360	2880 KINGSBRIDGE TERRACE	Bronx	EJZ		0.00 kW	0 kWh	0 MT CO2
14	DPR	St. James Park Recreation Center	West 192nd St at Jerome Ave	Bronx	EJZ		1.22 kW	1,432 kWh	0.4 MT CO2
14	CUNY	The Children's Center	2010 Sedgwick Ave	Bronx			3.05 kW	3,995 kWh	1 MT CO2
14	DPR	Kingsbridge Recreation Center	3101 Kings Bridge Ter	Bronx	EJZ		9.15 kW	10,741 kWh	3 MT CO2
14	DOE	X115	120 EAST 184 STREET	Bronx	EJZ		39.00 kW	50,607 kWh	13 MT CO2
14	DHS	Nelson Ave Family Residence	1605 Nelson Ave	Bronx	EJZ		39.70 kW	46,601 kWh	12 MT CO2
14	DOE	X240	1509-1531 JEROME AVE.	Bronx	EJZ		52.50 kW	61,627 kWh	16 MT CO2
14	CUNY	North Hall and Library	200 Hall of Fame Ter	Bronx			76.30 kW	94,574 kWh	25 MT CO2
14	DOE	X143	120 WEST 231 STREET	Bronx	EJZ		197.60 kW	248,355 kWh	65 MT CO2
15	DCLA	Garden Cafe & Terrace Room	2700 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ		0.00 kW	0 kWh	0 MT CO2
15	DCLA	Madagascar (Old Lion House)	2300 Southern Blvd	Bronx	EJZ		0.00 kW	0 kWh	0 MT CO2
15	DCLA	Reptile House	2300 Southern Blvd	Bronx	EJZ		0.00 kW	0 kWh	0 MT CO2
15	DCLA	Shelter Bldg (Elephant, Rhino, Tiger)	2300 Southern Blvd	Bronx	EJZ		0.00 kW	0 kWh	0 MT CO2
15	FDNY	Bronx Central Office	1129 East 180th St	Bronx	EJZ		1.83 kW	2,148 kWh	1 MT CO2
15	DCLA	World of Birds	2300 Southern Blvd	Bronx	EJZ		5.50 kW	6,458 kWh	2 MT CO2
15	DCLA	Stone Mill	2650 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ		20.40 kW	23,952 kWh	6 MT CO2
15	DOE	X465	4143 3RD AVENUE	Bronx	EJZ		21.40 kW	25,120 kWh	7 MT CO2
15	DCLA	Center for Global Conservation	2300 Southern Blvd	Bronx	EJZ		28.10 kW	32,992 kWh	9 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
15	DOE	X058	459 East 176th Street	Bronx	EJZ	Yes	58.20 kW	69,973 kWh	18 MT CO2
15	DOE	X254	2452 WASHINGTON AVE.	Bronx	EJZ		63.10 kW	87,749 kWh	23 MT CO2
15	DOE	X028	1861 ANTHONY AVENUE	Bronx	EJZ	Yes	72.00 kW	86,799 kWh	23 MT CO2
15	DOE	X205	2475 SOUTHERN BOULEVARD	Bronx	EJZ	Yes	76.50 kW	92,103 kWh	24 MT CO2
15	DCLA	LuEsther T. Mertz Library (Museum Building)	2674 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ		148.50 kW	174,355 kWh	45 MT CO2
16	DPR	Mullaly Park Rink and Rec Center	East 164th St at Jerome Ave	Bronx			3.97 kW	4,660 kWh	1 MT CO2
16	FDNY	Rescue 3	1655 Washington Ave	Bronx	EJZ		6.10 kW	7,160 kWh	2 MT CO2
16	NYPL	High Bridge Branch Library	78 West 168th St	Bronx	EJZ		21.40 kW	25,120 kWh	7 MT CO2
16	DOE	X011	1257 OGDEN AVENUE	Bronx	EJZ	Yes	65.00 kW	78,270 kWh	20 MT CO2
16	DOE	X002	1365 FULTON AVENUE	Bronx	EJZ		124.80 kW	166,800 kWh	43 MT CO2
16	DOE	X126	175 WEST 166 STREET	Bronx	EJZ		148.50 kW	174,315 kWh	45 MT CO2
16	DOE	X147	1600 WEBSTER AVENUE	Bronx	EJZ	Yes	150.28 kW	176,405 kWh	46 MT CO2
16	DOE	X148	3630 THIRD AVENUE	Bronx	EJZ	Yes	260.20 kW	304,992 kWh	79 MT CO2
16	DOE	X136	750 JENNINGS STREET	Bronx	EJZ	Yes	266.40 kW	292,845 kWh	76 MT CO2
17	DOE	X392	928 SIMPSON STREET	Bronx	EJZ		6.10 kW	7,160 kWh	2 MT CO2
17	DHS	Freeman Houses Residence	999 Freeman St	Bronx	EJZ		13.00 kW	17,434 kWh	5 MT CO2
17	DOE	X060	888 REVEREND JAMES A. POLITE AVE	Bronx	EJZ	Yes	22.40 kW	25,093 kWh	7 MT CO2
17	DOE	X099	1180 REVEREND JAMES A POLITE AVE	Bronx	EJZ	Yes	27.50 kW	32,818 kWh	9 MT CO2
17	CUNY	Hostos CC B Building	500 Grand Concourse	Bronx	EJZ		30.50 kW	40,243 kWh	10 MT CO2
17	DPR	Crotona Park Pool and Bathhouse	East 173rd St at Fulton Ave	Bronx			51.90 kW	60,922 kWh	16 MT CO2
17	DOE	X050	1550 VYSE AVENUE	Bronx	EJZ		54.00 kW	71,123 kWh	19 MT CO2
17	DEP	1270 Ryawa Ave	Hunts Point WPCP	Bronx	EJZ		62.50 kW	73,382 kWh	19 MT CO2
17	DOE	X039	965 LONGWOOD AVENUE	Bronx	EJZ	Yes	73.00 kW	86,805 kWh	23 MT CO2
17	DSNY	Section Station 92, Bronx Enforcement	1787 West Farms Rd	Bronx	EJZ		74.40 kW	100,974 kWh	26 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
17	DOE	X098	1619 BOSTON ROAD	Bronx	EJZ	Yes	75.50 kW	84,599 kWh	22 MT CO2
17	DOE	X066	1001 JENNINGS STREET	Bronx	EJZ		82.90 kW	109,931 kWh	29 MT CO2
17	DOE	X140	916 EAGLE AVENUE	Bronx	EJZ		107.30 kW	143,142 kWh	37 MT CO2
17	DOE	X130	750 PROSPECT AVENUE	Bronx	EJZ		163.20 kW	219,718 kWh	57 MT CO2
17	DOE	X790	730 CONCOURSE VILLAGE WEST	Bronx			205.60 kW	241,342 kWh	63 MT CO2
17	DOE	X074	730 BRYANT AVENUE	Bronx	EJZ		326.30 kW	430,435 kWh	112 MT CO2
18	FDNY	EMS 3	501 Zerega Ave	Bronx			0.00 kW	0 kWh	0 MT CO2
18	DHS	Commonwealth Avenue SRO Residence	1150 Commonwealth Ave	Bronx	EJZ		1.53 kW	1,796 kWh	0.5 MT CO2
18	NYPL	Soundview Branch Library	660 Soundview Ave	Bronx	EJZ		21.40 kW	25,120 kWh	7 MT CO2
18	DOE	X047	1794 EAST 172 STREET	Bronx	EJZ		57.60 kW	67,613 kWh	18 MT CO2
18	DOE	X036	1070 CASTLE HILL AVENUE	Bronx	EJZ		76.70 kW	104,555 kWh	27 MT CO2
18	DOE	X100	800 TAYLOR AVENUE	Bronx	EJZ	Yes	134.40 kW	165,629 kWh	43 MT CO2
18	DOE	X102	1827 ARCHER STREET	Bronx	EJZ		163.00 kW	191,336 kWh	50 MT CO2
18	DOE	X450	1980 LAFAYETTE AVE.	Bronx	EJZ	Yes	424.13 kW	698,036 kWh	182 MT CO2
19	DSNY	North Shore Marine Transfer Station	119-01 31st Ave	Queens		Yes	0.00 kW	0 kWh	0 MT CO2
19	FDNY	Building 413	413 Shore Rd	Queens			0.00 kW	0 kWh	0 MT CO2
19	NYPD	620 Circle Drive	620 Circle Drive	Queens			3.05 kW	3,580 kWh	1 MT CO2
19	DOE	Q094	41-77 LITTLE NECK PKWY	Queens			44.20 kW	51,884 kWh	14 MT CO2
19	QPL	Bayside Community Library	214-20 Northern Blvd	Queens			46.10 kW	54,114 kWh	14 MT CO2
19	DOE	Q130	200-01 42 AVENUE	Queens			72.50 kW	97,462 kWh	25 MT CO2
19	DOE	Q184	163-15 21 ROAD	Queens		Yes	140.20 kW	172,916 kWh	45 MT CO2
19	DOE	Q185	147-26 25 DRIVE	Queens	EJZ	Yes	242.90 kW	299,743 kWh	78 MT CO2
19	NYPD	Police Academy	130-30 28th Ave	Queens			393.60 kW	462,023 kWh	120 MT CO2
20	DOE	Q244	137-20 FRANKLIN AVE.	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
20	NYPD	Flushing Armory (Queens North Task Force)	137-58 Northern Blvd	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2
20	DOE	Q162	201-02 53 AVENUE	Queens	EJZ		104.30 kW	108,738 kWh	28 MT CO2
20	DPR	Al Oerter Recreation Center	131-40 Fowler Ave	Queens			119.00 kW	139,687 kWh	36 MT CO2
20	DOE	Q020	142-30 BARCLAY AVENUE	Queens	EJZ		210.30 kW	277,269 kWh	72 MT CO2
21	DPR	FMCP Aquatic Center	131-00 Avery Ave	Queens			0.00 kW	0 kWh	0 MT CO2
21	DOE	Q292	99-01 34th Ave	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2
21	DPR	Olmsted Center Campus: FMCP Garage	12 Olmsted Dr	Queens			28.30 kW	39,966 kWh	10 MT CO2
21	QPL	East Elmhurst Community Library	95-06 Astoria Blvd	Queens	EJZ		33.50 kW	45,004 kWh	12 MT CO2
21	DOE	Q014	107-01 OTIS AVENUE	Queens	EJZ		68.30 kW	91,451 kWh	24 MT CO2
21	DOE	Q019	98-02 ROOSEVELT AVE.	Queens	EJZ	Yes	68.50 kW	83,843 kWh	22 MT CO2
21	DOE	Q227	32-02 JUNCTION BLVD	Queens	EJZ	Yes	143.30 kW	168,211 kWh	44 MT CO2
21	DPR	Olmsted Center	Flushing Meadows-Corona Park	Queens			260.80 kW	306,137 kWh	80 MT CO2
22	DOE	Q151	50-05 31 AVENUE	Queens			87.80 kW	116,108 kWh	30 MT CO2
22	DOC	Rikers Island New Central Warehouse	15-15 Hazen Street	Bronx			88.50 kW	103,885 kWh	27 MT CO2
22	DOC	800 Bed Addition	16-16 Hazen St	Queens			97.00 kW	113,862 kWh	30 MT CO2
22	DOE	Q171	14-14 29 AVENUE	Queens	EJZ	Yes	148.50 kW	177,546 kWh	46 MT CO2
22	DOE	Q126	31-51 21 STREET	Queens		Yes	160.00 kW	179,235 kWh	47 MT CO2
23	DOE	Q035	191-02 90 AVENUE	Queens	EJZ		81.90 kW	108,414 kWh	28 MT CO2
23	DOE	Q033	91-37 222 STREET	Queens	EJZ		83.60 kW	98,133 kWh	26 MT CO2
23	QPL	Glen Oaks Community Library	256-04 Union Tpke	Queens	EJZ		106.80 kW	125,366 kWh	33 MT CO2
23	DOE	Q115	80-51 261 STREET	Queens		Yes	133.90 kW	157,177 kWh	41 MT CO2
23	DOE	Q213	231-02 67 AVENUE	Queens	EJZ	Yes	145.00 kW	176,892 kWh	46 MT CO2
23	DOE	Q178	189-10 RADNOR ROAD	Queens		Yes	149.10 kW	180,978 kWh	47 MT CO2
23	NYPD	Old 107th Precinct	186-01 73rd Ave	Queens	EJZ		164.70 kW	193,331 kWh	50 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
23	DOE	Q135	207-11 89 AVENUE	Queens	EJZ		173.60 kW	229,883 kWh	60 MT CO2
23	DOE	Q435	230-17 HILLSIDE AVENUE	Queens	EJZ		473.00 kW	635,210 kWh	165 MT CO2
24	DOE	Q131	170-45 84 AVENUE	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2
24	DOE	Q515	149-11 MELBOURNE AVENUE	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2
24	DOE	Q695	160-20 GOETHALS AVENUE	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2
24	FDNY	EMS 50	159-10 Goethals Ave	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2
24	DHS	Briarwood Residence	80-20 134th St	Queens	EJZ		6.10 kW	7,160 kWh	2 MT CO2
24	NYPD	107th Precinct	71-01 Parsons Blvd	Queens	EJZ		9.15 kW	10,741 kWh	3 MT CO2
25	HHC	Women's Health Pavilion	78-20 41st Ave	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2
25	QPL	Elmhurst (ALC) Community Library	85-08 51st Ave	Queens	EJZ		9.15 kW	10,741 kWh	3 MT CO2
25	DOE	Q102	55-24 VAN HORN STREET	Queens	EJZ		38.70 kW	48,184 kWh	13 MT CO2
25	HHC	Hope Pavilion	77-04 41st Ave	Queens			42.70 kW	50,123 kWh	13 MT CO2
25	DOE	Q089	85-28 BRITTON AVENUE	Queens	EJZ		46.80 kW	59,918 kWh	16 MT CO2
25	DOE	Q007	80-55 Cornish Ave	Queens	EJZ		52.10 kW	58,935 kWh	15 MT CO2
25	DOE	Q280	34-20 94TH STREET	Queens	EJZ		77.40 kW	101,936 kWh	27 MT CO2
26	DOE	Q570	35-12 35TH AVENUE	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2
26	QPL	Broadway Community Library	40-20 Broadway	Queens	EJZ		3.05 kW	3,580 kWh	1 MT CO2
26	DCLA	Museum of the Moving Image	36-01 35th Ave	Queens			30.50 kW	35,810 kWh	9 MT CO2
26	NYPD	Central Motor Repair Shop	53-15 58th St	Queens			106.80 kW	125,366 kWh	33 MT CO2
26	FDNY	Engine Co. 259 and Ladder Co. 128, Batt. 45	33-51 Greenpoint Ave	Queens	EJZ		131.20 kW	154,008 kWh	40 MT CO2
26	CUNY	C - Center 3 Building	29-10 Thomson Ave	Queens			143.40 kW	186,149 kWh	48 MT CO2
26	DHS	Borden Avenue Shelter	21-10 Borden Ave	Queens			298.90 kW	350,861 kWh	91 MT CO2
26	DOE	Q801	44-36 VERNON BLVD	Queens		Yes	299.64 kW	351,729 kWh	92 MT CO2
27	DOE	Q116	107-25 WREN PLACE	Queens	EJZ		75.40 kW	100,468 kWh	26 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
27	DOE	Q136	201-15 115 AVENUE	Queens	EJZ		137.20 kW	185,201 kWh	48 MT CO2
28	DOE	Q124	129-15 150 AVENUE	Queens	EJZ		33.60 kW	39,441 kWh	10 MT CO2
28	DEP	150-20 134th St	Jamaica WPCP	Queens			39.70 kW	46,612 kWh	12 MT CO2
28	DEP	150-20 Rear 134th St	Jamaica WPCP	Queens			79.30 kW	93,107 kWh	24 MT CO2
28	DOE	Q030	126-10 BEDELL STREET	Queens	EJZ		85.40 kW	100,246 kWh	26 MT CO2
28	DOE	Q875	142-10 LINDEN BLVD	Queens	EJZ		133.90 kW	177,895 kWh	46 MT CO2
28	DOE	Q400	156-10 BAISLEY BLVD	Queens	EJZ	Yes	219.64 kW	257,822 kWh	67 MT CO2
29	QPL	Richmond Hill Community Library	118-14 Hillside Ave	Queens			6.10 kW	7,160 kWh	2 MT CO2
29	QPL	Forest Hills Community Library	108-19 71st Ave	Queens			12.20 kW	14,321 kWh	4 MT CO2
29	DOE	Q303	108-55 69 AVENUE	Queens			16.30 kW	21,519 kWh	6 MT CO2
29	DPR	Lost Battalion Hall Recreation Center	93-29 Queens Blvd	Queens	EJZ		30.50 kW	35,802 kWh	9 MT CO2
29	DOE	Q686	91-30 METROPOLITAN AVENUE	Queens			76.30 kW	89,564 kWh	23 MT CO2
29	DOE	Q099	82-37 KEW GARDENS ROAD	Queens	EJZ		90.90 kW	106,702 kWh	28 MT CO2
29	DOE	Q196	71-25 113 STREET	Queens	EJZ		91.00 kW	118,641 kWh	31 MT CO2
29	DOE	Q220	62-10 108 STREET	Queens		Yes	106.80 kW	125,366 kWh	33 MT CO2
29	DOE	Q175	64-35 102 STREET	Queens		Yes	121.90 kW	149,633 kWh	39 MT CO2
30	DPR	Forest Park DPR Shops	82-99 88th Pl	Queens			0.00 kW	0 kWh	0 MT CO2
30	FDNY	Queens Central Office	83-24 Woodhaven Blvd	Queens			0.00 kW	0 kWh	0 MT CO2
30	DOE	Q087	67-54 80 STREET	Queens			6.10 kW	7,160 kWh	2 MT CO2
30	QPL	Ridgewood Community Library	20-12 Madison St	Queens			14.90 kW	17,490 kWh	5 MT CO2
30	DOE	Q113	87-21 79 AVENUE	Queens			52.00 kW	69,769 kWh	18 MT CO2
30	DOE	Q485	21-27 HIMROD STREET	Queens		Yes	296.14 kW	347,621 kWh	91 MT CO2
31	DSNY	Queens 14 District Garage	51-10 Almeda Ave	Queens	EJZ		0.00 kW	0 kWh	0 MT CO2
31	DOE	Q270	233-15 MERRICK BOULEVARD	Queens	EJZ		3.05 kW	3,580 kWh	1 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
31	NYPD	101st Precinct	16-12 Mott Ave	Queens	EJZ		21.40 kW	25,120 kWh	7 MT CO2
31	DHS	Springfield Family Residence	146-80 Guy R. Brewer Blvd	Queens	EJZ		46.20 kW	63,550 kWh	17 MT CO2
31	DOE	Q042	488 BEACH 66 STREET	Queens	EJZ		79.40 kW	93,203 kWh	24 MT CO2
31	DOE	Q333	365 BEACH 56 STREET	Queens	EJZ		108.20 kW	149,683 kWh	39 MT CO2
31	DOE	Q231	145-00 SPRINGFIELD BLVD	Queens	EJZ	Yes	179.52 kW	210,728 kWh	55 MT CO2
32	DOE	Q273	88-07 102ND STREET	Queens	EJZ		9.15 kW	10,741 kWh	3 MT CO2
32	DOE	Q262	95-16 89TH AVE.	Queens	EJZ		11.90 kW	13,969 kWh	4 MT CO2
32	DOE	Q137	109-15 98TH STREET	Queens	EJZ		98.80 kW	134,700 kWh	35 MT CO2
33	DEP	Main Building	329 Greenpoint Ave	Brooklyn			0.00 kW	0 kWh	0 MT CO2
33	DEP	Main Building Area 1	281 Greenpoint Ave	Brooklyn			0.00 kW	0 kWh	0 MT CO2
33	DEP	Main Building Area 2	281 Greenpoint Ave	Brooklyn			0.00 kW	0 kWh	0 MT CO2
33	DOE	K313	283 ADAMS STREET	Brooklyn			0.00 kW	0 kWh	0 MT CO2
33	DOE	K802	131 LIVINGSTON STREET	Brooklyn			0.00 kW	0 kWh	0 MT CO2
33	NYPD	94th Precinct	100 Meserole Ave	Brooklyn			1.53 kW	1,796 kWh	0.5 MT CO2
33	DOE	K054	195 SANFORD STREET	Brooklyn	EJZ		1.83 kW	2,148 kWh	1 MT CO2
33	DOE	K034	131 NORMAN AVENUE	Brooklyn	EJZ		12.20 kW	14,321 kWh	4 MT CO2
33	NYPD	Tow Pound Operations Building	Brooklyn Navy Yard	Brooklyn			12.70 kW	17,022 kWh	4 MT CO2
33	DOE	K008	37 HICKS STREET	Brooklyn			18.30 kW	21,481 kWh	6 MT CO2
33	DEP	S Control Bg	281 Greenpoint Ave	Brooklyn			70.20 kW	82,404 kWh	21 MT CO2
33	DOE	K307	209 YORK STREET	Brooklyn			91.30 kW	107,172 kWh	28 MT CO2
33	DEP	Cntr Residuals Bg	353 Greenpoint Ave	Brooklyn			97.60 kW	114,567 kWh	30 MT CO2
33	DOE	K806	362 SCHERMERHORN ST.	Brooklyn			144.00 kW	191,272 kWh	50 MT CO2
33	DOE	K126	424 LEONARD STREET	Brooklyn		Yes	208.08 kW	244,253 kWh	64 MT CO2
33	DOE	K650	257 NORTH 6TH ST.	Brooklyn			227.80 kW	299,051 kWh	78 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
33	DOE	K117	300 WILLOUGHBY AVENUE	Brooklyn	EJZ	Yes	252.00 kW	283,135 kWh	74 MT CO2
33	DOE	K497	284 BALTIC STREET	Brooklyn			261.00 kW	349,512 kWh	91 MT CO2
34	DOE	K123	100 IRVING AVENUE	Brooklyn	EJZ		0.00 kW	0 kWh	0 MT CO2
34	FDNY	Greenpoint EMT Station	332 Metropolitan Ave	Brooklyn			3.05 kW	3,580 kWh	1 MT CO2
34	DOE	Q245	378 SENECA AVE.	Queens			6.10 kW	7,160 kWh	2 MT CO2
34	BPL	DeKalb Branch Library	790 Bushwick Ave	Brooklyn	EJZ		6.10 kW	7,162 kWh	2 MT CO2
34	DOE	K132	320 MANHATTAN AVENUE	Brooklyn			15.30 kW	17,960 kWh	5 MT CO2
34	BPL	Leonard Branch Library	82 Devoe St	Brooklyn			15.30 kW	17,964 kWh	5 MT CO2
34	DOE	K017	208 NORTH 5 STREET	Brooklyn			27.50 kW	32,281 kWh	8 MT CO2
34	DOE	Q848	511 SENECA AVENUE	Queens			45.80 kW	53,762 kWh	14 MT CO2
34	DOE	Q849	976 SENECA AVENUE	Queens			97.30 kW	114,215 kWh	30 MT CO2
34	DEP	BWS Storehouse (GS1)	1201 Metropolitan Ave	Brooklyn			135.50 kW	183,187 kWh	48 MT CO2
34	DOE	K049	223 GRAHAM AVENUE	Brooklyn	EJZ	Yes	189.10 kW	220,983 kWh	58 MT CO2
35	DCLA	Brooklyn Academy of Music (BAM Richard B. Fisher Building)	321 Ashland Pl	Brooklyn			0.00 kW	0 kWh	0 MT CO2
35	DCLA	Brooklyn Botanic Garden Administrative Building	1000 Washington Ave	Brooklyn			0.00 kW	0 kWh	0 MT CO2
35	DCLA	Brooklyn Botanic Garden Conservatory	1000 Washington Ave	Brooklyn			0.00 kW	0 kWh	0 MT CO2
35	DOE	K430	29 FORT GREENE PL.	Brooklyn			0.00 kW	0 kWh	0 MT CO2
35	DHS	Atlantic Avenue Men's Shelter (Armory)	1322 Bedford Ave	Brooklyn	EJZ		0.00 kW	0 kWh	0 MT CO2
35	DOE	K813	355 PARK PLACE	Brooklyn			1.22 kW	1,432 kWh	0.4 MT CO2
35	DOE	K805	49 FLATBUSH AVE. EXT.	Brooklyn			5.67 kW	6,656 kWh	2 MT CO2
35	FDNY	Brooklyn Central Office	35 Empire Blvd	Brooklyn			6.10 kW	7,160 kWh	2 MT CO2
35	BPL	Eastern Parkway Branch Library and Learning Center	1044 Eastern Pkwy	Brooklyn	EJZ		15.30 kW	17,960 kWh	5 MT CO2
35	DHS	Auburn Family Residence	39 Auburn Place	Brooklyn	EJZ		36.60 kW	42,963 kWh	11 MT CO2



# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
35	DOE	K020	225 ADELPHI STREET	Brooklyn			54.90 kW	64,444 kWh	17 MT CO2
35	DEP	Hazmat Citywide Field Operations	82 Emerson Pl	Brooklyn	EJZ		58.50 kW	80,596 kWh	21 MT CO2
35	DOE	K287	50 NAVY STREET	Brooklyn	EJZ		136.60 kW	160,347 kWh	42 MT CO2
35	DOE	K600	901 CLASSON AVE	Brooklyn	EJZ		158.00 kW	172,029 kWh	45 MT CO2
35	BPL	Central Library and Learning Center	10 Grand Army Plz	Brooklyn			170.80 kW	200,538 kWh	52 MT CO2
36	DPR	St. Johns Recreation Center	1251 Prospect Pl	Brooklyn	EJZ		28.40 kW	33,337 kWh	9 MT CO2
36	DOE	K853	234 HERKIMER STREET	Brooklyn	EJZ		81.40 kW	95,551 kWh	25 MT CO2
36	DOE	K210	188 ROCHESTER AVENUE	Brooklyn	EJZ	Yes	121.00 kW	148,336 kWh	39 MT CO2
36	DOE	K003	50 JEFFERSON AVE.	Brooklyn	EJZ	Yes	135.00 kW	170,367 kWh	44 MT CO2
36	DOE	K023	545 WILLOUGHBY AVENUE	Brooklyn	EJZ		172.60 kW	236,307 kWh	62 MT CO2
37	NYPD	Facilities Management Division	127 Pennsylvania Ave	Brooklyn	EJZ		0.00 kW	0 kWh	0 MT CO2
37	BPL	Arlington Branch Library	203 Arlington Ave	Brooklyn	EJZ		1.22 kW	1,432 kWh	0.4 MT CO2
37	DOE	K086	220 IRVING AVENUE	Brooklyn	EJZ		2.84 kW	3,334 kWh	1 MT CO2
37	DOE	K814	265 WARWICK STREET	Brooklyn	EJZ		6.10 kW	7,160 kWh	2 MT CO2
37	DOE	K073	251 MAC DOUGAL STREET	Brooklyn	EJZ		25.40 kW	34,822 kWh	9 MT CO2
37	DOE	K798	696 JAMAICA AVENUE	Brooklyn	EJZ		42.40 kW	49,771 kWh	13 MT CO2
37	DOE	K151	763 KNICKERBOCKER AVENUE	Brooklyn	EJZ		53.10 kW	62,331 kWh	16 MT CO2
37	DOE	K345	111 BERRIMAN STREET	Brooklyn	EJZ		131.20 kW	154,008 kWh	40 MT CO2
37	DOE	K377	200 WOODBINE STREET	Brooklyn	EJZ		216.10 kW	289,921 kWh	75 MT CO2
38	DOE	K971	6214 4TH AVE.	Brooklyn	EJZ		3.05 kW	3,580 kWh	1 MT CO2
38	DOE	K486	1171 65TH STREET	Brooklyn	EJZ		25.70 kW	33,752 kWh	9 MT CO2
38	NYPD	68th Precinct	333 65th St	Brooklyn			27.50 kW	32,281 kWh	8 MT CO2
38	DOE	K564	153 35TH STREET	Brooklyn	EJZ		56.70 kW	66,557 kWh	17 MT CO2
38	DOE	K371	355 37 STREET	Brooklyn	EJZ		70.80 kW	83,108 kWh	22 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
38	DOE	K220	4812 9TH AVE.	Brooklyn	EJZ		106.90 kW	125,612 kWh	33 MT CO2
39	BPL	Park Slope Branch Library	431 6th Ave	Brooklyn			0.92 kW	1,074 kWh	0.3 MT CO2
39	DPR	Prospect Park Maintenance Facility	Prospect Park West at 7th st	Brooklyn			3.97 kW	4,660 kWh	1 MT CO2
39	DOE	K039	417 6TH AVENUE	Brooklyn			24.40 kW	28,642 kWh	7 MT CO2
39	DOE	K154	1625 11th Ave	Brooklyn			33.60 kW	42,799 kWh	11 MT CO2
39	DOE	K029	425 HENRY STREET	Brooklyn			41.50 kW	48,714 kWh	13 MT CO2
39	DOE	K077	62 PARK PLACE	Brooklyn			52.00 kW	69,475 kWh	18 MT CO2
39	DOE	K142	610 HENRY STREET	Brooklyn		Yes	155.20 kW	194,926 kWh	51 MT CO2
39	DSNY	Brooklyn South 6 District Garage	129 2nd Ave	Brooklyn			167.70 kW	215,108 kWh	56 MT CO2
40	BPL	Flatbush Branch Library and Learning Center	22 Linden Blvd	Brooklyn	EJZ		12.20 kW	14,324 kWh	4 MT CO2
40	DOE	K245	249 E. 17TH STREET	Brooklyn	EJZ		25.40 kW	34,867 kWh	9 MT CO2
40	DOE	K217	1100 NEWKIRK AVE.	Brooklyn			75.00 kW	88,038 kWh	23 MT CO2
40	HHC	Kings County Hospital Buildings A, B, C	451 Clarkson Ave	Brooklyn	EJZ		121.10 kW	142,152 kWh	37 MT CO2
40	DOE	K092	601 PARKSIDE AVENUE	Brooklyn	EJZ		130.00 kW	180,415 kWh	47 MT CO2
40	DOE	K249	18 MARLBOROUGH ROAD	Brooklyn	EJZ		189.00 kW	221,856 kWh	58 MT CO2
40	DOE	K470	600 KINGSTON AVE.	Brooklyn	EJZ	Yes	248.54 kW	291,746 kWh	76 MT CO2
41	DHS	Dean Street Family Residence	2155 Dean Street	Brooklyn	EJZ		2.14 kW	2,512 kWh	1 MT CO2
41	HRA	Brownsville Multi Service Center	444 Thomas Boyland St	Brooklyn	EJZ		18.30 kW	21,481 kWh	6 MT CO2
41	DOE	K135	684 LINDEN BLVD	Brooklyn	EJZ		54.90 kW	64,444 kWh	17 MT CO2
41	DOE	K091	532 ALBANY AVENUE	Brooklyn	EJZ		56.40 kW	66,205 kWh	17 MT CO2
41	DHS	East New York Avenue SRO Residence	1385 East New York Ave	Brooklyn	EJZ		61.00 kW	71,604 kWh	19 MT CO2
41	DOE	K232	905 WINTHROP STREET	Brooklyn	EJZ	Yes	112.90 kW	132,527 kWh	35 MT CO2
41	DOE	K005	820 HANCOCK STREET	Brooklyn	EJZ	Yes	184.30 kW	225,851 kWh	59 MT CO2
41	DOE	K309	794 MONROE STREET	Brooklyn	EJZ	Yes	219.90 kW	258,127 kWh	67 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
41	DOE	K391	790 EAST NEW YORK AVENUE	Brooklyn	EJZ	Yes	290.10 kW	340,531 kWh	89 MT CO2
42	DPR	Brownsville Recreation Center	1555 Linden Blvd	Brooklyn	EJZ		21.40 kW	25,120 kWh	7 MT CO2
42	DOE	K190	590 SHEFFIELD AVENUE	Brooklyn	EJZ		24.40 kW	28,642 kWh	7 MT CO2
42	DOE	K159	2781 PITKIN AVENUE	Brooklyn	EJZ		30.50 kW	35,802 kWh	9 MT CO2
42	DOE	K165	76 LOTT AVENUE	Brooklyn	EJZ		36.60 kW	42,963 kWh	11 MT CO2
42	DOE	K149	700 SUTTER AVENUE	Brooklyn	EJZ		42.70 kW	50,123 kWh	13 MT CO2
42	DEP	Brooklyn Repair - Remsen Yard	855 Remsen Ave	Brooklyn			164.80 kW	221,291 kWh	58 MT CO2
42	DOE	K213	580 HEGEMAN AVE.	Brooklyn	EJZ		173.90 kW	204,131 kWh	53 MT CO2
42	DOE	K275	985 ROCKAWAY AVENUE	Brooklyn	EJZ	Yes	271.50 kW	318,698 kWh	83 MT CO2
43	DOE	K807	109 BAY 14 STREET	Brooklyn	EJZ		59.80 kW	77,347 kWh	20 MT CO2
43	DOE	K204	8101 15TH AVE.	Brooklyn			75.10 kW	96,596 kWh	25 MT CO2
43	DOE	K259	7305 FT HAMILTON PKWY	Brooklyn			115.40 kW	150,258 kWh	39 MT CO2
44	DOE	K686	50 AVENUE P	Brooklyn			0.00 kW	0 kWh	0 MT CO2
44	BPL	Kensington Branch Library	4209 18th Ave	Brooklyn	EJZ		3.05 kW	3,581 kWh	1 MT CO2
44	DOE	K134	4001 18 AVE.	Brooklyn	EJZ		11.70 kW	15,878 kWh	4 MT CO2
44	DOE	K192	4715 18 AVENUE	Brooklyn			29.60 kW	34,746 kWh	9 MT CO2
44	DOE	K048	6015 18TH AVE.	Brooklyn	EJZ		36.60 kW	42,963 kWh	11 MT CO2
44	DOE	K160	5105 FT. HAMILTON PKWY	Brooklyn	EJZ		57.20 kW	74,677 kWh	19 MT CO2
45	DOE	K405	2839 BEDFORD AVENUE	Brooklyn	EJZ		0.00 kW	0 kWh	0 MT CO2
45	DOE	K729	3920 FLATLANDS AVENUE	Brooklyn			27.10 kW	31,811 kWh	8 MT CO2
45	DOE	K181	1023 NEW YORK AVENUE	Brooklyn	EJZ		37.70 kW	51,075 kWh	13 MT CO2
45	DOE	K198	4105 FARRAGUT ROAD	Brooklyn	EJZ		110.20 kW	148,870 kWh	39 MT CO2
45	DOE	K244	5404 TILDEN AVENUE	Brooklyn	EJZ		122.50 kW	169,288 kWh	44 MT CO2
46	NYPD	Highway District Unit 2	2900 Flatbush Ave	Brooklyn			0.00 kW	0 kWh	0 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
46	DOE	K366	965 EAST 107TH STREET	Brooklyn	EJZ		8.54 kW	10,025 kWh	3 MT CO2
46	DOE	K207	4011 FILLMORE AVE.	Brooklyn			75.60 kW	88,742 kWh	23 MT CO2
46	DOE	K222	3301 QUENTIN ROAD	Brooklyn			85.40 kW	100,246 kWh	26 MT CO2
46	DOE	K203	5101 AVENUE M	Brooklyn	EJZ		93.90 kW	110,224 kWh	29 MT CO2
46	DOE	K194	3117 Avenue W	Brooklyn			134.90 kW	187,030 kWh	49 MT CO2
46	DOE	K272	101-24 SEAVIEW AVENUE	Brooklyn	EJZ		180.00 kW	211,291 kWh	55 MT CO2
46	DOE	K276	1070 EAST 83 STREET	Brooklyn	EJZ		239.70 kW	281,369 kWh	73 MT CO2
46	DOE	K211	1001 EAST 100 STREET	Brooklyn	EJZ	Yes	251.50 kW	284,715 kWh	74 MT CO2
47	DCLA	Aquatic Animal Health Center (AAHC)	600 Surf Ave	Brooklyn	EJZ		0.00 kW	0 kWh	0 MT CO2
47	DCLA	Ocean Wonders	514 Surf Ave	Brooklyn	EJZ		0.00 kW	0 kWh	0 MT CO2
47	DPR	Abe Stark Ice Rink	1902 West 19th St	Brooklyn	EJZ		0.00 kW	0 kWh	0 MT CO2
47	HHC	New Ida G. Israel Community Health Center	2925 West 19th St	Brooklyn	EJZ		6.10 kW	7,160 kWh	2 MT CO2
47	DOE	K728	2865 W. 19TH STREET	Brooklyn	EJZ		8.80 kW	10,330 kWh	3 MT CO2
47	DOE	K186	7601 19 AVENUE	Brooklyn	EJZ		42.70 kW	50,123 kWh	13 MT CO2
47	DOE	K101	2360 BENSON AVE.	Brooklyn	EJZ		72.20 kW	96,073 kWh	25 MT CO2
47	DOE	K097	1855 STILLWELL AVE.	Brooklyn	EJZ		89.70 kW	105,293 kWh	27 MT CO2
47	DOE	K128	2075 84 STREET	Brooklyn	EJZ		96.10 kW	112,806 kWh	29 MT CO2
47	DOE	K090	2840 WEST 12 STREET	Brooklyn	EJZ		116.40 kW	160,608 kWh	42 MT CO2
47	DOE	K410	2800 OCEAN PARKWAY	Brooklyn		Yes	353.43 kW	414,870 kWh	108 MT CO2
48	DOE	K254	1801 AVENUE Y	Brooklyn			42.70 kW	50,123 kWh	13 MT CO2
48	CUNY	Robert J. Kibbee Library and Media Center	2000 Oriental Blvd	Brooklyn			76.30 kW	100,246 kWh	26 MT CO2
48	BPL	Brighton Beach Branch Library	16 Brighton 1st Rd	Brooklyn			79.30 kW	93,107 kWh	24 MT CO2
48	DOE	K206	2200 GRAVESEND NECK ROAD	Brooklyn	EJZ		100.70 kW	118,206 kWh	31 MT CO2
48	CUNY	Leon M. Goldstein Performing Arts Center	2001 Oriental Blvd	Brooklyn			100.70 kW	131,838 kWh	34 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
48	DOE	K197	1599 EAST 22 STREET	Brooklyn		Yes	112.20 kW	127,144 kWh	33 MT CO2
48	DOE	K225	1075 OCEAN VIEW AVENUE	Brooklyn	EJZ		129.70 kW	175,087 kWh	46 MT CO2
48	DOE	K052	2675 EAST 29TH ST.	Brooklyn		Yes	153.60 kW	188,215 kWh	49 MT CO2
48	CUNY	Temporary Building #8	2101 Oriental Blvd	Brooklyn			195.20 kW	248,170 kWh	65 MT CO2
49	DCLA	Bldg A/Staten Island Museum	1000 Richmond Ter	Staten Island			0.00 kW	0 kWh	0 MT CO2
49	DCLA	Staten Island Museum	75 Stuyvesant Pl	Staten Island	EJZ		0.00 kW	0 kWh	0 MT CO2
49	DOE	R065	98 GRANT STREET	Staten Island	EJZ		0.00 kW	0 kWh	0 MT CO2
49	DPR	Clove Lake Garage and Shops	21 Slosson Ave	Staten Island			3.05 kW	3,580 kWh	1 MT CO2
49	NYPD	121st Precinct	970 Richmond Ave	Staten Island			6.10 kW	7,160 kWh	2 MT CO2
49	NYPL	Mariner's Harbor Library	206 South Ave	Staten Island	EJZ		21.40 kW	25,120 kWh	7 MT CO2
49	DOE	R040	91 HENDERSON AVENUE	Staten Island	EJZ		70.20 kW	82,404 kWh	21 MT CO2
49	DOE	R450	105 HAMILTON AVE.	Staten Island	EJZ		85.40 kW	100,246 kWh	26 MT CO2
49	DPR	Lyons Pool and Recreation Center	317 Bay St	Staten Island	EJZ		88.50 kW	103,885 kWh	27 MT CO2
49	DOE	R861	280 REGIS DRIVE	Staten Island			91.50 kW	107,406 kWh	28 MT CO2
49	DOE	R044	80 MAPLE PARKWAY	Staten Island	EJZ		104.00 kW	142,501 kWh	37 MT CO2
50	DPR	High Rock Park Buildings	200 Nevada Ave	Staten Island			0.00 kW	0 kWh	0 MT CO2
50	DPR	Greenbelt Native Plant Center	3808 Victory Blvd	Staten Island			8.24 kW	9,672 kWh	3 MT CO2
50	DPR	Midland Beach Maintenance Facility	950 Father Capodanno Blvd	Staten Island			9.15 kW	10,741 kWh	3 MT CO2
50	DOE	R046	41 REID AVENUE	Staten Island	EJZ		62.00 kW	72,778 kWh	19 MT CO2
50	DOE	R440	485 CLAWSON ST.	Staten Island			76.50 kW	89,799 kWh	23 MT CO2
50	DOE	R029	1581 VICTORY BLVD	Staten Island			114.40 kW	155,717 kWh	41 MT CO2
50	DOE	R880	715 Ocean Terrace	Staten Island	EJZ	Yes	117.81 kW	138,290 kWh	36 MT CO2
50	DOE	R054	1060 WILLOWBROOK ROAD	Staten Island		Yes	145.30 kW	176,098 kWh	46 MT CO2
50	DOE	R051	20 HOUSTON ST.	Staten Island		Yes	157.08 kW	184,387 kWh	48 MT CO2

# Solar-Ready Buildings

City Council District	Agency	Site	Address	Borough	Environmental Justice Zone*	Solar-Readiness Assessment**	Estimated Capacity***	Estimated Annual Production***	Estimated Annual Emissions Reduction
50	DOE	R460	1200 MANOR RD	Staten Island	EJZ		790.00 kW	927,334 kWh	241 MT CO2
51	DOE	R848	25 AUGUSTA AVENUE	Staten Island			97.60 kW	114,567 kWh	30 MT CO2
51	DOE	R072	33 FERNDALE AVENUE	Staten Island		Yes	165.16 kW	193,871 kWh	50 MT CO2
51	DOE	R043	100 ESSEX DRIVE	Staten Island			205.90 kW	241,694 kWh	63 MT CO2
51	DOE	R036	255 Ionia Avenue	Staten Island			271.10 kW	318,228 kWh	83 MT CO2
51	DSNY	Staten Island 2 District Garage	2500 Richmond Ave	Staten Island		Yes	464.90 kW	530,806 kWh	138 MT CO2

\*Environmental Justice Zone: as defined by Local Law 64 of 2017, a low-income community or minority community, as determined by U.S. Census Bureau, 2011 – 2015 American Community Survey.

\*\*Solar-Readiness Assessments: onsite technical inspection of roof, structural systems, and electrical service, preliminary solar PV system design fitting building’s technical constraints and code compliance.

\*\*\*Estimated Capacity & Annual Production: solar installed potential in kilowatts (kW) DC and production in kilowatt-hours (kWh) AC. Professional-grade modeling tool used to produce a preliminary solar system design and system efficiency.

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
1	Not Solar-Ready	NYPL	Battery Park City Branch	175 North End Ave	Manhattan		10,000 GSF	Unknown	Unknown		
1	Not Solar-Ready	FDNY	EMS 4	Pier 36	Manhattan	EJZ	12,000 GSF	Unknown	15 to 19 years		
1	Solar-Ready	NYPL	Chatham Square Branch Library	33 East Broadway	Manhattan	EJZ	12,243 GSF	Fair	< 2 years		
1	Not Solar-Ready	FDNY	Engine Co. 33 & Ladder Co. 9	42 Great Jones St	Manhattan		12,649 GSF	Unknown	10 to 14 years		
1	Not Solar-Ready	DPR	Alfred E. Smith Recreation Center	86 Catherine St	Manhattan	EJZ	13,000 GSF	Fair	> 20 years		
1	Not Solar-Ready	HHC	Judson Health Center	34 Spring St	Manhattan	EJZ	18,000 GSF	Between Good and Fair	15 to 19 years		
1	Not Solar-Ready	FDNY	Engine Co. 7 at Ladder Co. 1, Batt. 1	100 Duane St	Manhattan		19,381 GSF	Unknown	10 to 14 years		
1	Not Solar-Ready	NYPL	Seward Park Branch Library	192 East Broadway	Manhattan		19,681 GSF	Fair	> 20 years		
1	Not Solar-Ready	DSNY	Manhattan 3B Garage	80 Henry St	Manhattan	EJZ	21,110 GSF	Poor	> 20 years		
1	Not Solar-Ready	NYPD	1st Precinct	16 Ericsson Pl	Manhattan		23,300 GSF	Unknown	15 to 19 years		
1	Solar-Ready	CUNY	BMCC Auditorium	199 Chambers St	Manhattan		23,337 GSF	Fair	2 to 4 years		
1	Not Solar-Ready	FDNY	Ladder Co. 20 and Medical and BFI Division	251 Lafayette St	Manhattan	EJZ	28,866 GSF	Unknown	10 to 14 years		
1	Solar-Ready	NYPD	5th Precinct	19 Elizabeth St	Manhattan	EJZ	32,989 GSF	Good	5 to 9 years		
1	Not Solar-Ready	DSNY	Print Shop and Storage	134 Madison St	Manhattan	EJZ	33,831 GSF	Poor	> 20 years		
1	Not Solar-Ready	DEP	Manhattan Repair Shop	30 Pike St	Manhattan	EJZ	41,428 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DCAS	115 Chrystie Street Office Building	115 Chrystie St	Manhattan	EJZ	55,000 GSF	Fair	> 20 years		
1	Not Solar-Ready	NYPD	7th Precinct, Engine Co. 15 and Ladder Co. 18, Batt. 4	19-25 Pitt St	Manhattan	EJZ	58,685 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DCAS	Excelsior Building	137 Centre St	Manhattan		59,000 GSF	Fair	> 20 years		
1	Not Solar-Ready	DOE	M110	285 DELANCEY STREET	Manhattan		62,480 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DOE	M042	71 HESTER STREET	Manhattan	EJZ	74,080 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
1	Not Solar-Ready	DOE	M234	292 GREENWICH STREET	Manhattan		84,903 GSF	Fair	> 20 years		
1	Not Solar-Ready	DOE	M001	8 HENRY STREET	Manhattan	EJZ	87,680 GSF	Between Good and Fair	15 to 19 years		
1	Not Solar-Ready	DOE	M510	198 FORSYTH STREET	Manhattan	EJZ	91,280 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DOE	M130	143 BAXTER STREET	Manhattan	EJZ	95,145 GSF	Fair	> 20 years		
1	Not Solar-Ready	DSNY	Administrative Offices	44 Beaver St	Manhattan		97,596 GSF	Unknown	Unknown		
1	Not Solar-Ready	DCAS	City Planning Building	22 Reade St	Manhattan		99,000 GSF	Poor	Unknown		
1	Not Solar-Ready	DOE	M140	123 RIDGE STREET	Manhattan	EJZ	99,481 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DOE	M184	327 CHERRY STREET	Manhattan	EJZ	99,700 GSF	Fair	> 20 years		
1	Not Solar-Ready	NYPD	Manhattan South Narcotics Unit	36 South St	Manhattan	EJZ	100,000 GSF	Between Good and Fair	10 to 14 years		
1	Not Solar-Ready	DOE	M134	293 EAST BROADWAY	Manhattan	EJZ	104,460 GSF	Between Good and Fair	10 to 14 years		
1	Not Solar-Ready	DOE	M126	80 CATHERINE STREET	Manhattan	EJZ	105,725 GSF	Fair	> 20 years		
1	Not Solar-Ready	DOE	M002	122 HENRY STREET	Manhattan	EJZ	109,300 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DOE	M124	40 DIVISION STREET	Manhattan	EJZ	111,725 GSF	Fair	> 20 years		
1	Not Solar-Ready	DOE	M089	201 WARREN STREET	Manhattan		114,125 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DOE	M833	100 TRINITY PLACE	Manhattan		115,125 GSF	Between Fair and Poor	15 to 19 years		
1	Solar-Ready	DHS	Catherine Life Family Shelter	78 Catherine St	Manhattan	EJZ	115,659 GSF	Good	5 to 9 years		
1	Not Solar-Ready	DOE	M142	100 ATTORNEY STREET	Manhattan	EJZ	119,519 GSF	Between Fair and Poor	> 20 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
1	Not Solar-Ready	DSNY	Manhattan 3 District Garage	280-284 South St	Manhattan	EJZ	120,000 GSF	Between Good and Fair	> 20 years	Yes	
1	Not Solar-Ready	DCAS	Tweed Courthouse	52 Chambers St	Manhattan		170,131 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DOE	M056	220 HENRY STREET	Manhattan	EJZ	183,775 GSF	Under construction	Under construction		
1	Not Solar-Ready	DOE	M131	100 HESTER STREET	Manhattan	EJZ	207,109 GSF	Fair	10 to 14 years		
1	Not Solar-Ready	DCAS	Manhattan Surrogate's Court	31 Chambers St	Manhattan		212,500 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DOC	Manhattan House Detention, North Tower	84 Baxter St	Manhattan	EJZ	236,142 GSF	Between Fair and Poor	> 20 years		
1	Not Solar-Ready	DCAS	Sun Building	280 Broadway	Manhattan		242,062 GSF	Good	15 to 19 years		
1	Solar-Ready	DOE	M445	350 GRAND ST.	Manhattan	EJZ	313,549 GSF	Good	< 2 years	Yes	
1	Not Solar-Ready	DCAS	Manhattan Supreme Court	60 Centre St	Manhattan	EJZ	322,300 GSF	Poor	Unknown		
1	Not Solar-Ready	HHC	Gouverneur Health Care Services	227 Madison St	Manhattan	EJZ	335,800 GSF	Between Good and Fair	15 to 19 years		
1	Solar-Ready	CUNY	BMCC Fiterman Hall	245 Greenwich St	Manhattan		357,774 GSF	Good	2 to 4 years		
1	Solar-Ready	DCAS	Court Square Building	2 Lafayette St	Manhattan		363,309 GSF	Good	2 to 4 years		
1	Solar-Ready	DOE	M520	411 PEARL ST	Manhattan	EJZ	366,200 GSF	Between Good and Fair	5 to 9 years		
1	Not Solar-Ready	DCAS	Health Building	125 Worth St	Manhattan		406,109 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DCAS	Manhattan Civil Court	111 Centre St	Manhattan		462,260 GSF	Poor	Unknown		
1	Not Solar-Ready	DCAS	Louis J. Lefkowitz Building	80 Centre St	Manhattan	EJZ	472,500 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DCAS	Manhattan Family Court	60 Lafayette St	Manhattan		481,000 GSF	Good	10 to 14 years		
1	Solar-Ready	DOE	M477	345 CHAMBERS ST.	Manhattan		483,250 GSF	Between Good and Fair	5 to 9 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
1	Not Solar-Ready	DOC	Manhattan House Detention, South Tower	125 White St	Manhattan	EJZ	514,000 GSF	Between Fair and Poor	> 20 years		
1	Not Solar-Ready	DCAS	Manhattan Criminal Court	100 Centre St	Manhattan	EJZ	795,700 GSF	Fair	> 20 years		
1	Not Solar-Ready	NYPD	NYPD Police Headquarters	1 Police Plz	Manhattan	EJZ	1,000,518 GSF	Fair	15 to 19 years		
1	Not Solar-Ready	DCAS	Manhattan Municipal Building	1 Centre St	Manhattan	EJZ	1,070,800 GSF	Good	15 to 19 years		
2	Not Solar-Ready	HHC	Roberto Clemente Clinic	538 East 13th St	Manhattan	EJZ	11,000 GSF	Between Good and Fair	10 to 14 years		
2	Not Solar-Ready	DPR	Hamilton Fish Recreation Center	128 Pitt St	Manhattan	EJZ	12,900 GSF	Fair	> 20 years		
2	Not Solar-Ready	NYPL	Tompkins Square Branch Library	331 East 10th St	Manhattan		14,703 GSF	Fair	15 to 19 years		
2	Not Solar-Ready	NYPL	Epiphany Branch Library	228 East 23rd St	Manhattan		16,218 GSF	Fair	15 to 19 years		
2	Solar-Ready	DHS	Kenton Hotel Shelter	333 Bowery	Manhattan	EJZ	23,492 GSF	Good	5 to 9 years		
2	Not Solar-Ready	DHS	Shelter	282 East 3rd St	Manhattan		23,530 GSF	Unknown	Unknown		
2	Not Solar-Ready	NYPD	Property Clerk and Youth Aid	34 East 12th St	Manhattan		41,490 GSF	Between Fair and Poor	Unknown		
2	Not Solar-Ready	NYPD	9th Precinct	321 East 5th St	Manhattan		42,235 GSF	Between Fair and Poor	5 to 9 years		
2	Not Solar-Ready	DOE	M751	113 E 4 TH ST 10003	Manhattan		49,260 GSF	Fair	15 to 19 years		
2	Solar-Ready	DHS	George Daly House Residence	269 East 4th St	Manhattan	EJZ	50,478 GSF	Good	< 2 years		
2	Not Solar-Ready	DCAS	Manhattan Appellate Court	27 Madison Ave	Manhattan	EJZ	54,300 GSF	Fair	15 to 19 years		
2	Solar-Ready	DHS	Manhattan Bowery Shelter	8 East 3rd St	Manhattan	EJZ	55,000 GSF	Good	5 to 9 years		
2	Not Solar-Ready	DOE	M661	240 2ND AVE	Manhattan		55,260 GSF	Fair	10 to 14 years		
2	Not Solar-Ready	DCLA	The Public Theater	425 Lafayette St	Manhattan		61,420 GSF	Good	Unknown		
2	Not Solar-Ready	DHS	Sirovich Senior SRO	331-37 East 12 Street	Manhattan		63,335 GSF	Unknown	Unknown		
2	Not Solar-Ready	DOE	M034	730 EAST 12 STREET	Manhattan	EJZ	66,080 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
2	Solar-Ready	DOE	M844	400 1ST AVENUE	Manhattan		68,480 GSF	Good	5 to 9 years		
2	Solar-Ready	DOE	M015	333 EAST 4 STREET	Manhattan	EJZ	72,080 GSF	Between Good and Fair	5 to 9 years		
2	Not Solar-Ready	DOE	M116	210 EAST 33 STREET	Manhattan	EJZ	74,480 GSF	Fair	10 to 14 years		
2	Not Solar-Ready	DOE	M660	127 E. 22 ST.	Manhattan		81,560 GSF	Fair	15 to 19 years		
2	Not Solar-Ready	DOE	M019	185 1ST AVENUE	Manhattan		84,125 GSF	Between Fair and Poor	> 20 years		
2	Not Solar-Ready	DOE	M097	525 EAST HOUSTON STREET	Manhattan	EJZ	85,300 GSF	Fair	15 to 19 years		
2	Not Solar-Ready	DOE	M061	610 EAST 12 STREET	Manhattan	EJZ	90,080 GSF	Fair	15 to 19 years		
2	Not Solar-Ready	DOE	M063	121 EAST 3 STREET	Manhattan		102,080 GSF	Under construction	Under construction		
2	Not Solar-Ready	DOE	M040	319 EAST 19 STREET	Manhattan		114,125 GSF	Between Good and Fair	10 to 14 years		
2	Not Solar-Ready	DOE	M047	223 EAST 23 STREET	Manhattan		141,660 GSF	Fair	> 20 years		
2	Solar-Ready	DOE	M060	420 EAST 12 STREET	Manhattan		144,175 GSF	Good	< 2 years		
2	Not Solar-Ready	DOE	M104	330 EAST 21 STREET	Manhattan		146,575 GSF	Fair	> 20 years		
2	Not Solar-Ready	DOE	M475	345 E. 15 ST.	Manhattan		218,562 GSF	Between Fair and Poor	> 20 years		
2	Not Solar-Ready	NYPD	13th Precinct	230 East 21st St	Manhattan		313,625 GSF	Good	10 to 14 years		
2	Not Solar-Ready	DOE	M620	111 E. 33 ST.	Manhattan	EJZ	314,952 GSF	Between Fair and Poor	> 20 years		
2	Not Solar-Ready	DOHMH	Public Health Laboratory	455 1st Ave	Manhattan	EJZ	324,505 GSF	Poor	15 to 19 years		
2	Not Solar-Ready	DOE	M460	40 IRVING PLACE	Manhattan		450,200 GSF	Under construction	Under construction		
3	Not Solar-Ready	FDNY	Engine Co. 1 and Ladder Co. 24	142 West 31st St	Manhattan		11,326 GSF	Unknown	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
3	Not Solar-Ready	NYPL	Columbus Branch Library	742 10th Ave	Manhattan		11,554 GSF	Poor	15 to 19 years		
3	Solar-Ready	NYPL	Muhlenberg Branch Library	209 West 23rd St	Manhattan	EJZ	12,953 GSF	Fair	< 2 years		
3	Not Solar-Ready	FDNY	FDNY Museum	278 Spring St	Manhattan		14,901 GSF	Fair	15 to 19 years		
3	Not Solar-Ready	NYPL	Hudson Park Branch Library	66 Leroy St	Manhattan		17,565 GSF	Unknown	15 to 19 years		
3	Not Solar-Ready	FDNY	Engine Co. 3 at Ladder Co. 12, Batt. 7	146 West 19th St	Manhattan		17,586 GSF	Unknown	10 to 14 years		
3	Not Solar-Ready	NYPD	10th Precinct	230 West 20th St	Manhattan		20,110 GSF	Unknown	> 20 years		
3	Not Solar-Ready	NYPL	Jefferson Market Branch Library	425 6th Ave	Manhattan		20,735 GSF	Unknown	Unknown		
3	Solar-Ready	DPR	High Line Maintenance and Operations Building	820 Washington St	Manhattan		24,641 GSF	Fair	2 to 4 years		
3	Solar-Ready	DPR	Tony Dapolito Recreation Center	3 Clarkson St	Manhattan		27,440 GSF	Between Good and Fair	5 to 9 years		Cool Roof
3	Not Solar-Ready	DOHMH	Chelsea Health Center	303 9th Ave	Manhattan	EJZ	27,985 GSF	Unknown	10 to 14 years		
3	Not Solar-Ready	NYPD	18th Precinct (Midtown North)	306 West 54th St	Manhattan		30,000 GSF	Poor	10 to 14 years		
3	Not Solar-Ready	NYPD	6th Precinct	233 West 10th St	Manhattan		30,489 GSF	Good	10 to 14 years		
3	Not Solar-Ready	NYPD	Parking Enforcement Division	134 West 30th St	Manhattan		36,702 GSF	Between Good and Fair	10 to 14 years		
3	Not Solar-Ready	DCAS	Midtown Community Court	314 West 54th St	Manhattan		39,150 GSF	Between Good and Fair	10 to 14 years		
3	Not Solar-Ready	NYPD	14th Precinct (Midtown South)	357 West 35th St	Manhattan		40,107 GSF	Between Fair and Poor	15 to 19 years		
3	Not Solar-Ready	DOE	M451	250 WEST 18 ST.	Manhattan	EJZ	48,953 GSF	Between Fair and Poor	> 20 years		
3	Solar-Ready	DPR	Chelsea Recreation Center	430 West 25th St	Manhattan		54,000 GSF	Between Good and Fair	5 to 9 years		Green Roof

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
3	Not Solar-Ready	DSNY	Manhattan 6 Vehicle Storage and Fueling	657 West 30th St	Manhattan		60,000 GSF	Fair	> 20 years		
3	Solar-Ready	DOE	M035	317 WEST 52 STREET	Manhattan		64,480 GSF	Good	< 2 years		
3	Not Solar-Ready	DOE	M033	281 9TH AVENUE	Manhattan	EJZ	83,100 GSF	Between Good and Fair	10 to 14 years		
3	Not Solar-Ready	DOE	M041	116 WEST 11 STREET	Manhattan		97,300 GSF	Fair	15 to 19 years		
3	Not Solar-Ready	DOE	M111	440 WEST 53 STREET	Manhattan	EJZ	108,080 GSF	Between Fair and Poor	> 20 years		
3	Not Solar-Ready	DOE	M051	520 W.44 STREET	Manhattan		108,597 GSF	Poor	Unknown		
3	Solar-Ready	DOE	M011	320 WEST 21 STREET	Manhattan		115,300 GSF	Fair	5 to 9 years		
3	Not Solar-Ready	DOE	M615	131 AVENUE OF AMERICAS	Manhattan		119,645 GSF	Fair	10 to 14 years		
3	Not Solar-Ready	DOE	M003	490 HUDSON STREET	Manhattan		121,280 GSF	Fair	> 20 years		
3	Not Solar-Ready	DOE	M017	328 WEST 48 STREET	Manhattan		121,300 GSF	Fair	10 to 14 years		
3	Not Solar-Ready	DOE	M641	16 CLARKSON ST.	Manhattan		133,325 GSF	Under construction	Under construction	Yes	
3	Not Solar-Ready	DOE	M933	425 WEST 33RD STREET	Manhattan		164,790 GSF	Fair	> 20 years		
3	Not Solar-Ready	DSNY	Manhattan Borough Repair Shop	640 West 26th St	Manhattan		205,000 GSF	Poor	> 20 years		
3	Not Solar-Ready	DOE	M625	439 W. 49 ST	Manhattan		272,912 GSF	Under construction	Under construction		
3	Solar-Ready	DOE	M600	225 W. 24 STREET	Manhattan		363,130 GSF	Fair	5 to 9 years		
3	Solar-Ready	DSNY	Manhattan Community Districts 1, 2 and 5	353 Spring St	Manhattan		388,255 GSF	Good	2 to 4 years		
3	Not Solar-Ready	NYPD	Pier 76 Tow Pound	1 Pier 76	Manhattan		393,040 GSF	Poor	> 20 years		
3	Not Solar-Ready	DOE	M535	525 W. 50 ST	Manhattan		517,274 GSF	Fair	15 to 19 years		
4	Not Solar-Ready	FDNY	Engine Co. 39, Ladder Co. 16	157 East 67th St	Manhattan		12,960 GSF	Unknown	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
4	Not Solar-Ready	NYPL	Yorkville Branch Library	222 East 79th St	Manhattan		13,112 GSF	Fair	> 20 years		
4	Not Solar-Ready	DCLA	Metropolitan Museum of Art Offices	6 East 82nd Street	Manhattan		13,457 GSF	Between Fair and Poor	> 20 years		
4	Solar-Ready	NYPL	96th Street Branch Library	112 East 96th St	Manhattan		13,615 GSF	Fair	< 2 years		
4	Not Solar-Ready	DPR	Asser Levy Recreation Center and Pool	East 23rd St at FDR Dr	Manhattan	EJZ	19,806 GSF	Fair	> 20 years		
4	Solar-Ready	DPR	Recreation Center 54	348 East 54th St	Manhattan		21,920 GSF	Between Good and Fair	< 2 years		Cool Roof
4	Not Solar-Ready	NYPD	19th Precinct	153 East 67th St	Manhattan		24,326 GSF	Between Fair and Poor	5 to 9 years		
4	Not Solar-Ready	DHS	New Providence SRO Residence	225 East 45th St	Manhattan		32,221 GSF	Under construction	Under construction		
4	Not Solar-Ready	DOE	M486	120 W.46 STREET	Manhattan	EJZ	62,180 GSF	Fair	> 20 years		
4	Not Solar-Ready	DOE	M169	110 EAST 88 STREET	Manhattan		74,480 GSF	Fair	> 20 years		
4	Not Solar-Ready	DOE	M488	228 EAST 57 STREET	Manhattan		80,000 GSF	Unknown	Unknown		
4	Solar-Ready	DCLA	The Met Breuer	945 Madison Avenue	Manhattan		82,000 GSF	Good	2 to 4 years		
4	Not Solar-Ready	OCME	Chief Medical Examiners Building	520 1st Ave	Manhattan	EJZ	90,456 GSF	Poor	> 20 years		
4	Not Solar-Ready	DOE	M006	45 EAST 81 STREET	Manhattan		91,300 GSF	Fair	> 20 years		
4	Not Solar-Ready	NYPL	Mid-Manhattan Library	455 5th Ave	Manhattan		146,157 GSF	Good	10 to 14 years		
4	Solar-Ready	DCLA	New York City Center	131 W 55 St.	Manhattan		177,000 GSF	Good	2 to 4 years		
4	Not Solar-Ready	HHC	Ambulatory Care Building	462 1st Ave	Manhattan	EJZ	192,559 GSF	Good	10 to 14 years		
4	Solar-Ready	DCLA	Carnegie Hall	881 7th Ave	Manhattan		304,000 GSF	Good	2 to 4 years		
4	Not Solar-Ready	OCME	OCME Center for Forensic Sciences	421 East 26th St	Manhattan	EJZ	330,000 GSF	Good	10 to 14 years		
4	Not Solar-Ready	DHS	Bellevue Men's Shelter	400 East 30th St	Manhattan	EJZ	480,000 GSF	Fair	> 20 years		
4	Not Solar-Ready	DOE	M630	1075 SECOND AVE	Manhattan		632,828 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
4	Solar-Ready	NYPL	Central Library - Stephen A. Schwartzman Building	476 5th Ave	Manhattan		661,428 GSF	Good	2 to 4 years		
5	Not Solar-Ready	DPR	John Jay Park, Pool and Comfort Station	East 76th St at FDR Dr	Manhattan		10,800 GSF	Fair	15 to 19 years		
5	Not Solar-Ready	NYPL	Webster Branch Library	1465 York Ave	Manhattan		11,801 GSF	Fair	> 20 years		
5	Not Solar-Ready	NYPL	67th Street Branch Library	328 East 67th St	Manhattan		13,788 GSF	Poor	15 to 19 years		
5	Not Solar-Ready	DPR	Gracie Mansion	97 East End Ave	Manhattan		15,000 GSF	Fair	15 to 19 years		
5	Solar-Ready	DCLA	Metropolitan Museum of Art Storage	438-440 East 91st St	Manhattan		27,323 GSF	Good	5 to 9 years		
5	Solar-Ready	DOE	M816	323 East 91st St	Manhattan		43,150 GSF	Good	5 to 9 years		
5	Not Solar-Ready	DOE	M190	311 EAST 82 STREET	Manhattan		50,700 GSF	Fair	15 to 19 years		
5	Not Solar-Ready	DPR	Asphalt Green Recreation Facility	1750 York Ave	Manhattan		56,000 GSF	Fair	> 20 years		
5	Not Solar-Ready	DOE	M183	419 EAST 66 STREET	Manhattan		58,800 GSF	Under construction	Under construction		
5	Not Solar-Ready	DOE	M066	421 EAST 88 STREET	Manhattan		69,680 GSF	Fair	> 20 years		
5	Solar-Ready	DOE	M151	1763 1ST AVENUE	Manhattan		78,595 GSF	Between Good and Fair	5 to 9 years		
5	Solar-Ready	DOE	M114	331 EAST 91ST STREET	Manhattan		79,020 GSF	Good	5 to 9 years		
5	Not Solar-Ready	DOE	M198	1700 3RD AVENUE	Manhattan		109,325 GSF	Between Fair and Poor	15 to 19 years		
5	Solar-Ready	DOE	M271	645 MAIN ST.	Manhattan		115,085 GSF	Good	2 to 4 years		
5	Solar-Ready	DOE	M158	1458 YORK AVENUE	Manhattan		127,325 GSF	Good	< 2 years		
5	Not Solar-Ready	DOE	M480	317 E. 67 STREET	Manhattan		361,820 GSF	Between Fair and Poor	> 20 years		
6	Not Solar-Ready	DPR	Wollman Rink	Mid Central Park at 65th St	Manhattan	EJZ	10,800 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
6	Not Solar-Ready	DPR	Central Park Lasker Rink and Pool	Central Park East Drive	Manhattan	EJZ	11,000 GSF	Fair	> 20 years		
6	Not Solar-Ready	DPR	CPC 79th St Maintenance Yard	West 79th St Transverse	Manhattan	EJZ	11,000 GSF	Fair	> 20 years		
6	Not Solar-Ready	DPR	North Meadow Recreation Center	Mid Central Park at 97th St Transverse	Manhattan	EJZ	13,000 GSF	Fair	> 20 years		
6	Not Solar-Ready	FDNY	Ladder Co. 25 and Division 3	205 West 77th St	Manhattan		13,300 GSF	Unknown	15 to 19 years		
6	Not Solar-Ready	FDNY	Manhattan Central Office	79th St Transverse Rd	Manhattan	EJZ	13,465 GSF	Unknown	> 20 years		
6	Not Solar-Ready	DPR	Tavern on the Green	65th St at Central Park West	Manhattan	EJZ	14,436 GSF	Fair	> 20 years		
6	Not Solar-Ready	NYPL	St. Agnes Branch Library	444 Amsterdam Ave	Manhattan		17,792 GSF	Fair	10 to 14 years		
6	Not Solar-Ready	DPR	Gertrude Ederle Recreation Center	232 West 60th St	Manhattan		20,000 GSF	Fair	> 20 years		
6	Not Solar-Ready	DPR	Manhattan Parks Shop and Garage	Mid Central Park at West 86th Transverse Rd	Manhattan	EJZ	20,000 GSF	Fair	> 20 years		
6	Solar-Ready	NYPD	22nd Precinct	190 86th St Transverse Rd	Manhattan	EJZ	21,700 GSF	Good	5 to 9 years		
6	Not Solar-Ready	NYPD	20th Precinct	120 West 82nd St	Manhattan	EJZ	28,000 GSF	Unknown	> 20 years		
6	Not Solar-Ready	DPR	Arsenal Building	830 5th Ave	Manhattan	EJZ	39,904 GSF	Fair	15 to 19 years		
6	Not Solar-Ready	DOE	M841	466 WEST END AVENUE	Manhattan		64,880 GSF	Fair	> 20 years		
6	Solar-Ready	DOE	M166	132 WEST 89 STREET	Manhattan		87,680 GSF	Fair	5 to 9 years		
6	Solar-Ready	DOE	M191	210 WEST 61 STREET	Manhattan		90,080 GSF	Good	2 to 4 years		
6	Not Solar-Ready	DOE	M084	32 WEST 92 STREET	Manhattan		104,525 GSF	Fair	10 to 14 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
6	Not Solar-Ready	DOE	M199	270 WEST 70 STREET	Manhattan		105,700 GSF	Between Good and Fair	10 to 14 years		
6	Not Solar-Ready	DOE	M009	100 WEST 84 STREET	Manhattan		105,725 GSF	Fair	15 to 19 years		
6	Not Solar-Ready	DOE	M087	160 WEST 78 STREET	Manhattan		106,800 GSF	Fair	15 to 19 years		
6	Solar-Ready	DOE	M075	735 WEST END AVENUE	Manhattan		110,575 GSF	Fair	5 to 9 years		
6	Not Solar-Ready	NYPL	The Library for the Performing Arts	40 Lincoln Center Plz	Manhattan		138,384 GSF	Between Good and Fair	15 to 19 years		
6	Not Solar-Ready	DOE	M118	154 WEST 93 STREET	Manhattan		168,175 GSF	Under construction	Under construction		
6	Not Solar-Ready	DCLA	Lincoln Center Garage/Plaza	West 65th St at Amsterdam Ave	Manhattan		200,000 GSF	Between Good and Fair	> 20 years		
6	Not Solar-Ready	DCLA	David H. Koch Theater	20 Lincoln Ctr	Manhattan		247,480 GSF	Between Fair and Poor	> 20 years		
6	Solar-Ready	DSNY	Manhattan 4, 4A, 7 District Garage; Salt	650 West 57th St	Manhattan		247,669 GSF	Good	2 to 4 years	Yes	
6	Not Solar-Ready	DCLA	David Geffen Hall	140 West 65th St	Manhattan		300,000 GSF	Between Good and Fair	> 20 years		
6	Solar-Ready	DCLA	Samuel B. & David Rose Building	70 Lincoln Center Plz	Manhattan		450,000 GSF	Good	5 to 9 years		
6	Not Solar-Ready	DOE	M490	122 AMSTERDAM AVE	Manhattan	EJZ	524,950 GSF	Fair	> 20 years	Yes	
6	Solar-Ready	DCLA	Metropolitan Opera House	Lincoln Center Plaza	Manhattan		860,000 GSF	Good	2 to 4 years		
6	Not Solar-Ready	DCLA	American Museum of Natural History	200 Central Park West	Manhattan		1,500,000 GSF	Between Good and Fair	> 20 years	Yes	
6	Not Solar-Ready	DCLA	Metropolitan Museum of Art	1000 5th Ave	Manhattan	EJZ	2,153,282 GSF	Good	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
7	Not Solar-Ready	FDNY	Engine Co. 80 and Ladder Co. 23	503 West 139th St	Manhattan	EJZ	10,667 GSF	Between Fair and Poor	15 to 19 years		
7	Not Solar-Ready	FDNY	Engine Co. 37 and Ladder Co. 40	415 West 125th St	Manhattan	EJZ	11,778 GSF	Between Fair and Poor	> 20 years		
7	Not Solar-Ready	FDNY	Engine Co. 84 and Ladder Co. 34	513 West 161st St	Manhattan	EJZ	11,792 GSF	Fair	10 to 14 years		
7	Not Solar-Ready	NYPL	George Bruce Branch Library	518 West 125th St	Manhattan	EJZ	16,364 GSF	Fair	10 to 14 years		
7	Not Solar-Ready	DOHMH	Manhattanville Health Center	21 Old Broadway	Manhattan	EJZ	17,000 GSF	Unknown	10 to 14 years		
7	Not Solar-Ready	NYPL	Hamilton Grange Branch Library	503 West 145th St	Manhattan	EJZ	20,403 GSF	Poor	15 to 19 years		
7	Not Solar-Ready	NYPD	30th Precinct	451 West 151st St	Manhattan	EJZ	32,764 GSF	Between Fair and Poor	15 to 19 years		
7	Not Solar-Ready	NYPD	26th Precinct	520 West 126th St	Manhattan	EJZ	36,856 GSF	Good	15 to 19 years		
7	Not Solar-Ready	DOHMH	Riverside Health Center	160 West 100th St	Manhattan		43,877 GSF	Poor	5 to 9 years		
7	Not Solar-Ready	NYPD	24th Precinct	151 West 100th St	Manhattan	EJZ	44,485 GSF	Poor	15 to 19 years		
7	Solar-Ready	HHC	Lower Washington Heights NFCC Clinic	1721 Amsterdam Ave	Manhattan	EJZ	59,209 GSF	Fair	5 to 9 years		
7	Not Solar-Ready	DSNY	W. 135th Marine Transfer Station	135th St & Hudson River	Manhattan		60,932 GSF	Fair	> 20 years		
7	Not Solar-Ready	DOT	West Side Highway Bents South Storage Yard	672 West 158th St	Manhattan	EJZ	61,000 GSF	Unknown	Unknown		
7	Not Solar-Ready	DOE	M093	501-503 WEST 152 STREET	Manhattan	EJZ	80,600 GSF	Good	10 to 14 years		
7	Not Solar-Ready	DOE	M163	163 WEST 97 STREET	Manhattan		82,801 GSF	Fair	15 to 19 years		
7	Solar-Ready	DOE	M004	500 WEST 160 STREET	Manhattan	EJZ	84,100 GSF	Good	2 to 4 years		
7	Solar-Ready	DOE	M036	123 MORNINGSIDE DRIVE	Manhattan	EJZ	85,280 GSF	Good	5 to 9 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
7	Solar-Ready	DOE	M145	150 WEST 105 STREET	Manhattan	EJZ	93,680 GSF	Between Good and Fair	5 to 9 years	Yes	
7	Solar-Ready	NYPD	Shop 9	675 West 158th St	Manhattan	EJZ	94,200 GSF	Good	5 to 9 years		
7	Not Solar-Ready	DOE	M506	140 WEST 102ND STREET	Manhattan	EJZ	102,100 GSF	Between Fair and Poor	15 to 19 years		
7	Not Solar-Ready	DHS	Regent Hotel Shelter	2720 Broadway	Manhattan		102,275 GSF	Poor	> 20 years		
7	Not Solar-Ready	DOE	M192	500 WEST 138 STREET	Manhattan	EJZ	118,788 GSF	Fair	> 20 years		
7	Not Solar-Ready	DOE	M054	103 WEST 107 STREET	Manhattan	EJZ	136,800 GSF	Fair	15 to 19 years		
7	Not Solar-Ready	DOE	M165	234 WEST 109 STREET	Manhattan	EJZ	144,125 GSF	Between Fair and Poor	> 20 years		
7	Not Solar-Ready	DOE	M043	509 WEST 129 STREET	Manhattan	EJZ	151,280 GSF	Under construction	Under construction		
7	Not Solar-Ready	DOE	M125	425 WEST 123 STREET	Manhattan	EJZ	160,925 GSF	Between Fair and Poor	15 to 19 years		
7	Not Solar-Ready	DOE	M153	1750 AMSTERDAM AVENUE	Manhattan	EJZ	162,125 GSF	Fair	> 20 years		
7	Not Solar-Ready	DOE	M195	625 WEST 133 STREET	Manhattan	EJZ	186,000 GSF	Poor	> 20 years		
7	Not Solar-Ready	DEP	Main Building	North River WPCP	Manhattan	EJZ	259,240 GSF	Poor	> 20 years		
8	Not Solar-Ready	NYPD	40th Precinct	257 Alexander Ave	Bronx	EJZ	10,296 GSF	Good	10 to 14 years		
8	Not Solar-Ready	FDNY	Building 8 - Haz Mat Ops	8 Cammarata Ave	Manhattan	EJZ	10,882 GSF	Unknown	Unknown		
8	Not Solar-Ready	FDNY	Engine Co. 35 and Ladder Co. 14, Batt. 12	2282 3rd Ave	Manhattan	EJZ	10,900 GSF	Between Fair and Poor	15 to 19 years		
8	Not Solar-Ready	FDNY	Engine Co. 60 and Ladder Co. 17, Batt. 14	341 East 143rd St	Bronx	EJZ	11,250 GSF	Between Fair and Poor	> 20 years		
8	Not Solar-Ready	DEP	Dewatering: A2	Wards Island WPCP	Manhattan	EJZ	11,286 GSF	Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
8	Not Solar-Ready	DHS	HS Cottage 1	124 Sunken Garden Loop, Ward's Island	Manhattan	EJZ	11,500 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DHS	HS Cottage 3	126 Sunken Garden Loop, Ward's Island	Manhattan	EJZ	11,500 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DHS	HS Cottage 4	127 Sunken Garden Loop, Ward's Island	Manhattan	EJZ	12,100 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	FDNY	Engine Co. 91	242 East 111th St	Manhattan	EJZ	12,298 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DEP	Dewatering: A3	Wards Island WPCP	Manhattan	EJZ	12,344 GSF	Poor	> 20 years		
8	Not Solar-Ready	DEP	#31 Old Administration Bldg	Wards Island WPCP	Manhattan	EJZ	12,720 GSF	Poor	> 20 years		
8	Not Solar-Ready	DEP	Old Administration Bldg	Wards Island WPCP	Manhattan	EJZ	12,720 GSF	Unknown	> 20 years		
8	Not Solar-Ready	NYPL	Aguilar Branch Library	174 East 110th St	Manhattan		13,126 GSF	Fair	15 to 19 years		
8	Solar-Ready	NYPL	125th Street Branch Library	224 East 125th St	Manhattan	EJZ	14,013 GSF	Fair	< 2 years		
8	Not Solar-Ready	DOHMH	Animal Shelter - Manhattan	326 East 110th St	Manhattan	EJZ	14,077 GSF	Good	10 to 14 years		
8	Not Solar-Ready	DOE	X855	577 EAST 139 STREET	Bronx	EJZ	14,460 GSF	Fair	> 20 years		
8	Not Solar-Ready	DHS	HS Cottage 2	125 Sunken Garden Loop, Ward's Island	Manhattan	EJZ	14,500 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	FDNY	Building 6 - Fleet Services Workshop	20 Reilly Blvd	Manhattan	EJZ	14,730 GSF	Between Fair and Poor	> 20 years		
8	Not Solar-Ready	NYPL	Mott Haven Branch Library	321 East 140th St	Bronx	EJZ	16,020 GSF	Good	10 to 14 years		
8	Not Solar-Ready	DEP	#24 Residuals Building	Wards Island WPCP	Manhattan	EJZ	17,500 GSF	Poor	> 20 years		
8	Not Solar-Ready	DEP	Residuals Handling	Wards Island WPCP	Manhattan	EJZ	17,500 GSF	Unknown	> 20 years		
8	Not Solar-Ready	DEP	#22 "E" Battery Gallery	Wards Island WPCP	Manhattan	EJZ	18,000 GSF	Between Good and Fair	10 to 14 years		
8	Not Solar-Ready	DEP	E Battery Control	Wards Island WPCP	Manhattan	EJZ	18,000 GSF	Unknown	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
8	Not Solar-Ready	DOE	M107	1680 LEXINGTON AVENUE	Manhattan	EJZ	18,000 GSF	Fair	10 to 14 years		
8	Not Solar-Ready	FDNY	Building 7 - Mask Services Unit	4 Cammarata Ave	Manhattan	EJZ	18,359 GSF	Unknown	Unknown		
8	Not Solar-Ready	DEP	#21 Marine Building	Wards Island WPCP	Manhattan	EJZ	20,000 GSF	Poor	> 20 years		
8	Not Solar-Ready	DEP	Marine Building	Wards Island WPCP	Manhattan	EJZ	20,000 GSF	Unknown	> 20 years		
8	Not Solar-Ready	HHC	Lincoln Detox Center Clinic (Substance Abuse Division)	349 East 140th St	Bronx	EJZ	21,675 GSF	Fair	> 20 years		
8	Solar-Ready	DHS	Jennie A. Clarke Residence	179 East 100th St	Manhattan	EJZ	21,870 GSF	Good	< 2 years		
8	Solar-Ready	DFTA	Leonardo Coverio Senior Center	312 East 109th St	Manhattan	EJZ	22,978 GSF	Good	5 to 9 years		
8	Solar-Ready	DPR	Thomas Jefferson Recreation Center	2180 1st Ave	Manhattan		23,357 GSF	Good	2 to 4 years		Green Roof
8	Not Solar-Ready	DOE	X807	501 COURTLANDT AVE.	Bronx	EJZ	24,000 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DEP	#34 Sludge Storage	Wards Island WPCP	Manhattan	EJZ	25,000 GSF	Poor	> 20 years		
8	Solar-Ready	NYPD	Randall's Island Street Crime Unit	1 Randall's Island	Manhattan	EJZ	25,000 GSF	Good	2 to 4 years		
8	Not Solar-Ready	DCAS	Harlem Courthouse	170 East 121st St	Manhattan	EJZ	25,700 GSF	Fair	> 20 years		
8	Not Solar-Ready	DPR	Icahn Stadium	20 Randall's Island	Manhattan	EJZ	26,000 GSF	Fair	10 to 14 years		
8	Solar-Ready	DPR	Mill Pond Park Power House	1 East 150th Street	Bronx	EJZ	26,978 GSF	Fair	5 to 9 years		Green Roof
8	Not Solar-Ready	NYPD	23rd Precinct and Engine Company 53	164 East 102nd St	Manhattan	EJZ	28,744 GSF	Unknown	15 to 19 years		
8	Not Solar-Ready	DEP	#33 Manhattan Grit Chamber	Wards Island WPCP	Manhattan	EJZ	30,000 GSF	Poor	> 20 years		
8	Not Solar-Ready	DHS	Clarke Thomas Building	121 Hell Gate Circle, Ward's Island	Manhattan	EJZ	30,500 GSF	Unknown	Unknown		
8	Not Solar-Ready	DEP	#32 Bronx Grit Chamber	Wards Island WPCP	Manhattan	EJZ	37,000 GSF	Poor	> 20 years		
8	Not Solar-Ready	DEP	#3 Dewatering: A1	Wards Island WPCP	Manhattan	EJZ	39,839 GSF	Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
8	Not Solar-Ready	FDNY	Building 9 - Administration	9 Reilly Blvd	Manhattan	EJZ	41,224 GSF	Between Fair and Poor	> 20 years		
8	Not Solar-Ready	FDNY	Building 11 - Administration	11 Reilly Blvd	Manhattan	EJZ	42,554 GSF	Between Fair and Poor	> 20 years		
8	Not Solar-Ready	DEP	#9 Pump & Blower House	Wards Island WPCP	Manhattan	EJZ	46,324 GSF	Poor	> 20 years		
8	Not Solar-Ready	DEP	Pump And Blower	Wards Island WPCP	Manhattan	EJZ	46,324 GSF	Unknown	> 20 years		
8	Not Solar-Ready	DSNY	Manhattan 11 District Garage	343 East 99th St	Manhattan	EJZ	47,000 GSF	Poor	> 20 years		
8	Not Solar-Ready	DOHMH	East Harlem Health Center	158 East 115th St	Manhattan	EJZ	47,349 GSF	Good	10 to 14 years		
8	Not Solar-Ready	DEP	#17 Cake Storage	Wards Island WPCP	Manhattan	EJZ	50,625 GSF	Poor	> 20 years		
8	Solar-Ready	DPR	St. Mary's Recreation Center and Indoor Pool	450 St Anns Ave	Bronx	EJZ	56,125 GSF	Between Good and Fair	5 to 9 years		Green Roof
8	Not Solar-Ready	DHS	Schwartz Homeless Shelter	65 Charles Gay Loop, Ward's Island	Manhattan	EJZ	57,430 GSF	Unknown	Unknown		
8	Not Solar-Ready	HHC	Segundo Ruiz Belvis Diagnostic and Treatment Center	545 East 142nd St	Bronx	EJZ	62,684 GSF	Between Fair and Poor	> 20 years		
8	Not Solar-Ready	DOE	M495	234 EAST 105 STREET	Manhattan	EJZ	66,060 GSF	Between Fair and Poor	10 to 14 years		
8	Not Solar-Ready	DEP	Hypo Facility	Wards Island WPCP	Manhattan	EJZ	67,944 GSF	Unknown	> 20 years		
8	Not Solar-Ready	DHS	Transitional Housing Office	346 Powers Ave	Bronx	EJZ	72,000 GSF	Between Good and Fair	10 to 14 years		
8	Solar-Ready	DHS	Jackson Family Residence	691 East 138th St	Bronx	EJZ	72,000 GSF	Good	5 to 9 years		
8	Solar-Ready	DHS	Emergency Assistance Unit (EAU)	151 East 151st St	Bronx	EJZ	76,743 GSF	Good	5 to 9 years		
8	Not Solar-Ready	DHS	Keener Assessment Shelter	64 Sunken Garden Loop, Ward's Island	Manhattan	EJZ	78,500 GSF	Unknown	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
8	Not Solar-Ready	DOE	M102	315 EAST 113 STREET	Manhattan	EJZ	82,880 GSF	Between Fair and Poor	15 to 19 years		
8	Not Solar-Ready	DOE	X025	811 EAST 149 STREET	Bronx	EJZ	84,080 GSF	Under construction	Under construction		
8	Not Solar-Ready	DOE	M038	232 EAST 103 STREET	Manhattan	EJZ	85,280 GSF	Fair	10 to 14 years		
8	Not Solar-Ready	DOE	X027	519 ST ANNS AVENUE	Bronx	EJZ	86,500 GSF	Between Fair and Poor	> 20 years		
8	Not Solar-Ready	DOE	M072	131 EAST 104 STREET	Manhattan	EJZ	88,900 GSF	Fair	> 20 years		
8	Not Solar-Ready	DHS	Help USA Support Employment Center	111 Sunken Garden Loop, Ward's Island	Manhattan	EJZ	90,010 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DOE	X065	677 EAST 141 STREET	Bronx	EJZ	91,300 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DOE	X073	1020 ANDERSON AVENUE	Bronx	EJZ	92,400 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	HRA	East Harlem Multi Service Center	413 East 120th St	Manhattan	EJZ	93,441 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DOE	X062	660 FOX STREET	Bronx	EJZ	94,880 GSF	Under construction	Under construction	Yes	
8	Not Solar-Ready	DOE	M083	219 EAST 109 STREET	Manhattan	EJZ	94,900 GSF	Fair	10 to 14 years		
8	Not Solar-Ready	DOE	M096	216 EAST 120 STREET	Manhattan	EJZ	94,900 GSF	Fair	15 to 19 years		
8	Solar-Ready	DHS	University Avenue Family Residences	1041 University Ave	Bronx	EJZ	99,975 GSF	Good	< 2 years		
8	Not Solar-Ready	DOE	X030	510 EAST 141 STREET	Bronx	EJZ	100,900 GSF	Between Good and Fair	10 to 14 years		
8	Not Solar-Ready	DOE	M007	160 EAST 120 STREET	Manhattan	EJZ	102,200 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DOE	X005	564 JACKSON AVENUE	Bronx	EJZ	103,280 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DOE	M155	319 EAST 117 STREET	Manhattan	EJZ	104,500 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
8	Not Solar-Ready	DOE	X161	620 TINTON AVENUE	Bronx	EJZ	104,525 GSF	Between Fair and Poor	10 to 14 years		
8	Not Solar-Ready	FDNY	EMS 10	1918 1st Ave	Manhattan	EJZ	105,650 GSF	Good	10 to 14 years		
8	Not Solar-Ready	DOE	M108	1615 MADISON AVENUE	Manhattan	EJZ	105,725 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DOE	X154	333 EAST 135 STREET	Bronx	EJZ	105,725 GSF	Between Fair and Poor	> 20 years		
8	Not Solar-Ready	DOE	X040	468 EAST 140 STREET	Bronx	EJZ	108,000 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DOE	M057	176 EAST 115 STREET	Manhattan	EJZ	109,300 GSF	Fair	> 20 years		
8	Not Solar-Ready	DOE	M146	421 EAST 106 STREET	Manhattan	EJZ	109,300 GSF	Between Good and Fair	15 to 19 years		
8	Not Solar-Ready	DEP	Dewatering	Wards Island WPCP	Manhattan	EJZ	110,000 GSF	Poor	> 20 years		
8	Solar-Ready	DOE	M646	321 E. 96 ST.	Manhattan	EJZ	112,800 GSF	Between Good and Fair	5 to 9 years		
8	Not Solar-Ready	DCLA	Museum of the City of New York	1220 5th Ave	Manhattan		113,915 GSF	Good	10 to 14 years		
8	Solar-Ready	DOE	M171	19 EAST 103 STREET	Manhattan		114,100 GSF	Good	5 to 9 years		
8	Not Solar-Ready	DOE	X043	165 BROWN PLACE	Bronx	EJZ	116,460 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DOE	X049	383 EAST 139 STREET	Bronx	EJZ	136,925 GSF	Fair	> 20 years		
8	Solar-Ready	DOE	M099	410 EAST 100 STREET	Manhattan	EJZ	138,125 GSF	Good	2 to 4 years		
8	Not Solar-Ready	DEP	#10 Digester	Wards Island WPCP	Manhattan	EJZ	141,043 GSF	Poor	> 20 years		
8	Not Solar-Ready	DOE	M050	433 EAST 100 STREET	Manhattan	EJZ	141,600 GSF	Under construction	Under construction		
8	Not Solar-Ready	DOE	M101	141 EAST 111 STREET	Manhattan	EJZ	142,925 GSF	Between Good and Fair	10 to 14 years		
8	Not Solar-Ready	DOE	X149	360 EAST 145 STREET	Bronx	EJZ	159,600 GSF	Fair	> 20 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
8	Not Solar-Ready	DOE	M013	1573 MADISON AVENUE	Manhattan	EJZ	180,175 GSF	Fair	15 to 19 years		
8	Solar-Ready	DOE	M117	240 EAST 109 STREET	Manhattan	EJZ	192,175 GSF	Good	< 2 years	Yes	
8	Not Solar-Ready	DOE	X183	339 MORRIS AVENUE	Bronx	EJZ	194,400 GSF	Between Fair and Poor	> 20 years		
8	Not Solar-Ready	DOE	X155	470 JACKSON AVENUE	Bronx	EJZ	201,775 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DOE	M045	2351 1ST AVENUE	Manhattan	EJZ	210,000 GSF	Fair	15 to 19 years		
8	Not Solar-Ready	DCLA	Heckscher Building /El Museo de Barrio	1230 5th Ave	Manhattan		210,547 GSF	Poor	> 20 years		
8	Not Solar-Ready	DOE	M435	280 Pleasant Ave	Manhattan		275,000 GSF	Between Good and Fair	10 to 14 years		
8	Not Solar-Ready	DCAS	Bronx County Courthouse	851 Grand Concourse	Bronx	EJZ	550,000 GSF	Fair	10 to 14 years		
9	Not Solar-Ready	FDNY	Engine Co. 69 and Ladder Co. 28, Batt. 16	248 West 143rd St	Manhattan	EJZ	11,250 GSF	Between Fair and Poor	15 to 19 years		
9	Not Solar-Ready	FDNY	Engine Co. 58 & Ladder Co. 26	1367 5th Ave	Manhattan	EJZ	12,000 GSF	Unknown	Unknown		
9	Not Solar-Ready	NYPL	Harlem Branch Library	9 West 124th St	Manhattan	EJZ	13,058 GSF	Poor	15 to 19 years		
9	Not Solar-Ready	DPR	Pelham Fritz Recreation Center	122nd St at Mt Morris Park West	Manhattan		14,000 GSF	Between Good and Fair	10 to 14 years		
9	Not Solar-Ready	NYPL	115th Street Branch Library	203 West 115th St	Manhattan	EJZ	14,080 GSF	Poor	15 to 19 years		
9	Not Solar-Ready	DEP	Manhattan Sewer Maintenance Yard	886 St Nicholas Ave	Manhattan	EJZ	16,779 GSF	Fair	> 20 years		
9	Not Solar-Ready	HHC	Sydenham Health Center	264 West 118th St	Manhattan	EJZ	21,081 GSF	Poor	> 20 years		
9	Solar-Ready	DPR	Marcus Garvey Park Pool	124th St at 5th Ave	Manhattan		22,800 GSF	Between Good and Fair	5 to 9 years		
9	Not Solar-Ready	NYPL	Countee Cullen Branch Library	104 West 136th St	Manhattan	EJZ	23,345 GSF	Poor	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
9	Not Solar-Ready	NYPD	32nd Precinct	250 West 135th St	Manhattan	EJZ	26,255 GSF	Good	10 to 14 years		
9	Not Solar-Ready	DPR	Jackie Robinson Park Pool and Rec Center	146th St	Manhattan	EJZ	30,000 GSF	Fair	> 20 years		
9	Not Solar-Ready	DOHMH	Central Harlem Health Center	2238 5th Ave	Manhattan		31,180 GSF	Unknown	10 to 14 years		
9	Not Solar-Ready	NYPD	28th Precinct	2271-89 8th Ave	Manhattan	EJZ	37,160 GSF	Poor	15 to 19 years		
9	Solar-Ready	DPR	Hansborough Pool and Recreation Center	35 West 134th St	Manhattan	EJZ	38,000 GSF	Good	2 to 4 years		Green Roof
9	Solar-Ready	NYPL	Schomburg Black History Library (Old Building)	103 West 135th St	Manhattan	EJZ	40,000 GSF	Fair	< 2 years		
9	Not Solar-Ready	DHS	Harlem 1 Men's Shelter	2960 Frederick Douglass Blvd	Manhattan	EJZ	41,446 GSF	Unknown	Unknown		
9	Not Solar-Ready	DOE	M911	22 E. 128 ST	Manhattan	EJZ	52,880 GSF	Fair	15 to 19 years		
9	Not Solar-Ready	NYPD	25th Precinct	120 East 119th St	Manhattan	EJZ	62,500 GSF	Fair	15 to 19 years		
9	Solar-Ready	DHS	East 119th Street Veterans Residence	22 East 119th St	Manhattan	EJZ	65,510 GSF	Good	5 to 9 years		
9	Solar-Ready	NYPL	Schomburg Center/Research in Black Culture (New)	515 Malcolm X Blvd	Manhattan	EJZ	69,924 GSF	Fair	< 2 years		
9	Not Solar-Ready	DOE	M133	2121 5TH AVENUE	Manhattan	EJZ	81,680 GSF	Fair	15 to 19 years		
9	Not Solar-Ready	DOE	M194	244 WEST 144 STREET	Manhattan	EJZ	90,080 GSF	Fair	15 to 19 years		
9	Not Solar-Ready	HRA	Help Harbor Transitional Housing Site II	126 West 127th St	Manhattan	EJZ	95,000 GSF	Between Good and Fair	Unknown		
9	Solar-Ready	DOE	M079	55 EAST 120 STREET	Manhattan	EJZ	97,500 GSF	Good	2 to 4 years	Yes	
9	Not Solar-Ready	DOE	M180	370 WEST 120 STREET	Manhattan	EJZ	99,680 GSF	Fair	15 to 19 years		
9	Solar-Ready	DOE	M197	2230 5TH AVENUE	Manhattan		100,925 GSF	Good	2 to 4 years		
9	Solar-Ready	DOE	M208	20 WEST 112 STREET	Manhattan	EJZ	102,000 GSF	Good	2 to 4 years		
9	Not Solar-Ready	DOE	M129	425 WEST 130 STREET	Manhattan		102,125 GSF	Fair	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
9	Solar-Ready	DOE	M175	175 WEST 134 STREET	Manhattan	EJZ	102,175 GSF	Good	5 to 9 years		
9	Not Solar-Ready	DOE	M207	41 WEST 117 STREET	Manhattan	EJZ	103,200 GSF	Fair	15 to 19 years		
9	Not Solar-Ready	DOE	M113	240 WEST 113 STREET	Manhattan	EJZ	105,100 GSF	Fair	> 20 years		
9	Not Solar-Ready	DOE	M076	220 WEST 121 STREET	Manhattan	EJZ	105,680 GSF	Fair	15 to 19 years		
9	Not Solar-Ready	DOE	M046	2987 FREDERICK DOUGLASS BLVD.	Manhattan	EJZ	107,538 GSF	Between Fair and Poor	15 to 19 years		
9	Solar-Ready	DOE	M081	212 W. 120TH ST	Manhattan	EJZ	110,480 GSF	Good	5 to 9 years	Yes	
9	Not Solar-Ready	DOE	M161	499 WEST 133 STREET	Manhattan	EJZ	114,125 GSF	Fair	15 to 19 years		
9	Not Solar-Ready	HHC	Kountz Pavilion	3-13 West 136th St	Manhattan		121,000 GSF	Fair	> 20 years		
9	Not Solar-Ready	DOE	M808	133 MORNINGSIDE AVE	Manhattan	EJZ	124,576 GSF	Fair	10 to 14 years		
9	Solar-Ready	DOE	M123	301 WEST 140 STREET	Manhattan	EJZ	125,048 GSF	Good	2 to 4 years	Yes	
9	Not Solar-Ready	HHC	Ronald H. Brown Ambulatory Care Pavilion	46 West 137th St	Manhattan		127,800 GSF	Poor	> 20 years		
9	Not Solar-Ready	HHC	Henry J. Carter Hospital - Skilled Nursing Facility	1752 Park Ave	Manhattan	EJZ	128,734 GSF	Good	15 to 19 years		
9	Not Solar-Ready	HRA	Help Harbor Transitional Housing Site I	127 West 127th St	Manhattan	EJZ	134,468 GSF	Between Good and Fair	Unknown		
9	Solar-Ready	DOE	M136	6 EDGECOMBE AVENUE	Manhattan	EJZ	135,725 GSF	Good	2 to 4 years		
9	Not Solar-Ready	DOE	M030	144-176 EAST 128 STREET	Manhattan	EJZ	163,375 GSF	Under construction	Under construction		
9	Not Solar-Ready	HHC	Women's Pavilion	15 West 136th St	Manhattan		165,900 GSF	Poor	> 20 years		
9	Not Solar-Ready	DOE	M540	443 West 135th St	Manhattan		195,600 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
9	Not Solar-Ready	DOE	M088	215 WEST 114TH ST.	Manhattan	EJZ	208,925 GSF	Between Good and Fair	15 to 19 years		
9	Not Solar-Ready	DOE	M010	2581 ADAM CLAYTON POWELL BLVD.	Manhattan		214,800 GSF	Fair	10 to 14 years	Yes	
9	Solar-Ready	HHC	Henry J. Carter Hospital	1879 Madison Ave	Manhattan	EJZ	276,398 GSF	Good	2 to 4 years		
9	Not Solar-Ready	HHC	Martin Luther King Pavilion	506 Lenox Ave	Manhattan		667,100 GSF	Fair	> 20 years		
10	Solar-Ready	DPR	J Hood Wright Park Recreation Center	351 Fort Washington Ave	Manhattan	EJZ	10,500 GSF	Between Good and Fair	5 to 9 years		
10	Not Solar-Ready	DOE	M847	93 NAGLE AVE.	Manhattan	EJZ	10,626 GSF	Poor	> 20 years		
10	Not Solar-Ready	NYPL	Fort Washington Branch Library	535 West 179th St	Manhattan	EJZ	15,158 GSF	Poor	> 20 years		
10	Not Solar-Ready	NYPL	Inwood Branch Library	4790 Broadway	Manhattan	EJZ	17,334 GSF	Poor	> 20 years		
10	Not Solar-Ready	NYPL	Washington Heights Branch Library	1000 St. Nicholas Ave	Manhattan	EJZ	17,497 GSF	Fair	15 to 19 years		
10	Not Solar-Ready	FDNY	Engine Co. 93, Ladder Co. 45 and Batt. 13	515 West 181st St	Manhattan	EJZ	21,883 GSF	Unknown	10 to 14 years		
10	Solar-Ready	DOE	M528	180 WADSWORTH AVENUE	Manhattan	EJZ	25,260 GSF	Good	2 to 4 years		
10	Not Solar-Ready	NYPD	34th Precinct	4295 Broadway	Manhattan		26,697 GSF	Unknown	10 to 14 years		
10	Solar-Ready	DPR	Highbridge Recreation Center	2275 Amsterdam Ave	Manhattan		30,054 GSF	Between Good and Fair	5 to 9 years		Green Roof
10	Not Solar-Ready	DOHMH	Washington Heights Health Center	600 West 168th St	Manhattan	EJZ	51,050 GSF	Unknown	15 to 19 years		
10	Not Solar-Ready	NYPD	33rd Precinct	2207 Amsterdam Ave	Manhattan	EJZ	52,207 GSF	Good	> 20 years		
10	Solar-Ready	DOE	M178	12-18 ELLWOOD STREET	Manhattan	EJZ	66,266 GSF	Fair	2 to 4 years	Yes	
10	Not Solar-Ready	DCLA	The Cloisters	799 Fort Washington Ave	Manhattan		70,000 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
10	Not Solar-Ready	DSNY	Manhattan 12 District Garage	301 West 215th St	Manhattan	EJZ	73,000 GSF	Good	10 to 14 years	Yes	
10	Solar-Ready	DOE	M876	2120 AMSTERDAM AVE.	Manhattan	EJZ	74,690 GSF	Fair	5 to 9 years		
10	Not Solar-Ready	DOE	M187	349 CABRINI BOULEVARD	Manhattan		80,480 GSF	Fair	10 to 14 years		
10	Solar-Ready	DOE	M263	202 SHERMAN AVENUE	Manhattan	EJZ	87,609 GSF	Between Good and Fair	5 to 9 years		
10	Not Solar-Ready	DOE	M008	465 WEST 167 STREET	Manhattan	EJZ	90,100 GSF	Fair	> 20 years		
10	Not Solar-Ready	DOE	M176	4862 BROADWAY	Manhattan	EJZ	91,300 GSF	Fair	> 20 years		
10	Not Solar-Ready	DOE	M132	185 WADSWORTH AVENUE	Manhattan	EJZ	97,300 GSF	Fair	15 to 19 years		
10	Not Solar-Ready	DSNY	BX07/BX08/M08	423 West 215th St	Manhattan	EJZ	100,000 GSF	Between Fair and Poor	Unknown	Yes	
10	Not Solar-Ready	DOE	M098	512 WEST 212 STREET	Manhattan	EJZ	107,134 GSF	Fair	15 to 19 years		
10	Not Solar-Ready	DOE	M048	4360 BROADWAY	Manhattan	EJZ	111,793 GSF	Fair	> 20 years		
10	Solar-Ready	DOE	M005	3703 10TH AVE.	Manhattan	EJZ	111,803 GSF	Good	< 2 years		
10	Not Solar-Ready	DOE	M152	93 NAGLE AVE.	Manhattan	EJZ	112,058 GSF	Fair	10 to 14 years		
10	Not Solar-Ready	DOE	M164	401 WEST 164 STREET	Manhattan	EJZ	115,200 GSF	Fair	15 to 19 years		
10	Not Solar-Ready	DOE	M115	586 WEST 177 STREET	Manhattan	EJZ	124,900 GSF	Fair	10 to 14 years	Yes	
10	Solar-Ready	DOE	M128	560 WEST 169 STREET	Manhattan	EJZ	128,480 GSF	Good	5 to 9 years	Yes	
10	Not Solar-Ready	DOE	M189	2580 AMSTERDAM AVENUE	Manhattan	EJZ	134,387 GSF	Between Fair and Poor	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
10	Not Solar-Ready	DOE	M173	306 FORT WASHINGTON AVENUE	Manhattan	EJZ	135,965 GSF	Between Fair and Poor	15 to 19 years		
10	Not Solar-Ready	DOE	M052	650 ACADEMY STREET	Manhattan	EJZ	164,575 GSF	Fair	10 to 14 years		
10	Not Solar-Ready	DOE	M090	21 JUMEL PLACE	Manhattan	EJZ	193,375 GSF	Between Fair and Poor	> 20 years		
10	Not Solar-Ready	DOE	M218	4600 BROADWAY	Manhattan	EJZ	210,000 GSF	Fair	> 20 years		
10	Not Solar-Ready	DHS	Fort Washington Armory-Shelter	216 Ft Washington Ave	Manhattan	EJZ	249,473 GSF	Fair	15 to 19 years		
10	Not Solar-Ready	DOE	M465	549 AUDUBON AVE	Manhattan	EJZ	374,312 GSF	Between Fair and Poor	15 to 19 years	Yes	
11	Not Solar-Ready	DPR	Van Cortlandt Park Pool	Broadway at West 242nd St	Bronx	EJZ	10,000 GSF	Fair	> 20 years		
11	Not Solar-Ready	NYPL	Mosholu Branch Library	285 East 205th St	Bronx	EJZ	10,285 GSF	Fair	Unknown		
11	Solar-Ready	NYPL	Kingsbridge Library	291 West 231 St	Bronx	EJZ	12,625 GSF	Good	< 2 years		
11	Not Solar-Ready	DOE	X868	2756 RESERVOIR AVENUE	Bronx		13,023 GSF	Fair	> 20 years		
11	Not Solar-Ready	DCLA	Glyndor House	675 Independence Ave	Bronx		14,362 GSF	Fair	> 20 years		
11	Not Solar-Ready	DPR	Arthur Ross Nursery	Nursery Rd at Van Cortlandt Park East	Bronx	EJZ	15,000 GSF	Fair	> 20 years		
11	Not Solar-Ready	DEP	North Bronx Yard and Reservoir HQ	411 East 203rd St	Bronx	EJZ	16,200 GSF	Between Good and Fair	> 20 years		
11	Solar-Ready	NYPD	52nd Precinct	3016 Webster Ave	Bronx	EJZ	18,746 GSF	Good	5 to 9 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
11	Not Solar-Ready	DCLA	NYBG Peter Jay Sharp Building Parking Garage	410 Bedford Park Blvd	Bronx	EJZ	19,270 GSF	Between Fair and Poor	15 to 19 years		
11	Not Solar-Ready	DCLA	Wave Hill House	675 Independence Ave	Bronx		24,055 GSF	Fair	> 20 years		
11	Not Solar-Ready	DOE	X852	3617 BAINBRIDGE AVENUE	Bronx	EJZ	27,600 GSF	Fair	15 to 19 years		
11	Solar-Ready	DOE	X056	341 EAST 207 STREET	Bronx	EJZ	31,545 GSF	Between Good and Fair	2 to 4 years		
11	Not Solar-Ready	DEP	3201 Jerome Ave	3201 Jerome Ave	Bronx	EJZ	39,431 GSF	Between Fair and Poor	> 20 years		
11	Not Solar-Ready	DOE	X019	4318 KATONAH AVENUE	Bronx		43,260 GSF	Fair	> 20 years		
11	Not Solar-Ready	NYPD	50th Precinct	3450 Kingsbridge Ave	Bronx		47,097 GSF	Unknown	10 to 14 years		
11	Not Solar-Ready	DOE	X340	25 W. 195 ST	Bronx		67,632 GSF	Between Fair and Poor	15 to 19 years		
11	Not Solar-Ready	DOE	X037	360 WEST 230 STREET	Bronx		70,800 GSF	Fair	> 20 years		
11	Not Solar-Ready	DOE	X081	5550 RIVERDALE AVENUE	Bronx		74,460 GSF	Between Fair and Poor	> 20 years		
11	Not Solar-Ready	DOE	X008	3010 BRIGGS AVENUE	Bronx	EJZ	83,022 GSF	Fair	10 to 14 years		
11	Not Solar-Ready	DOE	X086	2756 RESERVOIR AVENUE	Bronx		130,227 GSF	Fair	15 to 19 years		
11	Not Solar-Ready	DOE	X080	149 EAST MOSHOLU PKWY NORTH	Bronx	EJZ	133,109 GSF	Between Fair and Poor	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
11	Not Solar-Ready	DOE	X020	3050 WEBSTER AVENUE	Bronx	EJZ	141,932 GSF	Fair	15 to 19 years		
11	Not Solar-Ready	DOE	X368	2975 TIBBETT AVENUE	Bronx	EJZ	162,677 GSF	Fair	10 to 14 years		
11	Solar-Ready	DOE	X095	3961 HILLMAN AVENUE	Bronx	EJZ	172,800 GSF	Between Good and Fair	5 to 9 years		
11	Not Solar-Ready	DOE	X141	660 WEST 237 STREET	Bronx		204,000 GSF	Fair	> 20 years		
11	Not Solar-Ready	DOE	X430	2780 Reservoir Ave	Bronx		289,400 GSF	Fair	> 20 years	Yes	
11	Not Solar-Ready	HHC	North Central Bronx Hospital	3424 Kossuth Ave	Bronx	EJZ	797,600 GSF	Good	> 20 years		
12	Solar-Ready	NYPL	Wakefield Branch Library	4100 Lowerre Pl	Bronx	EJZ	10,743 GSF	Good	5 to 9 years		
12	Not Solar-Ready	DCAS	Bronx Neighborhood Building	4101 White Plains Rd	Bronx	EJZ	17,364 GSF	Poor	Unknown		
12	Not Solar-Ready	NYPD	47th Precinct	4111 Laconia Ave	Bronx	EJZ	34,700 GSF	Unknown	10 to 14 years		
12	Solar-Ready	DOE	X169	3500 EDSON AVENUE	Bronx	EJZ	37,200 GSF	Good	5 to 9 years		
12	Not Solar-Ready	ACS	1250 East 229 Street	1250 East 229 St	Bronx	EJZ	45,482 GSF	Good	Unknown		
12	Solar-Ready	DOE	X087	1935 BUSSING AVENUE	Bronx	EJZ	52,565 GSF	Fair	5 to 9 years		
12	Not Solar-Ready	DOE	X076	900 ADEE AVENUE	Bronx	EJZ	69,784 GSF	Fair	> 20 years		
12	Not Solar-Ready	DOE	X068	4011 MONTICELLO AVENUE	Bronx	EJZ	84,080 GSF	Fair	15 to 19 years		
12	Not Solar-Ready	DOE	X041	3352 OLINVILLE AVENUE	Bronx	EJZ	85,280 GSF	Between Good and Fair	10 to 14 years		
12	Solar-Ready	DOE	X112	1925 SCHIEFELIN AVENUE	Bronx	EJZ	85,325 GSF	Fair	5 to 9 years	Yes	



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
12	Not Solar-Ready	DOE	X111	3740 BAYCHESTER AVENUE	Bronx	EJZ	85,396 GSF	Fair	15 to 19 years		
12	Solar-Ready	DOE	X021	715 EAST 225 STREET	Bronx	EJZ	90,080 GSF	Good	2 to 4 years	Yes	
12	Solar-Ready	DOE	X103	4125 CARPENTER AVENUE	Bronx	EJZ	91,944 GSF	Fair	5 to 9 years		
12	Not Solar-Ready	DOE	X078	1400 NEEDHAM AVENUE	Bronx	EJZ	109,280 GSF	Fair	15 to 19 years		
12	Not Solar-Ready	DOE	X153	650 BAYCHESTER AVENUE	Bronx		112,200 GSF	Fair	10 to 14 years		
12	Not Solar-Ready	DOE	X178	850 BAYCHESTER AVENUE	Bronx		114,000 GSF	Between Good and Fair	10 to 14 years		
12	Not Solar-Ready	DOE	X189	3441 STEENWICK AVENUE	Bronx	EJZ	129,600 GSF	Fair	10 to 14 years	Yes	
12	Not Solar-Ready	DOE	X160	4140 HUTCHINSON RIVER PK	Bronx	EJZ	147,600 GSF	Fair	15 to 19 years		
12	Not Solar-Ready	DSNY	Bronx 12 District Garage	1643 East 233rd St	Bronx	EJZ	162,380 GSF	Fair	> 20 years	Yes	
12	Not Solar-Ready	DOE	X142	3750 BAYCHESTER AVENUE	Bronx	EJZ	164,751 GSF	Fair	15 to 19 years	Yes	
12	Not Solar-Ready	DOE	X180	700 BAYCHESTER AVENUE	Bronx		180,000 GSF	Fair	10 to 14 years		
12	Not Solar-Ready	DOE	X455	750 BAYCHESTER AVE.	Bronx		648,600 GSF	Fair	15 to 19 years	Yes	
13	Not Solar-Ready	NYPL	Allerton Branch Library	2740 Barnes Ave	Bronx	EJZ	10,984 GSF	Fair	15 to 19 years		
13	Not Solar-Ready	DPR	Orchard Beach Administration Building	1 Orchard Beach Rd	Bronx	EJZ	11,500 GSF	Fair	> 20 years		
13	Not Solar-Ready	NYPL	Morris Park Branch Library	985 Morris Park Ave	Bronx		16,300 GSF	Fair	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
13	Not Solar-Ready	DOHMH	Westchester Health Center	2527 Glebe Ave	Bronx	EJZ	21,364 GSF	Unknown	15 to 19 years		
13	Not Solar-Ready	NYPD	45th Precinct	2877 Barkley Ave	Bronx		26,300 GSF	Between Fair and Poor	Unknown		
13	Not Solar-Ready	NYPD	49th Precinct	2121 Eastchester Rd	Bronx	EJZ	31,070 GSF	Poor	10 to 14 years		
13	Not Solar-Ready	DOE	X108	1166 NEILL AVENUE	Bronx		37,426 GSF	Between Good and Fair	10 to 14 years		
13	Solar-Ready	DOE	X097	1375 MACE AVENUE	Bronx		43,904 GSF	Good	2 to 4 years		
13	Not Solar-Ready	HHC	Jacobi Medical Center Staff Residence	1900 Seminole Ave	Bronx	EJZ	55,300 GSF	Fair	15 to 19 years		
13	Not Solar-Ready	DOE	X175	200 CITY ISLAND AVENUE	Bronx		56,343 GSF	Between Good and Fair	10 to 14 years		
13	Solar-Ready	DOE	X014	3041 BRUCKNER BOULEVARD	Bronx		58,055 GSF	Between Good and Fair	5 to 9 years		
13	Not Solar-Ready	DOE	X981	1840 BOGART AVENUE	Bronx	EJZ	61,280 GSF	Between Fair and Poor	15 to 19 years		
13	Not Solar-Ready	DOE	X418	2040 ANTIN PL	Bronx	EJZ	63,330 GSF	Fair	10 to 14 years		
13	Not Solar-Ready	DOE	X722	2697 WESTCHESTER AVENUE	Bronx	EJZ	78,000 GSF	Fair	10 to 14 years		
13	Not Solar-Ready	DOE	X012	1450 OVERING STREET	Bronx	EJZ	84,100 GSF	Fair	15 to 19 years	Yes	
13	Not Solar-Ready	DOE	X083	950 RHINELANDER AVENUE	Bronx	EJZ	96,100 GSF	Fair	10 to 14 years		
13	Not Solar-Ready	DOE	X105	725 BRADY AVENUE	Bronx	EJZ	97,505 GSF	Fair	15 to 19 years		
13	Solar-Ready	DOE	X121	2750 THROOP AVENUE	Bronx	EJZ	98,884 GSF	Between Good and Fair	5 to 9 years	Yes	

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
13	Solar-Ready	DOE	X089	980 MACE AVENUE	Bronx	EJZ	107,782 GSF	Good	5 to 9 years	Yes	
13	Solar-Ready	DOE	X498	1640 BRONXDALE AVE.	Bronx		122,792 GSF	Between Good and Fair	5 to 9 years		
13	Not Solar-Ready	DOE	X071	3040 ROBERTS AVENUE	Bronx	EJZ	130,693 GSF	Fair	> 20 years		
13	Solar-Ready	DOE	X072	2951 DEWEY AVENUE	Bronx		179,960 GSF	Between Good and Fair	5 to 9 years	Yes	
13	Not Solar-Ready	DOE	X101	2750 LAFAYETTE AVENUE	Bronx	EJZ	182,525 GSF	Poor	15 to 19 years		
13	Solar-Ready	DCAS	Public Safety Answering Center II	350 Marconi St	Bronx	EJZ	450,000 GSF	Good	5 to 9 years		
13	Not Solar-Ready	HHC	Jacobi Medical Center	1400 Pelham Pkwy South	Bronx	EJZ	2,117,244 GSF	Good	15 to 19 years		
14	Not Solar-Ready	CUNY	Loew Annex	2085 University Ave	Bronx		10,138 GSF	Poor	Unknown		
14	Not Solar-Ready	CUNY	Snow Hall	135 Hall of Fame Ter	Bronx	EJZ	10,526 GSF	Unknown	Unknown		
14	Not Solar-Ready	FDNY	Engine Co. 75 and Ladder Co. 33, Batt. 19	2175 Walton Ave	Bronx	EJZ	12,541 GSF	Unknown	15 to 19 years		
14	Not Solar-Ready	CUNY	Havemeyer Lab	185 West 180th St	Bronx		12,768 GSF	Under construction	Under construction		
14	Solar-Ready	CUNY	The Children's Center	2010 Sedgwick Ave	Bronx		13,327 GSF	Good	5 to 9 years		
14	Solar-Ready	DPR	St. James Park Recreation Center	West 192nd St at Jerome Ave	Bronx	EJZ	13,700 GSF	Good	2 to 4 years		Green Roof
14	Not Solar-Ready	CUNY	Roscoe C. Brown Student Center - Brown Annex	160 Hall of Fame Ter	Bronx		14,295 GSF	Poor	Unknown		
14	Not Solar-Ready	CUNY	Philosophy Hall	2070 Sedgwick Ave	Bronx		16,234 GSF	Poor	Unknown		
14	Not Solar-Ready	NYPL	Francis Martin Branch Library	2150 University Ave	Bronx	EJZ	16,486 GSF	Fair	15 to 19 years		
14	Not Solar-Ready	CUNY	Butler Hall	2018 Sedgwick Ave	Bronx		17,028 GSF	Poor	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
14	Not Solar-Ready	CUNY	MacCracken Hall	181 Hall of Fame Ter	Bronx	EJZ	17,028 GSF	Between Fair and Poor	Unknown		
14	Solar-Ready	CUNY	South Hall	187 W 180th St	Bronx		18,978 GSF	Good	5 to 9 years		
14	Solar-Ready	DPR	Kingsbridge Recreation Center	3101 Kings Bridge Ter	Bronx	EJZ	20,468 GSF	Between Good and Fair	5 to 9 years		Green Roof
14	Not Solar-Ready	CUNY	Language Hall	2050 Sedgwick Ave	Bronx		21,413 GSF	Between Fair and Poor	Unknown		
14	Not Solar-Ready	CUNY	Guggenheim Hall	155 West 180 St	Bronx		21,896 GSF	Poor	Unknown		
14	Not Solar-Ready	CUNY	Energy Plant	121 West 180 St	Bronx		25,231 GSF	Poor	Unknown		
14	Not Solar-Ready	ACS	Babove Worldwide Institute Inc.	1810 Davidson Ave	Bronx	EJZ	25,760 GSF	Poor	Unknown		
14	Not Solar-Ready	CUNY	Sage Hall	175 West 180 St	Bronx		27,328 GSF	Good	15 to 19 years		
14	Not Solar-Ready	DOE	X226	1950 SEDGWICK AVENUE	Bronx		27,600 GSF	Fair	> 20 years		
14	Not Solar-Ready	CUNY	Bliss Hall	145 West 180 St	Bronx		29,210 GSF	Between Fair and Poor	Unknown		
14	Not Solar-Ready	CUNY	Community Hall	2020 Sedgwick Ave	Bronx		36,404 GSF	Poor	Unknown		
14	Not Solar-Ready	CUNY	New Hall	135 West 180 St	Bronx		39,605 GSF	Under construction	Under construction		
14	Not Solar-Ready	CUNY	Gould Hall	2151 University Ave	Bronx		41,400 GSF	Poor	Unknown		
14	Not Solar-Ready	DOE	X206	2280 AQUEDUCT AVENUE	Bronx	EJZ	50,400 GSF	Between Good and Fair	10 to 14 years	Yes	
14	Not Solar-Ready	CUNY	Loew Hall	2055 University Ave	Bronx		53,776 GSF	Poor	Unknown		
14	Not Solar-Ready	CUNY	Gould Memorial Library	2060 Sedgwick Ave	Bronx		54,653 GSF	Poor	Unknown		
14	Not Solar-Ready	DOE	X170	1594-98 TOWNSEND AVE.	Bronx	EJZ	56,343 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
14	Not Solar-Ready	CUNY	Roscoe C. Brown Student Center	160 Hall of Fame Ter	Bronx		58,794 GSF	Under construction	Under construction		
14	Not Solar-Ready	CUNY	Polowczyk Hall	2016 Sedgwick Ave	Bronx		61,969 GSF	Poor	Unknown		
14	Solar-Ready	DOE	X360	2880 KINGSBRIDGE TERRACE	Bronx	EJZ	67,280 GSF	Good	2 to 4 years		
14	Solar-Ready	DHS	Mount Eden Avenue SRO Residence	50 Mt Eden Ave West	Bronx	EJZ	68,185 GSF	Good	2 to 4 years		
14	Not Solar-Ready	CUNY	Alumni Gymnasium	2053 University Ave	Bronx		70,616 GSF	Poor	Unknown		
14	Not Solar-Ready	CUNY	Nichols Hall	125 West 180 St	Bronx		73,344 GSF	Poor	Unknown		
14	Not Solar-Ready	DOE	X843	2641 GRAND CONCOURSE	Bronx	EJZ	74,480 GSF	Under construction	Under construction		
14	Solar-Ready	DOE	X240	1509-1531 JEROME AVE.	Bronx	EJZ	74,594 GSF	Good	2 to 4 years		
14	Not Solar-Ready	DOE	X091	2200 AQUEDUCT AVENUE	Bronx	EJZ	78,132 GSF	Poor	10 to 14 years	Yes	
14	Not Solar-Ready	DOE	X033	24-24 JEROME AVENUE	Bronx	EJZ	84,080 GSF	Fair	15 to 19 years		
14	Not Solar-Ready	DOE	X109	1771 POPHAM AVENUE	Bronx	EJZ	86,324 GSF	Fair	> 20 years		
14	Not Solar-Ready	DOE	X122	260 WEST KINGSBRIDGE ROAD	Bronx	EJZ	91,715 GSF	Fair	15 to 19 years		
14	Not Solar-Ready	DOE	X279	2100 WALTON AVE.	Bronx	EJZ	93,516 GSF	Fair	15 to 19 years		
14	Solar-Ready	DOE	X204	1780 DR. MARTIN LUTHER KING JR.	Bronx	EJZ	93,771 GSF	Good	5 to 9 years		
14	Solar-Ready	CUNY	North Hall and Library	200 Hall of Fame Ter	Bronx		93,845 GSF	Good	2 to 4 years		
14	Solar-Ready	DHS	Nelson Ave Family Residence	1605 Nelson Ave	Bronx	EJZ	107,000 GSF	Good	2 to 4 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
14	Not Solar-Ready	DOE	X082	1700 MACOMBS ROAD	Bronx	EJZ	107,125 GSF	Fair	10 to 14 years		
14	Not Solar-Ready	CUNY	Colston Hall	2020 Sedgwick Ave	Bronx		112,416 GSF	Poor	Unknown		
14	Solar-Ready	DOE	X115	120 EAST 184 STREET	Bronx	EJZ	133,325 GSF	Good	5 to 9 years		
14	Solar-Ready	DOE	X143	120 WEST 231 STREET	Bronx	EJZ	159,775 GSF	Good	< 2 years		
14	Not Solar-Ready	DOE	X015	2195 ANDREWS AVENUE	Bronx	EJZ	162,125 GSF	Between Fair and Poor	> 20 years		
14	Not Solar-Ready	DOE	X079	125 EAST 181 STREET	Bronx	EJZ	182,400 GSF	Under construction	Under construction	Yes	
14	Not Solar-Ready	DOE	X306	40 WEST TREMONT AVENUE	Bronx	EJZ	202,975 GSF	Fair	> 20 years		
14	Not Solar-Ready	CUNY	Meister Hall	161 West 180 St	Bronx		230,601 GSF	Poor	Unknown		
15	Not Solar-Ready	DOE	X236	499 EAST 175 STREET	Bronx	EJZ	9,779 GSF	Fair	10 to 14 years		
15	Not Solar-Ready	DCLA	Operations Multi-Purpose Building	2667 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	10,250 GSF	Fair	> 20 years		
15	Not Solar-Ready	DCLA	Operations Garage/Storage Building	2667 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	10,733 GSF	Poor	> 20 years		
15	Solar-Ready	FDNY	Bronx Central Office	1129 East 180th St	Bronx	EJZ	10,860 GSF	Good	5 to 9 years		
15	Not Solar-Ready	DCLA	Bronx Zoo Store	2300 Southern Blvd	Bronx	EJZ	11,000 GSF	Good	15 to 19 years		
15	Solar-Ready	DCLA	Reptile House	2300 Southern Blvd	Bronx	EJZ	11,405 GSF	Good	2 to 4 years		
15	Not Solar-Ready	DCLA	Mouse House	2300 Southern Blvd	Bronx	EJZ	11,600 GSF	Fair	> 20 years		
15	Not Solar-Ready	DCLA	Heads & Horns	2300 Southern Blvd	Bronx	EJZ	11,840 GSF	Good	> 20 years		
15	Not Solar-Ready	NYPL	Tremont Branch Library	1866 Washington Ave	Bronx	EJZ	11,900 GSF	Good	10 to 14 years		
15	Not Solar-Ready	FDNY	Engine Co. 90 and Ladder Co. 41	1843 White Plains Rd	Bronx	EJZ	12,520 GSF	Between Fair and Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
15	Not Solar-Ready	FDNY	Engine Co. 88 and Ladder Co. 38	2225 Belmont Ave	Bronx	EJZ	12,600 GSF	Between Fair and Poor	> 20 years		
15	Not Solar-Ready	DCLA	Zoo Center	2300 Southern Blvd	Bronx	EJZ	14,320 GSF	Good	Unknown		
15	Solar-Ready	DCLA	Stone Mill	2650 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	14,459 GSF	Good	5 to 9 years		
15	Not Solar-Ready	DCLA	Monkey House	2300 Southern Blvd	Bronx	EJZ	15,108 GSF	Good	10 to 14 years		
15	Solar-Ready	DCLA	Garden Cafe & Terrace Room	2700 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	15,540 GSF	Good	2 to 4 years		
15	Not Solar-Ready	DCLA	Dancing Crane	2300 Southern Blvd	Bronx	EJZ	16,000 GSF	Good	15 to 19 years		
15	Not Solar-Ready	DCLA	Administration East	2300 Southern Blvd	Bronx	EJZ	16,176 GSF	Fair	Unknown		
15	Not Solar-Ready	DCLA	Farm Apartments	2300 Southern Blvd	Bronx	EJZ	16,750 GSF	Fair	> 20 years		
15	Not Solar-Ready	FDNY	Engine Co. 48 and Ladder Co. 56, Division 7	2417 Webster Ave	Bronx	EJZ	17,242 GSF	Between Fair and Poor	15 to 19 years		
15	Solar-Ready	DCLA	Shelter Bldg (Elephant, Rhino, Tiger)	2300 Southern Blvd	Bronx	EJZ	18,100 GSF	Fair	5 to 9 years		
15	Not Solar-Ready	DCLA	Jungle World	2300 Southern Blvd	Bronx	EJZ	18,350 GSF	Good	> 20 years		
15	Not Solar-Ready	NYPL	Grand Concourse Branch Library	155 East 173rd St	Bronx	EJZ	18,874 GSF	Fair	15 to 19 years		
15	Not Solar-Ready	DCLA	Aquatic Bird House	2300 Southern Blvd	Bronx	EJZ	20,110 GSF	Poor	Unknown		
15	Not Solar-Ready	DCLA	Harriet Barnes Pratt Library Wing	2674 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	20,950 GSF	Good	10 to 14 years		
15	Not Solar-Ready	NYPL	Belmont Branch Library	610 East 186th St	Bronx	EJZ	21,267 GSF	Poor	Unknown		
15	Not Solar-Ready	DCLA	Wildlife Health Center	2300 Southern Blvd	Bronx	EJZ	21,320 GSF	Fair	> 20 years		
15	Not Solar-Ready	FDNY	BX Boro Command, District Office and Communications	453 East 176th St	Bronx	EJZ	21,479 GSF	Unknown	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
15	Not Solar-Ready	DCLA	NYBG Maintenance Buildings	2645 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	21,600 GSF	Between Fair and Poor	> 20 years		
15	Not Solar-Ready	DCLA	TOPS	2300 Southern Blvd	Bronx	EJZ	22,000 GSF	Good	15 to 19 years		
15	Not Solar-Ready	NYPD	Transit District 12	460 Morris Park Ave	Bronx	EJZ	24,700 GSF	Between Good and Fair	15 to 19 years		
15	Not Solar-Ready	DOE	X864	2375 SOUTHERN BOULEVARD	Bronx	EJZ	25,260 GSF	Fair	10 to 14 years		
15	Not Solar-Ready	NYPD	46th Precinct	2120 Ryer Ave	Bronx	EJZ	25,434 GSF	Good	15 to 19 years		
15	Not Solar-Ready	DCLA	Pfizer Plant Research Laboratory	2692 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	25,880 GSF	Good	10 to 14 years		
15	Not Solar-Ready	DOE	X209	317 EAST 183 STREET	Bronx	EJZ	26,400 GSF	Fair	> 20 years		
15	Not Solar-Ready	DCLA	Jeannette Kittredge Watson Science and Education Building	2674 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	27,168 GSF	Good	10 to 14 years		
15	Not Solar-Ready	DCLA	Administration West	2300 Southern Blvd	Bronx	EJZ	27,720 GSF	Fair	Unknown		
15	Solar-Ready	DCLA	World of Birds	2300 Southern Blvd	Bronx	EJZ	29,110 GSF	Good	2 to 4 years		
15	Solar-Ready	DCLA	Center for Global Conservation	2300 Southern Blvd	Bronx	EJZ	30,000 GSF	Good	5 to 9 years		
15	Not Solar-Ready	DFTA	East Concourse Senior Center	236 East Tremont Ave	Bronx	EJZ	31,496 GSF	Between Good and Fair	10 to 14 years		
15	Not Solar-Ready	DSNY	Bronx Lot Cleaning	4389 3rd Ave	Bronx	EJZ	34,000 GSF	Poor	> 20 years		
15	Not Solar-Ready	DOT	BX Borough Engineering, BX Sign Shop	4409 Park Ave	Bronx	EJZ	35,735 GSF	Good	15 to 19 years		
15	Not Solar-Ready	DOE	X163	2075 WEBSTER AVENUE	Bronx	EJZ	39,811 GSF	Between Fair and Poor	15 to 19 years		
15	Not Solar-Ready	DCLA	Congo Gorilla Forest	2300 Southern Blvd	Bronx	EJZ	40,000 GSF	Good	15 to 19 years		
15	Solar-Ready	DCLA	Madagascar (Old Lion House)	2300 Southern Blvd	Bronx	EJZ	40,268 GSF	Fair	5 to 9 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
15	Not Solar-Ready	DOT	Fleet Services Maintenance and Repair	2144 Webster Ave	Bronx	EJZ	45,000 GSF	Between Fair and Poor	15 to 19 years		
15	Not Solar-Ready	DCLA	Nolen Glasshouses	2658 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	45,400 GSF	Good	10 to 14 years		
15	Not Solar-Ready	DCLA	Enid A. Haupt Conservatory	2740 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	50,741 GSF	Poor	> 20 years		
15	Not Solar-Ready	DCLA	International Plant Science Center	2680 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	53,740 GSF	Good	15 to 19 years		
15	Not Solar-Ready	DPR	Bronx Parks Headquarters and Shops - Ranaqua	1900 Birchall Ave	Bronx	EJZ	65,000 GSF	Fair	15 to 19 years		
15	Solar-Ready	DOE	X205	2475 SOUTHERN BOULEVARD	Bronx	EJZ	66,080 GSF	Good	5 to 9 years	Yes	
15	Not Solar-Ready	DOE	X234	2050 PROSPECT AVENUE	Bronx	EJZ	73,497 GSF	Between Fair and Poor	15 to 19 years		
15	Not Solar-Ready	NYPL	Bronx Library Center	310 East Kingsbridge Rd	Bronx	EJZ	74,476 GSF	Good	10 to 14 years		
15	Solar-Ready	DOE	X058	459 East 176th Street	Bronx	EJZ	74,480 GSF	Good	5 to 9 years	Yes	
15	Solar-Ready	DOE	X465	4143 3RD AVENUE	Bronx	EJZ	78,910 GSF	Between Good and Fair	5 to 9 years		
15	Not Solar-Ready	DOE	X059	2185 BATHGATE AVENUE	Bronx	EJZ	82,880 GSF	Fair	10 to 14 years		
15	Solar-Ready	DOE	X254	2452 WASHINGTON AVE.	Bronx	EJZ	82,880 GSF	Good	< 2 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
15	Not Solar-Ready	DOE	X023	2151 WASHINGTON AVE.	Bronx	EJZ	90,031 GSF	Fair	> 20 years		
15	Not Solar-Ready	DOE	X046	279 EAST 196 STREET	Bronx	EJZ	90,087 GSF	Between Fair and Poor	> 20 years		
15	Not Solar-Ready	DOE	X054	2703 WEBSTER AVE	Bronx	EJZ	91,200 GSF	Fair	15 to 19 years		
15	Not Solar-Ready	DOE	X057	2111 CROTONA AVENUE	Bronx	EJZ	91,280 GSF	Fair	15 to 19 years		
15	Solar-Ready	DOE	X028	1861 ANTHONY AVENUE	Bronx	EJZ	93,423 GSF	Good	5 to 9 years	Yes	
15	Not Solar-Ready	DOE	X003	2100 LAFONTAINE AVENUE	Bronx	EJZ	96,080 GSF	Fair	> 20 years		
15	Not Solar-Ready	DOE	X032	690 EAST 183 STREET	Bronx	EJZ	97,908 GSF	Fair	10 to 14 years		
15	Not Solar-Ready	DOE	X118	577 EAST 179 STREET	Bronx	EJZ	98,236 GSF	Fair	15 to 19 years		
15	Not Solar-Ready	DOE	X085	2400 MARION AVENUE	Bronx	EJZ	117,624 GSF	Under construction	Under construction		
15	Solar-Ready	DCLA	LuEsther T. Mertz Library	2674 Dr. Theodore Kazimiroff Blvd	Bronx	EJZ	121,200 GSF	Good	5 to 9 years		
15	Not Solar-Ready	DOE	X009	230 East 183rd St	Bronx	EJZ	121,213 GSF	Fair	10 to 14 years		
15	Not Solar-Ready	DOE	X096	650 WARING AVENUE	Bronx	EJZ	122,835 GSF	Fair	15 to 19 years		
15	Not Solar-Ready	DOE	X004	1701 FULTON AVENUE	Bronx	EJZ	127,325 GSF	Poor	15 to 19 years	Yes	
15	Not Solar-Ready	DOE	X045	2502 LORILLARD PLACE	Bronx	EJZ	144,125 GSF	Fair	15 to 19 years		
15	Not Solar-Ready	DOE	X070	1691 WEEKS AVENUE	Bronx	EJZ	161,473 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
15	Not Solar-Ready	DOE	X660	2474 CROTONA AVE.	Bronx	EJZ	166,975 GSF	Fair	> 20 years		
15	Not Solar-Ready	DOE	X137	2225 WEBSTER AVENUE	Bronx	EJZ	237,600 GSF	Under construction	Under construction	Yes	
15	Not Solar-Ready	DOE	X435	500 East Fordham Road	Bronx	EJZ	382,925 GSF	Under construction	Under construction		
16	Not Solar-Ready	DPR	Claremont Park Pool	Clay Ave at East 171st St	Bronx		10,200 GSF	Fair	> 20 years		
16	Not Solar-Ready	FDNY	Engine Co. 68 and Ladder 49	1160 Ogden Ave	Bronx	EJZ	10,220 GSF	Unknown	15 to 19 years		
16	Solar-Ready	NYPL	High Bridge Branch Library	78 West 168th St	Bronx	EJZ	10,400 GSF	Good	< 2 years		
16	Not Solar-Ready	FDNY	Engine Co. 92 and Ladder Co. 44, Batt. 17	1259 Morris Ave	Bronx	EJZ	10,623 GSF	Fair	10 to 14 years		
16	Not Solar-Ready	DPR	West Bronx Recreation Center	1527 Jesup Ave	Bronx	EJZ	12,500 GSF	Fair	15 to 19 years		
16	Not Solar-Ready	FDNY	Engine Co. 50 and Ladder Co. 19, Batt. 26	1155 Washington Ave	Bronx	EJZ	13,500 GSF	Between Fair and Poor	15 to 19 years		
16	Not Solar-Ready	NYPL	Morrisania Branch Library	610 East 169th St	Bronx	EJZ	14,503 GSF	Fair	> 20 years		
16	Solar-Ready	DPR	Mullaly Park Rink and Rec Center	East 164th St at Jerome Ave	Bronx		15,500 GSF	Between Good and Fair	5 to 9 years		Green Roof
16	Not Solar-Ready	NYPD	44th Precinct	1278 Sedgwick Ave	Bronx	EJZ	18,265 GSF	Between Fair and Poor	15 to 19 years		
16	Not Solar-Ready	ACS	Children Pride Early Learning Center	800 Concourse Village East	Bronx	EJZ	20,160 GSF	Poor	> 20 years		
16	Not Solar-Ready	DSNY	Bronx 5 District Garage	1331 Cromwell Ave	Bronx	EJZ	21,126 GSF	Between Fair and Poor	> 20 years		
16	Not Solar-Ready	DSNY	Bronx 03 Section Station 1	1595 Washington Ave	Bronx	EJZ	22,750 GSF	Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
16	Not Solar-Ready	DOE	X088	1340 SHERIDAN AVENUE	Bronx	EJZ	27,660 GSF	Fair	10 to 14 years		
16	Solar-Ready	FDNY	Rescue 3	1655 Washington Ave	Bronx	EJZ	29,250 GSF	Good	< 2 years		
16	Not Solar-Ready	NYPD	44th Precinct	2 East 169th St	Bronx	EJZ	48,200 GSF	Unknown	> 20 years		
16	Not Solar-Ready	DOHMH	Morrisania Health Center	1309 Fulton Ave	Bronx	EJZ	51,434 GSF	Unknown	10 to 14 years		
16	Not Solar-Ready	DOE	X035	261 EAST 163 STREET	Bronx	EJZ	54,175 GSF	Fair	> 20 years		
16	Not Solar-Ready	DOE	X053	360 EAST 168 STREET	Bronx	EJZ	78,002 GSF	Fair	15 to 19 years		
16	Not Solar-Ready	DOE	X042	1537 Washington Ave	Bronx	EJZ	78,175 GSF	Fair	> 20 years		
16	Solar-Ready	DOE	X011	1257 OGDEN AVENUE	Bronx	EJZ	81,680 GSF	Good	2 to 4 years	Yes	
16	Not Solar-Ready	DOE	X114	1155 CROMWELL AVENUE	Bronx		82,925 GSF	Fair	15 to 19 years		
16	Not Solar-Ready	HHC	Morrisania DTC Center	1225 Gerard Ave	Bronx	EJZ	83,031 GSF	Fair	> 20 years		
16	Solar-Ready	DOE	X002	1365 FULTON AVENUE	Bronx	EJZ	91,300 GSF	Good	2 to 4 years		
16	Not Solar-Ready	DOE	X063	1260 FRANKLIN AVE.	Bronx	EJZ	92,100 GSF	Fair	> 20 years	Yes	
16	Not Solar-Ready	DOE	X064	1425 WALTON AVENUE	Bronx	EJZ	93,581 GSF	Fair	10 to 14 years		
16	Not Solar-Ready	DHS	Franklin Women's Shelter	1122 Franklin Ave	Bronx	EJZ	97,000 GSF	Unknown	Unknown		
16	Not Solar-Ready	DOE	X146	968 CAULDWELL AVENUE	Bronx	EJZ	98,525 GSF	Fair	15 to 19 years		
16	Not Solar-Ready	DCAS	Bronx Housing Court	1118 Grand Concourse	Bronx	EJZ	99,000 GSF	Poor	Unknown		
16	Solar-Ready	DOE	X126	175 WEST 166 STREET	Bronx	EJZ	105,700 GSF	Good	5 to 9 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
16	Not Solar-Ready	DOE	X090	1116 SHERIDAN AVENUE	Bronx	EJZ	112,090 GSF	Under construction	Under construction		
16	Not Solar-Ready	DOE	X110	580 CROTONA PARK SOUTH	Bronx	EJZ	112,925 GSF	Fair	10 to 14 years		
16	Not Solar-Ready	DOE	X132	1245 WASHINGTON AVENUE	Bronx	EJZ	117,725 GSF	Fair	> 20 years		
16	Not Solar-Ready	DOE	X104	1449 SHAKESPEARE AVENUE	Bronx	EJZ	124,900 GSF	Fair	> 20 years		
16	Not Solar-Ready	DOE	X235	1220 GERARD AVE.	Bronx	EJZ	125,583 GSF	Fair	15 to 19 years		
16	Not Solar-Ready	DOE	X460	244 EAST 163RD STREET	Bronx	EJZ	135,600 GSF	Fair	10 to 14 years		
16	Not Solar-Ready	DOE	X120	890 CAULDWELL AVENUE	Bronx	EJZ	138,175 GSF	Fair	10 to 14 years		
16	Not Solar-Ready	DOE	X055	450 SAINT PAUL'S PLACE	Bronx	EJZ	147,725 GSF	Under construction	Under construction		
16	Not Solar-Ready	DOE	X970	1595 BATHGATE AVENUE	Bronx	EJZ	154,000 GSF	Fair	10 to 14 years		
16	Not Solar-Ready	DOE	X022	270 East 167th St	Bronx	EJZ	158,575 GSF	Fair	> 20 years		
16	Not Solar-Ready	DHS	Webster Avenue SRO	1075 Webster Ave	Bronx	EJZ	174,600 GSF	Good	Unknown		
16	Solar-Ready	DOE	X136	750 JENNINGS STREET	Bronx	EJZ	178,975 GSF	Good	< 2 years	Yes	
16	Not Solar-Ready	DOE	X229	275 HARLEM RIVER PARK BRIDGE	Bronx	EJZ	186,000 GSF	Fair	10 to 14 years	Yes	
16	Not Solar-Ready	DOE	X145	1000 TELLER AVENUE	Bronx	EJZ	186,175 GSF	Between Fair and Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
16	Solar-Ready	DOE	X148	3630 THIRD AVENUE	Bronx	EJZ	188,575 GSF	Good	5 to 9 years	Yes	
16	Not Solar-Ready	DOE	X400	1110 Boston Road	Bronx	EJZ	199,036 GSF	Fair	15 to 19 years		
16	Solar-Ready	DOE	X147	1600 WEBSTER AVENUE	Bronx	EJZ	199,200 GSF	Between Good and Fair	5 to 9 years	Yes	
16	Not Solar-Ready	DOE	X158	800 HOME STREET	Bronx	EJZ	224,575 GSF	Fair	10 to 14 years		
16	Not Solar-Ready	DCAS	Bronx Concourse Plaza	198 East 161st	Bronx	EJZ	231,190 GSF	Good	> 20 years		
16	Not Solar-Ready	DOE	X410	240 E. 172ND STREET	Bronx	EJZ	336,731 GSF	Fair	10 to 14 years		
16	Not Solar-Ready	DCAS	Bronx Family and Criminal Court	215 East 161st St	Bronx	EJZ	388,800 GSF	Poor	Unknown		
17	Not Solar-Ready	DOE	X817	1680 HOE AVENUE	Bronx	EJZ	10,860 GSF	Between Good and Fair	10 to 14 years		
17	Not Solar-Ready	CUNY	Hostos CC Administration Building - G	135 East 146th St	Bronx	EJZ	13,178 GSF	Poor	Unknown		
17	Not Solar-Ready	NYPL	Hunt's Point Branch Library	877 Southern Blvd	Bronx	EJZ	13,715 GSF	Fair	Unknown		
17	Not Solar-Ready	DEP	SLUDGE DEWATERING BUILDING	Hunts Point WPCP	Bronx	EJZ	14,280 GSF	Between Fair and Poor	> 20 years		
17	Not Solar-Ready	FDNY	Engine Co. 71 and Ladder Co. 55, Division 6	720 Melrose Ave	Bronx	EJZ	14,416 GSF	Unknown	15 to 19 years		
17	Not Solar-Ready	NYPL	Melrose Library	910 Morris Avenue	Bronx	EJZ	14,890 GSF	Poor	15 to 19 years		
17	Not Solar-Ready	FDNY	Engine Co. 73 and Ladder Co. 42	665 Prospect Ave	Bronx	EJZ	15,170 GSF	Poor	> 20 years		
17	Not Solar-Ready	FDNY	Engine Co. 45 and Ladder Co. 58, Batt. 18	925 East Tremont Ave	Bronx	EJZ	15,225 GSF	Between Fair and Poor	> 20 years		
17	Not Solar-Ready	NYPL	West Farms Branch Library	2085 Honeywell Ave	Bronx	EJZ	15,591 GSF	Poor	Unknown		
17	Not Solar-Ready	DSNY	Bronx 3A Broom Depot	1661 West Farms Rd	Bronx	EJZ	15,600 GSF	Between Fair and Poor	> 20 years		
17	Not Solar-Ready	NYPL	Woodstock Branch Library	761 East 160th St	Bronx	EJZ	16,524 GSF	Fair	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
17	Not Solar-Ready	HRA	New Day Family Residence I	1138 Longfellow Ave	Bronx	EJZ	17,200 GSF	Between Good and Fair	Unknown		
17	Not Solar-Ready	ACS	La Peninsula Head Start Program	1054 Intervale Ave	Bronx	EJZ	20,000 GSF	Between Good and Fair	15 to 19 years		
17	Solar-Ready	DHS	Freeman Houses Residence	999 Freeman St	Bronx	EJZ	21,633 GSF	Good	5 to 9 years		
17	Not Solar-Ready	DPR	Hunt's Point Recreation Center	765 Manida St	Bronx	EJZ	22,340 GSF	Fair	> 20 years		
17	Not Solar-Ready	NYPD	Detective Borough Command (Old 41st Precinct)	1086 Simpson St	Bronx	EJZ	22,962 GSF	Between Fair and Poor	15 to 19 years		
17	Not Solar-Ready	DCLA	Charles B. Harding Laboratory Building	1 Southern Blvd	Bronx	EJZ	23,500 GSF	Fair	15 to 19 years		
17	Solar-Ready	DPR	Crotona Park Pool and Bathhouse	East 173rd St at Fulton Ave	Bronx		25,000 GSF	Between Good and Fair	5 to 9 years		Green Roof
17	Not Solar-Ready	NYPD	42nd Precinct	830 Washington Ave	Bronx	EJZ	25,465 GSF	Unknown	15 to 19 years		
17	Not Solar-Ready	DEP	Main Building	Hunts Point WPCP	Bronx	EJZ	28,137 GSF	Between Fair and Poor	> 20 years		
17	Not Solar-Ready	DEP	Dewatering Building	Hunts Point WPCP	Bronx	EJZ	29,722 GSF	Between Fair and Poor	> 20 years		
17	Solar-Ready	DSNY	Section Station 92, Bronx Enforcement	1787 West Farms Rd	Bronx	EJZ	32,700 GSF	Good	2 to 4 years		
17	Not Solar-Ready	DHS	Willow Avenue Men's Shelter	780 East 136th St	Bronx	EJZ	36,000 GSF	Unknown	Unknown		
17	Not Solar-Ready	HRA	New Day Family Residence II	1275 Westchester Ave	Bronx	EJZ	37,060 GSF	Fair	Unknown		
17	Not Solar-Ready	DOHMH	Tremont Health Center	1826 Arthur Ave	Bronx	EJZ	41,894 GSF	Between Fair and Poor	10 to 14 years		
17	Not Solar-Ready	NYPD	41st Precinct	1035 Longwood Ave	Bronx	EJZ	42,567 GSF	Poor	Unknown		
17	Not Solar-Ready	CUNY	Hostos CC Savoy Building D	120 East 149th St	Bronx	EJZ	44,976 GSF	Poor	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
17	Not Solar-Ready	DHS	Seneca Houses Residence	1215 Seneca Ave	Bronx	EJZ	64,315 GSF	Poor	> 20 years		
17	Not Solar-Ready	DOE	X973	1716 SOUTHERN BLVD.	Bronx	EJZ	70,230 GSF	Fair	10 to 14 years		
17	Not Solar-Ready	DOE	X044	1825 PROSPECT AVENUE	Bronx	EJZ	72,080 GSF	Under construction	Under construction		
17	Not Solar-Ready	DPR	Citywide Services and Storehouse	850 East 138th St	Bronx	EJZ	74,080 GSF	Fair	> 20 years		
17	Solar-Ready	DOE	X130	750 PROSPECT AVENUE	Bronx	EJZ	81,680 GSF	Good	2 to 4 years		
17	Not Solar-Ready	DSNY	Bronx 6, 6A District Garage	800 East 176th St	Bronx	EJZ	85,715 GSF	Poor	> 20 years	Yes	
17	Solar-Ready	DOE	X050	1550 VYSE AVENUE	Bronx	EJZ	88,900 GSF	Between Good and Fair	5 to 9 years		
17	Not Solar-Ready	DOE	X093	1535 STORY AVENUE	Bronx	EJZ	91,663 GSF	Under construction	Under construction		
17	Not Solar-Ready	DOE	X972	1440 STORY AVENUE	Bronx	EJZ	92,100 GSF	Fair	10 to 14 years		
17	Solar-Ready	DOE	X099	1180 REVEREND JAMES A POLITE AVE	Bronx	EJZ	92,400 GSF	Fair	5 to 9 years	Yes	
17	Not Solar-Ready	DOE	X061	1550 CROTONA PARK EAST	Bronx	EJZ	92,500 GSF	Between Fair and Poor	15 to 19 years		
17	Not Solar-Ready	DOE	X157	757 CAULDWELL AVENUE	Bronx	EJZ	98,400 GSF	Under construction	Under construction		
17	Solar-Ready	DOE	X392	928 SIMPSON STREET	Bronx	EJZ	99,121 GSF	Good	5 to 9 years		
17	Not Solar-Ready	DOE	X006	1000 EAST TREMONT AVENUE	Bronx	EJZ	99,828 GSF	Fair	> 20 years		
17	Solar-Ready	DOE	X140	916 EAGLE AVENUE	Bronx	EJZ	101,346 GSF	Fair	5 to 9 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
17	Not Solar-Ready	DOE	X048	1290 SPOFFORD AVENUE	Bronx	EJZ	102,060 GSF	Fair	15 to 19 years		
17	Solar-Ready	DOE	X039	965 LONGWOOD AVENUE	Bronx	EJZ	102,100 GSF	Good	5 to 9 years	Yes	
17	Not Solar-Ready	DOE	X029	758 COURTLANDT AVENUE	Bronx	EJZ	108,080 GSF	Under construction	Under construction		
17	Not Solar-Ready	DOE	X152	1007 EVERGREEN AVENUE	Bronx	EJZ	109,200 GSF	Fair	15 to 19 years		
17	Not Solar-Ready	DOE	X359	750 CONCOURSE VILLAGE WEST	Bronx		114,000 GSF	Fair	> 20 years		
17	Not Solar-Ready	DOE	X150	920 EAST 167 STREET	Bronx	EJZ	114,175 GSF	Between Good and Fair	> 20 years		
17	Not Solar-Ready	DOE	X001	335 EAST 152 STREET	Bronx	EJZ	115,375 GSF	Fair	> 20 years		
17	Not Solar-Ready	DOE	X470	701 ST. ANN'S AVE.	Bronx	EJZ	119,810 GSF	Between Fair and Poor	15 to 19 years		
17	Not Solar-Ready	DOE	X198	1180 TINTON AVENUE	Bronx	EJZ	122,400 GSF	Poor	> 20 years		
17	Not Solar-Ready	DCAS	Bronx Bergen Building	1932 Arthur Ave	Bronx	EJZ	123,802 GSF	Fair	> 20 years		
17	Solar-Ready	CUNY	Hostos CC B Building	500 Grand Concourse	Bronx	EJZ	124,892 GSF	Good	5 to 9 years		
17	Not Solar-Ready	DOE	X067	2024 MOHEGAN AVENUE	Bronx	EJZ	128,568 GSF	Fair	15 to 19 years		
17	Not Solar-Ready	DOE	X075	984 FAILE STREET	Bronx	EJZ	130,925 GSF	Good	10 to 14 years	Yes	
17	Solar-Ready	DOE	X066	1001 JENNINGS STREET	Bronx	EJZ	130,925 GSF	Fair	5 to 9 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
17	Solar-Ready	DOE	X060	888 REVEREND JAMES A. POLITE AVE	Bronx	EJZ	135,700 GSF	Good	5 to 9 years	Yes	
17	Not Solar-Ready	DOE	X650	900 TINTON AVENUE	Bronx	EJZ	154,951 GSF	Fair	> 20 years		
17	Solar-Ready	DOE	X074	730 BRYANT AVENUE	Bronx	EJZ	166,975 GSF	Between Good and Fair	5 to 9 years		
17	Solar-Ready	DOE	X098	1619 BOSTON ROAD	Bronx	EJZ	171,725 GSF	Good	2 to 4 years	Yes	
17	Not Solar-Ready	DOE	X401	1010 REV. J.A. POLITE AVE.	Bronx	EJZ	194,575 GSF	Fair	15 to 19 years		
17	Not Solar-Ready	DOE	X151	250 EAST 156 STREET	Bronx	EJZ	205,200 GSF	Fair	15 to 19 years		
17	Not Solar-Ready	DOE	X167	1970 WEST FARMS ROAD	Bronx	EJZ	207,600 GSF	Fair	10 to 14 years	Yes	
17	Not Solar-Ready	DOE	X116	977 FOX STREET	Bronx	EJZ	208,975 GSF	Fair	15 to 19 years		
17	Not Solar-Ready	DOE	X193	1919 PROSPECT AVENUE	Bronx	EJZ	210,175 GSF	Fair	15 to 19 years		
17	Not Solar-Ready	ACS	Horizon Juvenile Center	560 Brook Ave	Bronx	EJZ	210,444 GSF	Between Good and Fair	> 20 years		
17	Not Solar-Ready	DOE	X084	1434 LONGFELLOW AVENUE	Bronx	EJZ	211,200 GSF	Under construction	Under construction		
17	Not Solar-Ready	DOE	X162	600 SAINT ANN'S AVENUE	Bronx	EJZ	211,375 GSF	Fair	15 to 19 years		
17	Solar-Ready	DOE	X790	730 CONCOURSE VILLAGE WEST	Bronx		279,045 GSF	Fair	5 to 9 years		
17	Not Solar-Ready	DOE	X600	333 E. 151ST STREET	Bronx	EJZ	282,668 GSF	Fair	10 to 14 years		
17	Solar-Ready	DEP	1270 Ryawa Ave	Hunts Point WPCP	Bronx	EJZ	422,396 GSF	Good	< 2 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
17	Not Solar-Ready	HHC	Lincoln Medical and Mental Health Center	234 East 149th St	Bronx	EJZ	1,628,485 GSF	Between Fair and Poor	> 20 years		
18	Solar-Ready	NYPL	Soundview Branch Library	660 Soundview Ave	Bronx	EJZ	10,350 GSF	Good	< 2 years		
18	Not Solar-Ready	DOE	X982	1250 WARD AVENUE	Bronx	EJZ	11,016 GSF	Between Fair and Poor	15 to 19 years		
18	Solar-Ready	FDNY	EMS 3	501 Zerega Ave	Bronx		11,333 GSF	Good	2 to 4 years		
18	Not Solar-Ready	NYPL	Parkchester Branch Library	1985 Westchester Ave	Bronx	EJZ	14,744 GSF	Poor	Unknown		
18	Not Solar-Ready	NYPD	43rd Precinct	900 Fteley Ave	Bronx	EJZ	29,179 GSF	Unknown	15 to 19 years		
18	Not Solar-Ready	DSNY	Bronx 11 Sanitation Garage	850 Zerega Ave	Bronx		38,632 GSF	Good	> 20 years		
18	Not Solar-Ready	DOE	X069	560 THIERIOT AVENUE	Bronx	EJZ	42,000 GSF	Between Good and Fair	10 to 14 years		
18	Solar-Ready	DHS	Commonwealth Avenue SRO Residence	1150 Commonwealth Ave	Bronx	EJZ	60,000 GSF	Between Good and Fair	5 to 9 years		
18	Not Solar-Ready	DOE	X119	1075 PUGSLEY AVENUE	Bronx	EJZ	64,628 GSF	Fair	15 to 19 years		
18	Not Solar-Ready	DOE	X138	2060 LAFAYETTE AVENUE	Bronx	EJZ	85,253 GSF	Fair	> 20 years		
18	Solar-Ready	DOE	X036	1070 CASTLE HILL AVENUE	Bronx	EJZ	85,260 GSF	Good	< 2 years		
18	Not Solar-Ready	DOE	X107	1695 SEWARD AVENUE	Bronx	EJZ	88,925 GSF	Fair	15 to 19 years		
18	Solar-Ready	DOE	X100	800 TAYLOR AVENUE	Bronx	EJZ	97,280 GSF	Good	2 to 4 years	Yes	

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
18	Solar-Ready	DOE	X047	1794 EAST 172 STREET	Bronx	EJZ	100,925 GSF	Good	2 to 4 years		
18	Not Solar-Ready	DOE	X182	601 STICKBALL BLVD.	Bronx	EJZ	102,000 GSF	Between Good and Fair	10 to 14 years	Yes	
18	Not Solar-Ready	DOE	X077	1250 WARD AVENUE	Bronx	EJZ	109,854 GSF	Under construction	Under construction		
18	Not Solar-Ready	DSNY	Bronx 9/10 Sanitation Garage	850 Zerega Ave	Bronx		115,900 GSF	Poor	> 20 years		
18	Solar-Ready	DOE	X102	1827 ARCHER STREET	Bronx	EJZ	116,236 GSF	Good	2 to 4 years		
18	Not Solar-Ready	DOE	X423	1300 BOYNTON AVE.	Bronx	EJZ	133,344 GSF	Under construction	Under construction	Yes	
18	Not Solar-Ready	DOE	X106	2120 ST. RAYMOND AVENUE	Bronx	EJZ	133,512 GSF	Fair	10 to 14 years		
18	Not Solar-Ready	DOE	X127	1560 PURDY STREET	Bronx	EJZ	153,725 GSF	Fair	15 to 19 years		
18	Not Solar-Ready	DOE	X123	1025 MORRISON AVENUE	Bronx	EJZ	157,200 GSF	Fair	15 to 19 years		
18	Not Solar-Ready	DOE	X194	1301 ZEREGA AVENUE	Bronx	EJZ	176,400 GSF	Fair	15 to 19 years		
18	Not Solar-Ready	DOE	X174	456 WHITE PLAINS ROAD	Bronx	EJZ	202,880 GSF	Between Fair and Poor	> 20 years		
18	Solar-Ready	DOE	X450	1980 LAFAYETTE AVE.	Bronx	EJZ	441,898 GSF	Good	2 to 4 years	Yes	
19	Solar-Ready	QPL	Bayside Community Library	214-20 Northern Blvd	Queens		10,300 GSF	Good	5 to 9 years		
19	Not Solar-Ready	FDNY	Building 400	400 Murray Ave	Queens		10,935 GSF	Unknown	Unknown		
19	Not Solar-Ready	FDNY	Building 418	418 Weaver Ave	Queens		10,935 GSF	Unknown	Unknown		
19	Not Solar-Ready	FDNY	Building 420	420 Weaver Ave	Queens		10,935 GSF	Unknown	Unknown		
19	Not Solar-Ready	FDNY	Building 402	402 Murray Ave	Queens		12,041 GSF	Unknown	Unknown		
19	Not Solar-Ready	FDNY	Building 326	326 Story Ave	Queens		12,108 GSF	Unknown	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
19	Not Solar-Ready	FDNY	Building 401	401 Murray Ave	Queens		12,401 GSF	Unknown	Unknown		
19	Not Solar-Ready	FDNY	Building 107	107 Duane Rd	Queens		12,404 GSF	Poor	> 20 years		
19	Not Solar-Ready	FDNY	Building 318	318 Murray Ave	Queens		12,966 GSF	Unknown	Unknown		
19	Not Solar-Ready	DEP	Collection Facility North Quarters	Tallman Island WPCP	Queens	EJZ	13,560 GSF	Poor	> 20 years		
19	Not Solar-Ready	FDNY	Building 409	409 Shore Rd	Queens		13,728 GSF	Unknown	Unknown		
19	Not Solar-Ready	FDNY	Building 411	411 Shore Rd	Queens		13,728 GSF	Unknown	Unknown		
19	Solar-Ready	FDNY	Building 413	413 Shore Rd	Queens		13,728 GSF	Good	< 2 years		
19	Not Solar-Ready	FDNY	Building 333	333 Pratt Ave	Queens		17,602 GSF	Unknown	Unknown		
19	Not Solar-Ready	NYPD	Harbor Unit Launch	14th Ave at Powells Cove Blvd	Queens	EJZ	18,300 GSF	Between Good and Fair	Unknown		
19	Not Solar-Ready	DEP	Screen Building	Tallman Island WPCP	Queens	EJZ	19,377 GSF	Poor	> 20 years		
19	Not Solar-Ready	FDNY	Building 405	405 Whistler Ave	Queens		22,392 GSF	Unknown	Unknown		
19	Not Solar-Ready	FDNY	Building 336	336 Shore Rd	Queens		23,732 GSF	Unknown	Unknown		
19	Not Solar-Ready	NYPD	111th Precinct	45-06 215th St	Queens		23,793 GSF	Good	10 to 14 years		
19	Not Solar-Ready	FDNY	Building 304	304 Shore Rd	Queens		28,831 GSF	Unknown	Unknown		
19	Not Solar-Ready	DEP	Dewatering Facility	Tallman Island WPCP	Queens	EJZ	29,722 GSF	Poor	> 20 years		
19	Not Solar-Ready	FDNY	Building 322	322 Story Ave	Queens		30,260 GSF	Unknown	Unknown		
19	Not Solar-Ready	FDNY	Building 325	325 Pratt Ave	Queens		31,892 GSF	Unknown	Unknown		
19	Not Solar-Ready	FDNY	Building 323	323 Story Ave	Queens		31,902 GSF	Unknown	Unknown		
19	Not Solar-Ready	DOE	Q098	40-20 235 STREET	Queens	EJZ	44,460 GSF	Fair	> 20 years		
19	Solar-Ready	DOE	Q094	41-77 LITTLE NECK PKWY	Queens		45,600 GSF	Good	2 to 4 years		
19	Not Solar-Ready	DOE	Q029	125-10 23 AVENUE	Queens		49,171 GSF	Fair	10 to 14 years		
19	Not Solar-Ready	DSNY	Queens 7A District Garage Annex	30-19 122nd St	Queens		49,921 GSF	Good	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
19	Not Solar-Ready	DEP	Pump & Blower Building	Tallman Island WPCP	Queens	EJZ	51,652 GSF	Poor	> 20 years		
19	Not Solar-Ready	NYPD	Narcotics and Warrant Squad	13-10 111th St	Queens	EJZ	56,944 GSF	Between Good and Fair	10 to 14 years		
19	Not Solar-Ready	DOE	Q041	214-43 35 AVENUE	Queens		67,307 GSF	Between Fair and Poor	15 to 19 years		
19	Solar-Ready	DOE	Q184	163-15 21 ROAD	Queens		68,400 GSF	Between Good and Fair	5 to 9 years	Yes	
19	Not Solar-Ready	DOE	Q031	211-45 46 ROAD	Queens	EJZ	68,460 GSF	Under construction	Under construction		
19	Not Solar-Ready	DOE	Q159	205-01 33 AVENUE	Queens		75,700 GSF	Fair	> 20 years		
19	Solar-Ready	DOE	Q130	200-01 42 AVENUE	Queens		76,800 GSF	Good	2 to 4 years		
19	Not Solar-Ready	DOE	Q193	152-20 11 AVENUE	Queens		79,111 GSF	Fair	15 to 19 years		
19	Not Solar-Ready	DOE	Q032	171-11 35 AVENUE	Queens		85,023 GSF	Between Fair and Poor	15 to 19 years		
19	Not Solar-Ready	DOE	Q209	16-10 UTOPIA PKWY	Queens		91,325 GSF	Fair	10 to 14 years		
19	Not Solar-Ready	DOE	Q169	18-25 212 STREET	Queens		92,575 GSF	Between Good and Fair	> 20 years		
19	Solar-Ready	DSNY	North Shore Marine Transfer Station	119-01 31st Ave	Queens		110,088 GSF	Good	5 to 9 years	Yes	
19	Not Solar-Ready	DOE	Q129	128-02 7TH AVENUE	Queens		115,842 GSF	Fair	> 20 years		
19	Not Solar-Ready	DOE	Q079	15-28 149 STREET	Queens		119,268 GSF	Fair	15 to 19 years		
19	Not Solar-Ready	DOE	Q107	167-02 45 AVENUE	Queens	EJZ	132,060 GSF	Fair	10 to 14 years		
19	Not Solar-Ready	DSNY	Queens 7 Garage and Boro Office	120-15 31st Ave	Queens		134,564 GSF	Good	> 20 years	Yes	
19	Solar-Ready	DOE	Q185	147-26 25 DRIVE	Queens	EJZ	152,525 GSF	Fair	2 to 4 years	Yes	
19	Not Solar-Ready	DOE	Q194	154-60 17 AVENUE	Queens		153,725 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
19	Not Solar-Ready	DOE	Q158	46-35 OCEANIA STREET	Queens	EJZ	164,525 GSF	Between Good and Fair	15 to 19 years		
19	Solar-Ready	NYPD	Police Academy	130-30 28th Ave	Queens		250,577 GSF	Good	< 2 years		
19	Not Solar-Ready	FDNY	Fort Totten	422 Weaver Ave	Queens		434,139 GSF	Unknown	10 to 14 years		
19	Solar-Ready	NYPD	620 Circle Drive	620 Circle Drive	Queens		5,926,250 GSF	Good	5 to 9 years		
20	Not Solar-Ready	DOT	DOT Asphalt Plant	30-01 Harper St	Queens		14,300 GSF	Between Fair and Poor	Unknown		
20	Not Solar-Ready	DCLA	Flushing Town Hall	137-35 Northern Blvd	Queens	EJZ	18,000 GSF	Good	> 20 years		
20	Not Solar-Ready	DCLA	Greenhouse / Maintenance Building	43-50 Main St	Queens	EJZ	21,226 GSF	Good	10 to 14 years		
20	Not Solar-Ready	DOE	Q023	138-11 35 AVENUE	Queens	EJZ	25,260 GSF	Fair	> 20 years		
20	Solar-Ready	NYPD	Flushing Armory (Queens North Task Force)	137-58 Northern Blvd	Queens	EJZ	35,734 GSF	Good	5 to 9 years		
20	Solar-Ready	DPR	Al Oerter Recreation Center	131-40 Fowler Ave	Queens		39,000 GSF	Fair	5 to 9 years		
20	Solar-Ready	DOE	Q244	137-20 FRANKLIN AVE.	Queens	EJZ	42,000 GSF	Between Good and Fair	5 to 9 years		
20	Not Solar-Ready	NYPD	109th Precinct	37-05 Union St	Queens	EJZ	48,700 GSF	Unknown	10 to 14 years		
20	Not Solar-Ready	DOE	Q242	136-11 31ST ROAD	Queens	EJZ	59,592 GSF	Fair	15 to 19 years		
20	Not Solar-Ready	DOE	Q177	56-37 188 STREET	Queens	EJZ	60,320 GSF	Fair	15 to 19 years		
20	Not Solar-Ready	DOE	Q163	159-01 59 AVENUE	Queens	EJZ	67,979 GSF	Fair	10 to 14 years		
20	Not Solar-Ready	DOE	Q214	31-15 140 STREET	Queens	EJZ	72,080 GSF	Under construction	Under construction		
20	Solar-Ready	DOE	Q162	201-02 53 AVENUE	Queens	EJZ	73,200 GSF	Good	< 2 years		
20	Not Solar-Ready	QPL	Flushing (ALC) Community Library	41-17 Main St	Queens	EJZ	76,000 GSF	Between Fair and Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
20	Not Solar-Ready	DOE	Q022	153-33 SANFORD AVENUE	Queens	EJZ	76,643 GSF	Between Good and Fair	10 to 14 years		
20	Not Solar-Ready	DOE	Q024	141-11 HOLLY AVENUE	Queens	EJZ	77,620 GSF	Fair	15 to 19 years		
20	Not Solar-Ready	DOE	Q120	58-01 136th St	Queens	EJZ	111,725 GSF	Fair	> 20 years		
20	Solar-Ready	DOE	Q020	142-30 BARCLAY AVENUE	Queens	EJZ	156,175 GSF	Between Good and Fair	5 to 9 years		
20	Not Solar-Ready	DOE	Q189	144-80 BARCLAY AVENUE	Queens	EJZ	168,125 GSF	Fair	> 20 years		
20	Not Solar-Ready	DOE	Q460	35-01 UNION STREET	Queens	EJZ	276,250 GSF	Fair	> 20 years	Yes	
20	Not Solar-Ready	DOE	Q859	30-48 LINDEN PLACE	Queens	EJZ	291,811 GSF	Fair	Unknown		
20	Not Solar-Ready	DOE	Q430	58-20 UTOPIA PKWY	Queens	EJZ	358,437 GSF	Fair	15 to 19 years	Yes	
21	Not Solar-Ready	DPR	Worlds Fair Marina	Flushing Bay Promenade	Queens		10,500 GSF	Fair	> 20 years		
21	Solar-Ready	QPL	East Elmhurst Community Library	95-06 Astoria Blvd	Queens	EJZ	11,860 GSF	Fair	5 to 9 years		
21	Not Solar-Ready	NYPD	110th Precinct	94-41 43rd Ave	Queens	EJZ	15,300 GSF	Between Fair and Poor	10 to 14 years		
21	Not Solar-Ready	DPR	Allied Building II	13 East Rd	Queens		16,808 GSF	Fair	15 to 19 years		
21	Solar-Ready	DPR	Olmsted Center Campus: FMCP Garage	12 Olmsted Dr	Queens		18,569 GSF	Fair	5 to 9 years		
21	Not Solar-Ready	DPR	Allied Building I	15 East Rd	Queens		19,836 GSF	Fair	15 to 19 years		
21	Not Solar-Ready	QPL	Langston Hughes Community Library	100-01 Northern Blvd	Queens	EJZ	23,000 GSF	Good	10 to 14 years		
21	Not Solar-Ready	DPR	Louis Armstrong Recreation Center	33-16 108th St	Queens		25,650 GSF	Fair	> 20 years		
21	Not Solar-Ready	DOHMH	Corona Health Center	34-33 Junction Blvd	Queens	EJZ	28,600 GSF	Unknown	10 to 14 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
21	Not Solar-Ready	DOE	Q028	109-10 47TH AVENUE	Queens	EJZ	51,795 GSF	Fair	15 to 19 years		
21	Not Solar-Ready	DOE	Q228	32-65 93RD STREET	Queens	EJZ	53,855 GSF	Between Fair and Poor	15 to 19 years		
21	Solar-Ready	DPR	Olmsted Center	Flushing Meadows-Corona Park	Queens		61,000 GSF	Fair	5 to 9 years		Green Roof
21	Solar-Ready	DOE	Q292	99-01 34th Ave	Queens	EJZ	95,149 GSF	Between Good and Fair	5 to 9 years		
21	Not Solar-Ready	DOT	North Fleet Depot (Harper St. Yard Facility)	32-11 Harper St	Queens		95,761 GSF	Unknown	Unknown		
21	Solar-Ready	DPR	FMCP Aquatic Center	131-00 Avery Ave	Queens		110,000 GSF	Fair	5 to 9 years		
21	Not Solar-Ready	DOE	Q127	98-01 25th Ave	Queens	EJZ	111,725 GSF	Fair	10 to 14 years		
21	Not Solar-Ready	DOE	Q143	34-74 113 STREET	Queens	EJZ	112,719 GSF	Fair	15 to 19 years		
21	Solar-Ready	DOE	Q019	98-02 ROOSEVELT AVE.	Queens	EJZ	116,866 GSF	Good	2 to 4 years	Yes	
21	Solar-Ready	DOE	Q014	107-01 OTIS AVENUE	Queens	EJZ	142,925 GSF	Good	< 2 years		
21	Not Solar-Ready	DOE	Q016	41-15 104 STREET	Queens	EJZ	147,600 GSF	Fair	10 to 14 years		
21	Solar-Ready	DOE	Q227	32-02 JUNCTION BLVD	Queens	EJZ	170,900 GSF	Between Good and Fair	5 to 9 years	Yes	
21	Not Solar-Ready	DOE	Q061	98-50 50 AVENUE	Queens	EJZ	237,892 GSF	Under construction	Under construction	Yes	
22	Not Solar-Ready	DOC	Hart Island Module / S1	Rikers Island	Bronx		10,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Module 1	Rikers Island	Bronx		10,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Modules DD/(6)	Rikers Island	Bronx		10,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Pantry Buildings 1&2	Rikers Island	Bronx		10,000 GSF	Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
22	Not Solar-Ready	DOC	Pantry Buildings 3&4	Rikers Island	Bronx		10,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Pantry Buildings 5	Rikers Island	Bronx		10,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Sprung 1 (HIIP)	Rikers Island	Bronx		10,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	QPL	Steinway (ALC) Community Library	21-45 31st St	Queens		11,200 GSF	Good	15 to 19 years		
22	Not Solar-Ready	DEP	Main Building Electrical Wing	4301 Berrian Blvd	Queens		11,205 GSF	Unknown	Unknown		
22	Not Solar-Ready	DEP	New Boiler Wing	4301 Berrian Blvd	Queens		12,742 GSF	Unknown	Unknown		
22	Not Solar-Ready	DOC	Locker Room	Rikers Island	Bronx		15,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Rikers Island Telecom / SOD / COD	Rikers Island	Bronx		16,000 GSF	Fair	15 to 19 years		
22	Not Solar-Ready	DOC	Rikers Island Laundry Facility	Rikers Island	Bronx		19,350 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Buildings 3&4	Rikers Island	Bronx		20,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Modules OO & PP/ (11&12)	Rikers Island	Bronx		20,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Modules WW & XX/ (7&8)	Rikers Island	Bronx		20,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DPR	Astoria Park Pool House	19-00 23rd Ter	Queens		25,800 GSF	Fair	> 20 years		
22	Not Solar-Ready	DOHMH	Astoria Health Center	12-26 31st Ave	Queens		28,372 GSF	Unknown	10 to 14 years		
22	Solar-Ready	DOC	Rikers Island New Central Warehouse	15-15 Hazen Street	Bronx		28,838 GSF	Good	5 to 9 years		
22	Not Solar-Ready	DOC	200 Bed Modules	Rikers Island	Bronx		30,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Rikers Island Division 1 Storehouse	Rikers Island	Bronx		30,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	West Sprungs	Rikers Island	Bronx		30,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Sprungs, MOD 3	Rikers Island	Bronx		30,400 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Rikers Island Bakery	Rikers Island	Bronx		30,750 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Dorms 17-20	Rikers Island	Bronx		32,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	East Sprungs & WS	Rikers Island	Bronx		33,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Rikers Island Powerhouse	Rikers Island	Bronx		36,450 GSF	Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
22	Not Solar-Ready	DOE	Q739	23-15 NEWTOWN AVENUE	Queens		37,400 GSF	Between Good and Fair	10 to 14 years		
22	Not Solar-Ready	DEP	SLUDGE DEWATERING BUILDING	4301 Berrian Blvd	Queens		52,813 GSF	Unknown	Unknown		
22	Not Solar-Ready	DOE	Q084	22-45 41 STREET	Queens		58,880 GSF	Fair	> 20 years		
22	Not Solar-Ready	DOC	North Infirmary Command (NIC)	Rikers Island	Bronx		66,800 GSF	Fair	15 to 19 years		
22	Not Solar-Ready	DOE	Q085	23-70 31 STREET	Queens		69,918 GSF	Fair	15 to 19 years		
22	Not Solar-Ready	DOC	MODS 14,15,16,LL,N,QQ,RR	Rikers Island	Bronx		70,980 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	Rikers Island Transportation Garage (ASRS)	Rikers Island	Bronx		73,895 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOE	Q002	75-10 21 AVENUE	Queens		74,480 GSF	Fair	10 to 14 years		
22	Solar-Ready	DOE	Q151	50-05 31 AVENUE	Queens		78,290 GSF	Good	< 2 years		
22	Not Solar-Ready	DEP	Service Building	4301 Berrian Blvd	Queens		85,556 GSF	Unknown	Unknown		
22	Not Solar-Ready	DOC	GMDC MODS 4,5,8,9,10,11,12,13	Rikers Island	Bronx		92,000 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOC	WF Detention Facility	Rikers Island	Bronx		94,914 GSF	Poor	> 20 years		
22	Not Solar-Ready	DEP	Main Building + Low Level Screens + High Level Screens	4301 Berrian Blvd	Queens		107,738 GSF	Unknown	Unknown		
22	Not Solar-Ready	DOC	Mods 2,4,10	Rikers Island	Bronx		118,200 GSF	Poor	> 20 years		
22	Not Solar-Ready	DOE	Q017	28-37 29 STREET	Queens		118,900 GSF	Fair	15 to 19 years		
22	Not Solar-Ready	DOC	300 Bed Annex	Rikers Island	Bronx		120,000 GSF	Between Fair and Poor	> 20 years		
22	Not Solar-Ready	DOC	CPSU 500 Bed Annex	Rikers Island	Bronx		120,000 GSF	Between Fair and Poor	> 20 years		
22	Not Solar-Ready	DOE	Q234	30-15 29TH STREET	Queens		121,894 GSF	Fair	10 to 14 years		
22	Not Solar-Ready	DOE	Q122	21-21 DITMARS BLVD.	Queens		130,925 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
22	Solar-Ready	DOE	Q126	31-51 21 STREET	Queens		139,325 GSF	Between Good and Fair	5 to 9 years	Yes	
22	Not Solar-Ready	DOE	Q070	30-45 42 STREET	Queens		159,922 GSF	Fair	15 to 19 years		
22	Solar-Ready	DOE	Q171	14-14 29 AVENUE	Queens	EJZ	160,900 GSF	Good	2 to 4 years	Yes	
22	Solar-Ready	DOC	800 Bed Addition	16-16 Hazen St	Queens		225,000 GSF	Between Good and Fair	5 to 9 years		
22	Not Solar-Ready	DOC	RMSC Detention Facility	Rikers Island	Bronx		291,000 GSF	Between Fair and Poor	Unknown		
22	Not Solar-Ready	DOE	Q452	14-30 BROADWAY	Queens	EJZ	345,250 GSF	Fair	> 20 years		
22	Not Solar-Ready	DOC	Rikers Island GRVC Detention Facility	Rikers Island	Bronx		458,000 GSF	Between Fair and Poor	Unknown		
22	Not Solar-Ready	DOC	Main Building	Rikers Island	Bronx		461,047 GSF	Between Fair and Poor	Unknown		
22	Not Solar-Ready	DOC	EMTC Detention Facility	Rikers Island	Bronx		484,407 GSF	Fair	15 to 19 years		
22	Not Solar-Ready	DOC	GMDC Detention Facility	Rikers Island	Bronx		533,491 GSF	Fair	15 to 19 years		
22	Not Solar-Ready	DOC	RNDC Detention Facility	Rikers Island	Bronx		557,200 GSF	Between Fair and Poor	Unknown		
22	Not Solar-Ready	DOC	JATC Detention Facility	Rikers Island	Bronx		642,800 GSF	Poor	Unknown		
22	Not Solar-Ready	DOC	AMKC Detention Facility	Rikers Island	Bronx		963,830 GSF	Between Fair and Poor	Unknown		
23	Not Solar-Ready	FDNY	Engine Co. 301 and Ladder Co. 150	91-02 197th St	Queens	EJZ	10,000 GSF	Between Fair and Poor	> 20 years		
23	Not Solar-Ready	CUNY	W Building	226-11 56th Ave	Queens	EJZ	10,540 GSF	Between Fair and Poor	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
23	Not Solar-Ready	CUNY	Y2 Building	222-09 56th Ave	Queens	EJZ	12,840 GSF	Between Fair and Poor	Unknown		
23	Not Solar-Ready	DPR	Cunningham Park Maintenance Building	200 Union Turnpike	Queens		13,500 GSF	Fair	15 to 19 years		
23	Solar-Ready	QPL	Glen Oaks Community Library	256-04 Union Tpke	Queens	EJZ	18,000 GSF	Good	5 to 9 years		
23	Not Solar-Ready	CUNY	C Building	222-03 56th Ave	Queens	EJZ	20,804 GSF	Between Fair and Poor	Unknown		
23	Not Solar-Ready	CUNY	Oakland Building	221-15 56th Ave	Queens	EJZ	23,520 GSF	Fair	> 20 years		
23	Not Solar-Ready	DOE	Q799	188-04 91ST AVENUE	Queens	EJZ	25,000 GSF	Between Good and Fair	10 to 14 years		
23	Not Solar-Ready	CUNY	Service Building	221-03 56th Ave	Queens	EJZ	27,622 GSF	Poor	Unknown		
23	Not Solar-Ready	CUNY	Technology Building	221-25 56th Ave	Queens	EJZ	30,632 GSF	Poor	Unknown		
23	Not Solar-Ready	NYPD	105th Precinct	92-08 222nd St	Queens	EJZ	31,500 GSF	Good	10 to 14 years		
23	Not Solar-Ready	NYPD	Highway District #3	198-15 Grand Central Parkway	Queens		33,500 GSF	Good	15 to 19 years		
23	Not Solar-Ready	CUNY	Cafeteria / Student Union Building	221-35 56th Ave	Queens	EJZ	33,746 GSF	Between Good and Fair	> 20 years		
23	Not Solar-Ready	CUNY	Kennedy Hall Gymnasium	221-05 56th Ave	Queens	EJZ	57,776 GSF	Between Fair and Poor	Unknown		
23	Solar-Ready	NYPD	Old 107th Precinct	186-01 73rd Ave	Queens	EJZ	61,400 GSF	Good	2 to 4 years		
23	Solar-Ready	DOE	Q178	189-10 RADNOR ROAD	Queens		69,680 GSF	Good	5 to 9 years	Yes	
23	Not Solar-Ready	DOE	Q188	218-12 HARTLAND AVENUE	Queens		69,905 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
23	Solar-Ready	DOE	Q115	80-51 261 STREET	Queens		70,734 GSF	Between Good and Fair	10 to 14 years	Yes	
23	Not Solar-Ready	DOE	Q811	61-25 MARATHON PKWY	Queens		70,925 GSF	Between Good and Fair	15 to 19 years		
23	Not Solar-Ready	CUNY	Administration / Business Building	222-11 56th Ave	Queens	EJZ	72,026 GSF	Between Fair and Poor	Unknown		
23	Not Solar-Ready	DOE	Q266	74-10 COMMONWEALTH BOULEVARD	Queens	EJZ	81,600 GSF	Fair	10 to 14 years		
23	Not Solar-Ready	DSNY	Queens East 11/13 District Garage	75-05 Douglaston Pkwy	Queens		86,000 GSF	Poor	Unknown		
23	Not Solar-Ready	DOE	Q191	85-15 258 STREET	Queens		87,600 GSF	Between Fair and Poor	> 20 years		
23	Not Solar-Ready	DOE	Q208	74-30 COMMONWEALTH BOULEVARD	Queens	EJZ	87,600 GSF	Fair	10 to 14 years		
23	Solar-Ready	DOE	Q213	231-02 67 AVENUE	Queens	EJZ	88,217 GSF	Good	2 to 4 years	Yes	
23	Not Solar-Ready	DOE	Q186	252-12 72 AVENUE	Queens		92,575 GSF	Fair	15 to 19 years		
23	Not Solar-Ready	DOE	Q133	248-05 86 AVENUE	Queens	EJZ	93,883 GSF	Fair	15 to 19 years		
23	Not Solar-Ready	DOE	Q221	57-40 MARATHON PKWY	Queens		94,880 GSF	Fair	15 to 19 years		
23	Not Solar-Ready	DOE	Q203	53-11 SPRINGFIELD BLVD	Queens	EJZ	94,880 GSF	Fair	> 20 years		
23	Not Solar-Ready	DOE	Q026	195-02 69 AVENUE	Queens	EJZ	103,300 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
23	Solar-Ready	DOE	Q035	191-02 90 AVENUE	Queens	EJZ	103,433 GSF	Between Good and Fair	5 to 9 years		
23	Not Solar-Ready	DOE	Q263	222-14 JAMAICA AVENUE	Queens	EJZ	106,800 GSF	Fair	10 to 14 years	Yes	
23	Not Solar-Ready	CUNY	Kurt Schmeller Library	222-05 56th Ave	Queens	EJZ	107,884 GSF	Between Fair and Poor	Unknown		
23	Solar-Ready	DOE	Q135	207-11 89 AVENUE	Queens	EJZ	120,125 GSF	Good	2 to 4 years		
23	Not Solar-Ready	DOE	Q205	75-25 BELL BLVD	Queens		120,648 GSF	Under construction	Under construction		
23	Not Solar-Ready	DOE	Q109	213-10 92 AVENUE	Queens	EJZ	128,777 GSF	Fair	> 20 years	Yes	
23	Solar-Ready	DOE	Q033	91-37 222 STREET	Queens	EJZ	136,755 GSF	Good	< 2 years		
23	Not Solar-Ready	CUNY	Medical Arts Building	222-01 56th Ave	Queens	EJZ	141,324 GSF	Poor	Unknown		
23	Not Solar-Ready	CUNY	Humanities Building	222-25 56th Ave	Queens	EJZ	148,066 GSF	Poor	Unknown		
23	Not Solar-Ready	DOE	Q172	81-14 257 STREET	Queens	EJZ	160,975 GSF	Fair	15 to 19 years		
23	Not Solar-Ready	CUNY	Science Building	222-15 56th Ave	Queens	EJZ	171,204 GSF	Poor	Unknown		
23	Not Solar-Ready	DOE	Q566	74-20 COMMONWEALTH BOULEVARD	Queens	EJZ	273,066 GSF	Fair	10 to 14 years		
23	Not Solar-Ready	DOE	Q415	57-00 223 STREET	Queens	EJZ	341,153 GSF	Between Good and Fair	10 to 14 years	Yes	
23	Solar-Ready	DOE	Q435	230-17 HILLSIDE AVENUE	Queens	EJZ	371,973 GSF	Between Good and Fair	5 to 9 years		
24	Solar-Ready	FDNY	EMS 50	159-10 Goethals Ave	Queens	EJZ	15,000 GSF	Good	< 2 years		
24	Not Solar-Ready	DOHMH	Jamaica Health Center Annex	90-27 Parsons Blvd	Queens	EJZ	15,840 GSF	Unknown	5 to 9 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
24	Not Solar-Ready	DPR	FMCP Building	Flushing Meadows Corona Park	Queens		25,000 GSF	Fair	> 20 years		
24	Solar-Ready	NYPD	107th Precinct	71-01 Parsons Blvd	Queens	EJZ	32,000 GSF	Good	5 to 9 years		
24	Not Solar-Ready	DOHMH	Jamaica Health Center Main	90-37 Parsons Blvd	Queens	EJZ	35,900 GSF	Unknown	15 to 19 years		
24	Not Solar-Ready	OCME	Chief Medical Examiner	82-68 164th St	Queens	EJZ	40,950 GSF	Good	10 to 14 years		
24	Not Solar-Ready	DOE	Q173	174-10 67th Ave	Queens	EJZ	50,850 GSF	Fair	> 20 years		
24	Not Solar-Ready	DOE	Q595	162-02 HILLSIDE AVENUE	Queens	EJZ	55,038 GSF	Between Good and Fair	10 to 14 years		
24	Not Solar-Ready	HHC	Queens Hospital E & F Building	82-68 164th St	Queens	EJZ	57,555 GSF	Between Fair and Poor	15 to 19 years		
24	Not Solar-Ready	HHC	Queens Hospital S Building	158-02 Goethals Ave	Queens	EJZ	59,150 GSF	Fair	15 to 19 years		
24	Solar-Ready	DOE	Q131	170-45 84 AVENUE	Queens	EJZ	67,508 GSF	Good	< 2 years		
24	Not Solar-Ready	DOE	Q200	70-10 164 STREET	Queens	EJZ	68,080 GSF	Fair	15 to 19 years		
24	Not Solar-Ready	DOE	Q082	88-02 144 STREET	Queens	EJZ	68,460 GSF	Poor	> 20 years		
24	Not Solar-Ready	DOE	Q201	65-11 155 STREET	Queens	EJZ	87,725 GSF	Fair	15 to 19 years		
24	Not Solar-Ready	DOE	Q164	138-01 77 AVENUE	Queens		90,060 GSF	Between Fair and Poor	15 to 19 years		
24	Not Solar-Ready	DOE	Q154	75-02 162 STREET	Queens	EJZ	91,260 GSF	Between Good and Fair	10 to 14 years		
24	Not Solar-Ready	DOE	Q165	70-35 150 STREET	Queens	EJZ	98,500 GSF	Fair	10 to 14 years	Yes	
24	Not Solar-Ready	DOE	Q117	85-15 143rd St	Queens	EJZ	111,680 GSF	Between Good and Fair	10 to 14 years		
24	Not Solar-Ready	DOE	Q219	144-39 GRAVETT ROAD	Queens	EJZ	115,450 GSF	Under construction	Under construction		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
24	Not Solar-Ready	DOE	Q680	150-91 87 ROAD	Queens	EJZ	117,568 GSF	Under construction	Under construction		
24	Not Solar-Ready	DOE	Q499	148-20 REEVES AVENUE	Queens	EJZ	136,900 GSF	Fair	10 to 14 years		
24	Not Solar-Ready	DOE	Q217	85-05 144 STREET	Queens	EJZ	139,314 GSF	Between Fair and Poor	> 20 years		
24	Solar-Ready	DHS	Briarwood Residence	80-20 134th St	Queens	EJZ	142,000 GSF	Good	5 to 9 years		
24	Solar-Ready	DOE	Q695	160-20 GOETHALS AVENUE	Queens	EJZ	143,000 GSF	Good	5 to 9 years		
24	Not Solar-Ready	DOE	Q168	158-40 76 ROAD	Queens	EJZ	145,375 GSF	Poor	10 to 14 years	Yes	
24	Not Solar-Ready	DOE	Q216	64-20 175 STREET	Queens	EJZ	151,325 GSF	Fair	> 20 years		
24	Not Solar-Ready	DOE	Q425	63-25 MAIN ST	Queens	EJZ	159,502 GSF	Under construction	Under construction	Yes	
24	Solar-Ready	DOE	Q515	149-11 MELBOURNE AVENUE	Queens	EJZ	210,100 GSF	Between Good and Fair	2 to 4 years		
24	Not Solar-Ready	DCAS	Queens Civil Court	89-17 Sutphin Blvd	Queens	EJZ	230,035 GSF	Good	15 to 19 years		
24	Not Solar-Ready	HHC	Queens Hospital T Building	82-41 Parsons Blvd	Queens	EJZ	250,040 GSF	Poor	> 20 years		
24	Not Solar-Ready	DOE	Q470	167-01 GOTHIC DR.	Queens	EJZ	291,600 GSF	Fair	15 to 19 years		
24	Not Solar-Ready	DCAS	Queens Supreme Court	88-11 Sutphin Blvd	Queens	EJZ	308,200 GSF	Good	> 20 years		
25	Solar-Ready	QPL	Elmhurst (ALC) Community Library	85-08 51st Ave	Queens	EJZ	14,800 GSF	Good	2 to 4 years		Green Roof
25	Not Solar-Ready	QPL	Jackson Heights Community Library	35-51 81st St	Queens	EJZ	17,100 GSF	Between Fair and Poor	> 20 years		
25	Solar-Ready	HHC	Women's Health Pavilion	78-20 41st Ave	Queens	EJZ	17,370 GSF	Good	5 to 9 years		
25	Not Solar-Ready	DOE	Q322	89-11 43RD AVENUE	Queens	EJZ	17,384 GSF	Fair	10 to 14 years	Yes	
25	Solar-Ready	HHC	Hope Pavilion	77-04 41st Ave	Queens		23,954 GSF	Good	5 to 9 years		
25	Not Solar-Ready	DOE	Q222	86-15 37TH AVENUE	Queens		55,020 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
25	Solar-Ready	DOE	Q280	34-20 94TH STREET	Queens	EJZ	60,844 GSF	Between Good and Fair	5 to 9 years		
25	Not Solar-Ready	DOE	Q212	34-25 82ND STREET	Queens	EJZ	94,900 GSF	Fair	15 to 19 years		
25	Not Solar-Ready	DOE	Q230	34-01 73RD STREET	Queens	EJZ	100,880 GSF	Fair	15 to 19 years		
25	Not Solar-Ready	DOE	Q069	77-02 37 AVENUE	Queens		109,333 GSF	Between Good and Fair	10 to 14 years		
25	Not Solar-Ready	DOE	Q148	89-02 32 AVENUE	Queens	EJZ	110,525 GSF	Between Good and Fair	10 to 14 years		
25	Not Solar-Ready	DOE	Q457	48-01 90th St	Queens		111,836 GSF	Between Good and Fair	10 to 14 years		
25	Not Solar-Ready	DOE	Q149	93-11 34 AVNEUE	Queens	EJZ	112,900 GSF	Between Good and Fair	15 to 19 years		
25	Solar-Ready	DOE	Q102	55-24 VAN HORN STREET	Queens	EJZ	147,600 GSF	Between Good and Fair	5 to 9 years		
25	Solar-Ready	DOE	Q007	80-55 Cornish Ave	Queens	EJZ	150,175 GSF	Fair	5 to 9 years		
25	Solar-Ready	DOE	Q089	85-28 BRITTON AVENUE	Queens	EJZ	159,600 GSF	Good	2 to 4 years		
25	Not Solar-Ready	DOE	Q005	50-40 JACOBUS STREET	Queens	EJZ	180,166 GSF	Between Good and Fair	> 20 years		
25	Not Solar-Ready	DOE	Q013	55-01 94 STREET	Queens	EJZ	214,800 GSF	Fair	15 to 19 years		
25	Not Solar-Ready	DOE	Q145	33-34 80 STREET	Queens		240,175 GSF	Fair	> 20 years		
26	Not Solar-Ready	QPL	Woodside Community Library	54-22 Skillman Ave	Queens	EJZ	10,200 GSF	Between Fair and Poor	> 20 years		
26	Not Solar-Ready	FDNY	Engine Co 258 and Ladder Co. 115	10-40 47th Ave	Queens		13,500 GSF	Unknown	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
26	Not Solar-Ready	NYPD	108th Precinct	5-47 50th Ave	Queens		15,000 GSF	Good	10 to 14 years		
26	Solar-Ready	QPL	Broadway Community Library	40-20 Broadway	Queens	EJZ	15,700 GSF	Good	5 to 9 years		
26	Solar-Ready	FDNY	Engine Co. 259 and Ladder Co. 128, Batt. 45	33-51 Greenpoint Ave	Queens	EJZ	15,790 GSF	Good	5 to 9 years		
26	Not Solar-Ready	QPL	Long Island City Community Library	37-44 21st St	Queens		18,000 GSF	Unknown	10 to 14 years		
26	Not Solar-Ready	DOT	Streetlighting Warehouse	46-01 37th Ave	Queens		18,472 GSF	Fair	Unknown		
26	Not Solar-Ready	DOE	Q825	46-02 47TH AVE.	Queens		19,205 GSF	Good	10 to 14 years	Yes	
26	Not Solar-Ready	QPL	Hunters Point Community Library	47-40 Center Blvd	Queens		22,000 GSF	Unknown	Unknown		
26	Not Solar-Ready	DSNY	Queens West 1 District Garage	34-28 21st St	Queens	EJZ	33,725 GSF	Between Fair and Poor	Unknown		
26	Solar-Ready	DOE	Q570	35-12 35TH AVENUE	Queens	EJZ	43,000 GSF	Between Good and Fair	5 to 9 years		
26	Solar-Ready	DHS	Borden Avenue Shelter	21-10 Borden Ave	Queens		55,000 GSF	Good	5 to 9 years		
26	Not Solar-Ready	DCAS	Long Island City Courthouse	25-10 Court Sq	Queens		59,300 GSF	Good	15 to 19 years		
26	Not Solar-Ready	NYPD	Property Clerk	47-07 Pearson Pl	Queens		66,296 GSF	Between Fair and Poor	Unknown		
26	Solar-Ready	NYPD	Central Motor Repair Shop	53-15 58th St	Queens		75,400 GSF	Good	2 to 4 years		
26	Not Solar-Ready	DOE	Q112	25-05 37 AVENUE	Queens	EJZ	79,325 GSF	Fair	15 to 19 years		
26	Not Solar-Ready	DOE	Q011	54-25 SKILLMAN AVENUE	Queens		79,464 GSF	Fair	15 to 19 years		
26	Not Solar-Ready	DOE	Q199	39-20 48TH AVE.	Queens		82,613 GSF	Fair	10 to 14 years	Yes	
26	Solar-Ready	DCLA	Museum of the Moving Image	36-01 35th Ave	Queens		96,000 GSF	Good	5 to 9 years		
26	Not Solar-Ready	DOE	Q111	37-15 13 STREET	Queens		104,500 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
26	Not Solar-Ready	DOE	Q150	40-01 43 AVENUE	Queens	EJZ	104,500 GSF	Between Fair and Poor	15 to 19 years		
26	Not Solar-Ready	DOE	Q076	36-36 10 STREET	Queens	EJZ	114,100 GSF	Fair	15 to 19 years		
26	Not Solar-Ready	DOE	Q012	42-00 72 STREET	Queens	EJZ	116,105 GSF	Fair	> 20 years		
26	Not Solar-Ready	DOE	Q152	33-52 62 STREET	Queens	EJZ	116,431 GSF	Fair	15 to 19 years		
26	Not Solar-Ready	DOE	Q166	33-09 35 AVENUE	Queens		126,125 GSF	Fair	> 20 years		
26	Not Solar-Ready	DCLA	P.S. 1 Contemporary Art Center	46-01 21st St	Queens		140,000 GSF	Fair	15 to 19 years		
26	Not Solar-Ready	DOE	Q725	21-16 44TH RD.	Queens		145,025 GSF	Fair	10 to 14 years		
26	Not Solar-Ready	DOT	Warehouse	11-00 53rd Ave	Queens		155,000 GSF	Unknown	Unknown		
26	Not Solar-Ready	DOT	Office	28-11 Queens Plz North	Queens		188,542 GSF	Unknown	Unknown		
26	Not Solar-Ready	DOE	Q800	28-11 QUEENS PLAZA NORTH	Queens		219,362 GSF	Fair	15 to 19 years		
26	Not Solar-Ready	CUNY	M - Joseph Shenker Hall	31-10 Thomson Ave	Queens		261,099 GSF	Poor	Unknown		
26	Not Solar-Ready	DOE	Q610	45-30 36 STREET	Queens		317,000 GSF	Under construction	Under construction		
26	Not Solar-Ready	CUNY	E - E Building	31-40 Thomson Ave	Queens		367,000 GSF	Poor	Unknown		
26	Solar-Ready	DOE	Q801	44-36 VERNON BLVD	Queens		750,000 GSF	Good	2 to 4 years	Yes	
26	Solar-Ready	CUNY	C - Center 3 Building	29-10 Thomson Ave	Queens		892,106 GSF	Between Good and Fair	5 to 9 years		
27	Not Solar-Ready	DOE	Q835	109-36 204th St	Queens	EJZ	12,000 GSF	Between Good and Fair	15 to 19 years		
27	Not Solar-Ready	QPL	South Jamaica Community Library	108-41 Guy R. Brewer Blvd	Queens	EJZ	13,500 GSF	Good	15 to 19 years		
27	Not Solar-Ready	ACS	Blanche Day Care Center	109-60 202nd St	Queens	EJZ	17,590 GSF	Good	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
27	Not Solar-Ready	NYPD	103rd Precinct	168-02 91st Ave	Queens	EJZ	27,250 GSF	Fair	15 to 19 years		
27	Not Solar-Ready	DOE	Q036	187-01 FOCH BLVD	Queens	EJZ	42,049 GSF	Between Fair and Poor	15 to 19 years		
27	Not Solar-Ready	DOE	Q034	104-12 SPRINGFIELD BLVD	Queens	EJZ	58,556 GSF	Between Good and Fair	> 20 years		
27	Not Solar-Ready	DPR	Roy Wilkins Recreation Center	117-05 Merrick Blvd	Queens	EJZ	60,000 GSF	Fair	15 to 19 years		
27	Not Solar-Ready	DOE	Q176	120-45 235 STREET	Queens	EJZ	71,827 GSF	Fair	> 20 years		
27	Not Solar-Ready	DHS	Jamaica Arms Hotel / Family Respite Residence	175-10 88th Ave	Queens	EJZ	80,332 GSF	Between Good and Fair	10 to 14 years		
27	Not Solar-Ready	DOE	Q118	190-20 109TH RD.	Queens	EJZ	82,900 GSF	Fair	> 20 years		
27	Solar-Ready	DOE	Q136	201-15 115 AVENUE	Queens	EJZ	85,300 GSF	Between Good and Fair	2 to 4 years		
27	Not Solar-Ready	DOT	Parking Garage	150-02 Jamaica Ave	Queens	EJZ	88,000 GSF	Unknown	Unknown		
27	Solar-Ready	DOE	Q116	107-25 WREN PLACE	Queens	EJZ	91,955 GSF	Good	< 2 years		
27	Not Solar-Ready	DOE	Q147	218-01 116 AVENUE	Queens	EJZ	96,100 GSF	Fair	> 20 years		
27	Not Solar-Ready	DOE	Q134	203-02 109TH AVENUE	Queens	EJZ	97,200 GSF	Fair	10 to 14 years		
27	Not Solar-Ready	DOE	Q268	92-07 175 STREET	Queens	EJZ	105,600 GSF	Fair	10 to 14 years		
27	Not Solar-Ready	DOE	Q037	179-37 137 AVENUE	Queens	EJZ	105,725 GSF	Fair	15 to 19 years		
27	Not Solar-Ready	DOE	Q095	179-01 90 AVENUE	Queens	EJZ	111,310 GSF	Between Fair and Poor	15 to 19 years		
27	Not Solar-Ready	NYPD	NYPD Police Laboratory	150-14 Jamaica Ave	Queens	EJZ	132,500 GSF	Fair	15 to 19 years		
27	Not Solar-Ready	DOE	Q059	132-55 RIDGEDALE STREET	Queens	EJZ	169,375 GSF	Between Good and Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
27	Not Solar-Ready	QPL	Queens Central Library	89-11 Merrick Blvd	Queens	EJZ	239,750 GSF	Good	15 to 19 years		
27	Not Solar-Ready	DOE	Q238	88-15 182 STREET	Queens	EJZ	240,055 GSF	Fair	10 to 14 years		
27	Not Solar-Ready	DCAS	Queens Family Court	151-02 Jamaica Ave	Queens	EJZ	291,589 GSF	Between Good and Fair	15 to 19 years		
28	Not Solar-Ready	NYPD	Springfield Gardens Auto Pound	174-20 North Boundary Rd	Queens		10,000 GSF	Unknown	5 to 9 years		
28	Solar-Ready	DOE	Q875	142-10 LINDEN BLVD	Queens	EJZ	17,909 GSF	Good	2 to 4 years		
28	Not Solar-Ready	HRA	South Jamaica MAC	114-02 Guy R. Brewer Blvd	Queens	EJZ	21,255 GSF	Between Good and Fair	10 to 14 years		
28	Not Solar-Ready	NYPD	113th Precinct	167-02 Baisley Blvd	Queens	EJZ	22,250 GSF	Between Fair and Poor	5 to 9 years		
28	Solar-Ready	DEP	150-20 Rear 134th St	Jamaica WPCP	Queens		26,600 GSF	Good	2 to 4 years		
28	Not Solar-Ready	DOE	Q096	130-01 ROCKAWAY BLVD	Queens	EJZ	35,808 GSF	Fair	15 to 19 years		
28	Not Solar-Ready	DOE	Q048	155-02 108 AVENUE	Queens	EJZ	44,460 GSF	Under construction	Under construction		
28	Not Solar-Ready	DEP	Dewatering	Jamaica WPCP	Queens		54,450 GSF	Unknown	Unknown		
28	Not Solar-Ready	DOE	Q055	131-10 97 AVENUE	Queens	EJZ	54,920 GSF	Fair	15 to 19 years		
28	Not Solar-Ready	DEP	Main Bldg	Jamaica WPCP	Queens		55,278 GSF	Unknown	Unknown		
28	Not Solar-Ready	DOE	Q050	143-26 101 AVENUE	Queens	EJZ	64,869 GSF	Between Good and Fair	15 to 19 years		
28	Not Solar-Ready	DOE	Q045	126-28 150 STREET	Queens	EJZ	68,480 GSF	Fair	15 to 19 years		
28	Not Solar-Ready	DOE	Q155	130-02 115 AVENUE	Queens	EJZ	80,020 GSF	Fair	15 to 19 years		
28	Not Solar-Ready	DOE	Q140	166-01 116 AVENUE	Queens	EJZ	84,052 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
28	Not Solar-Ready	DOE	Q160	109-59 INWOOD STREET	Queens	EJZ	84,721 GSF	Under construction	Under construction		
28	Not Solar-Ready	DSNY	Queens East 8,10,12 District Garage;12A Broom	130-23 150th Ave	Queens	EJZ	90,620 GSF	Under construction	Under construction		
28	Not Solar-Ready	DOE	Q121	126-10 109 AVENUE	Queens	EJZ	91,919 GSF	Fair	15 to 19 years		
28	Solar-Ready	DOE	Q030	126-10 BEDELL STREET	Queens	EJZ	98,303 GSF	Good	< 2 years		
28	Not Solar-Ready	DOE	Q080	171-05 137 AVENUE	Queens	EJZ	100,900 GSF	Between Good and Fair	15 to 19 years		
28	Not Solar-Ready	DOE	Q161	101-33 124TH STREET	Queens	EJZ	103,280 GSF	Between Good and Fair	15 to 19 years		
28	Not Solar-Ready	DOE	Q062	97-25 108 STREET	Queens	EJZ	107,464 GSF	Fair	> 20 years		
28	Solar-Ready	DOE	Q124	129-15 150 AVENUE	Queens	EJZ	117,680 GSF	Fair	5 to 9 years		
28	Not Solar-Ready	DOE	Q100	111-11 118 STREET	Queens	EJZ	118,800 GSF	Between Fair and Poor	15 to 19 years		
28	Not Solar-Ready	DOE	Q040	109-20 UNION HALL STREET	Queens	EJZ	121,865 GSF	Between Fair and Poor	> 20 years		
28	Not Solar-Ready	DOE	Q223	125-20 SUTPHIN BLVD	Queens	EJZ	122,575 GSF	Fair	> 20 years		
28	Not Solar-Ready	DOE	Q142	142-10 LINDEN BLVD	Queens	EJZ	127,466 GSF	Fair	15 to 19 years		
28	Not Solar-Ready	DOE	Q123	145-01 119TH AVE.	Queens	EJZ	129,120 GSF	Between Good and Fair	> 20 years		
28	Not Solar-Ready	DOE	Q650	94-06 104TH STREET	Queens	EJZ	149,900 GSF	Between Good and Fair	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
28	Not Solar-Ready	DOE	Q108	108-10 109 AVENUE	Queens	EJZ	164,575 GSF	Fair	> 20 years		
28	Not Solar-Ready	DOE	Q690	116-25 GUY BREWER BOULEVARD	Queens	EJZ	197,423 GSF	Between Good and Fair	10 to 14 years		
28	Not Solar-Ready	DOE	Q475	89-30 114TH STREET	Queens	EJZ	239,664 GSF	Fair	> 20 years		
28	Solar-Ready	DOE	Q400	156-10 BAISLEY BLVD	Queens	EJZ	279,357 GSF	Good	2 to 4 years	Yes	
28	Solar-Ready	DEP	150-20 134th St	Jamaica WPCP	Queens		686,240 GSF	Good	< 2 years		
29	Solar-Ready	QPL	Richmond Hill Community Library	118-14 Hillside Ave	Queens		13,000 GSF	Between Good and Fair	5 to 9 years		
29	Not Solar-Ready	NYPD	102nd Precinct	87-30 118th St	Queens	EJZ	18,225 GSF	Good	10 to 14 years		
29	Not Solar-Ready	DOT	Glendale Yard	69-46 Sybilla St	Queens		23,624 GSF	Fair	Unknown		
29	Solar-Ready	QPL	Forest Hills Community Library	108-19 71st Ave	Queens		23,739 GSF	Good	2 to 4 years		
29	Solar-Ready	DOE	Q303	108-55 69 AVENUE	Queens		30,000 GSF	Between Good and Fair	5 to 9 years		
29	Not Solar-Ready	DOC	Queens Detention Complex Auxiliary Building	126-02 82nd Ave	Queens	EJZ	31,333 GSF	Between Fair and Poor	> 20 years		
29	Solar-Ready	DPR	Lost Battalion Hall Recreation Center	93-29 Queens Blvd	Queens	EJZ	32,640 GSF	Between Good and Fair	5 to 9 years		Green Roof
29	Not Solar-Ready	NYPD	112th Precinct	68-40 Austin St	Queens	EJZ	36,111 GSF	Unknown	10 to 14 years		
29	Not Solar-Ready	DOE	Q054	86-02 127 STREET	Queens	EJZ	55,148 GSF	Fair	10 to 14 years		
29	Not Solar-Ready	DOE	Q101	2 RUSSELL PLACE	Queens		66,060 GSF	Between Good and Fair	> 20 years		
29	Solar-Ready	DOE	Q099	82-37 KEW GARDENS ROAD	Queens	EJZ	74,500 GSF	Good	2 to 4 years		
29	Not Solar-Ready	DOE	Q206	61-21 97 PLACE	Queens	EJZ	75,177 GSF	Fair	> 20 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
29	Not Solar-Ready	DOE	Q144	93-02 69 AVENUE	Queens		80,480 GSF	Fair	15 to 19 years		
29	Not Solar-Ready	DOE	Q174	65-10 DIETERLE CRESCENT	Queens		85,727 GSF	Fair	15 to 19 years		
29	Solar-Ready	DOE	Q175	64-35 102 STREET	Queens		98,500 GSF	Good	2 to 4 years	Yes	
29	Solar-Ready	DOE	Q196	71-25 113 STREET	Queens	EJZ	112,800 GSF	Good	2 to 4 years		
29	Not Solar-Ready	DOE	Q190	68-17 AUSTIN STREET	Queens		147,725 GSF	Between Fair and Poor	> 20 years		
29	Solar-Ready	DOE	Q220	62-10 108 STREET	Queens		165,780 GSF	Good	5 to 9 years	Yes	
29	Not Solar-Ready	DOC	Queens Detention Complex Main Building	126-02 82nd Ave	Queens	EJZ	177,554 GSF	Between Fair and Poor	> 20 years		
29	Not Solar-Ready	DCAS	Queens Criminal Court (Annex)	125-01 Queens Blvd	Queens	EJZ	207,360 GSF	Fair	> 20 years		
29	Not Solar-Ready	DCAS	Queens Borough Hall	120-55 Queens Blvd	Queens	EJZ	261,000 GSF	Fair	15 to 19 years		
29	Not Solar-Ready	DOE	Q440	67-01 110 ST.	Queens	EJZ	279,591 GSF	Fair	> 20 years		
29	Solar-Ready	DOE	Q686	91-30 METROPOLITAN AVENUE	Queens		298,673 GSF	Between Good and Fair	5 to 9 years		
29	Not Solar-Ready	DCAS	Queens Criminal Court	125-01 Queens Blvd	Queens	EJZ	440,640 GSF	Poor	Unknown		
30	Solar-Ready	FDNY	Queens Central Office	83-24 Woodhaven Blvd	Queens		10,762 GSF	Good	5 to 9 years		
30	Solar-Ready	QPL	Ridgewood Community Library	20-12 Madison St	Queens		12,000 GSF	Good	5 to 9 years		
30	Not Solar-Ready	DPR	Forest Park Greenhouse	88th Pl at Myrtle Ave	Queens		12,796 GSF	Fair	15 to 19 years		
30	Not Solar-Ready	QPL	Glendale Community Library	78-60 73rd Pl	Queens		13,356 GSF	Between Good and Fair	15 to 19 years		
30	Not Solar-Ready	DSNY	Sanitation Police Enforcement	51-15 Flushing Ave	Queens		17,700 GSF	Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
30	Not Solar-Ready	NYPD	104th Precinct	64-2 Catalpa Ave	Queens		19,075 GSF	Between Fair and Poor	10 to 14 years		
30	Not Solar-Ready	DOE	Q878	63-25 69th St	Queens		20,760 GSF	Fair	> 20 years		
30	Solar-Ready	DPR	Forest Park DPR Shops	82-99 88th Pl	Queens		27,000 GSF	Good	< 2 years		Green Roof
30	Not Solar-Ready	DSNY	Queens West 5A Broom Garage	47-01 48th Street	Queens	EJZ	37,000 GSF	Poor	> 20 years		
30	Not Solar-Ready	DOE	Q009	58-74 57 STREET	Queens		54,060 GSF	Between Fair and Poor	15 to 19 years		
30	Not Solar-Ready	DSNY	Queens 6 Garage	58-73 53rd Ave	Queens		62,880 GSF	Poor	Unknown		
30	Not Solar-Ready	DOE	Q049	79-15 PENELOPE AVENUE	Queens		84,000 GSF	Fair	15 to 19 years		
30	Not Solar-Ready	DOE	Q068	59-09 SAINT FELIX AVENUE	Queens	EJZ	86,500 GSF	Fair	15 to 19 years		
30	Not Solar-Ready	DSNY	Queens West 5 and 5A District Garages	48-01 58th Rd	Queens		91,868 GSF	Poor	Unknown		
30	Solar-Ready	DOE	Q087	67-54 80 STREET	Queens		96,765 GSF	Good	2 to 4 years		
30	Solar-Ready	DOE	Q113	87-21 79 AVENUE	Queens		97,200 GSF	Between Good and Fair	5 to 9 years		
30	Not Solar-Ready	DOE	Q071	62-85 FOREST AVENUE	Queens		98,500 GSF	Under construction	Under construction		
30	Not Solar-Ready	NYPD	Building Maintenance/Quartermaster	59-06 Laurel Hill Blvd	Queens		101,600 GSF	Good	10 to 14 years		
30	Not Solar-Ready	DOT	Maspeth Central Shops	58-50 57th Rd	Queens		109,800 GSF	Between Fair and Poor	Unknown		
30	Not Solar-Ready	DOE	Q119	74-01 78 AVENUE	Queens		121,375 GSF	Fair	> 20 years		
30	Not Solar-Ready	DOE	Q091	68-10 CENTRAL AVE	Queens		124,925 GSF	Between Fair and Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
30	Not Solar-Ready	DOE	Q088	60-85 CATALPA AVENUE	Queens		129,600 GSF	Between Good and Fair	10 to 14 years		
30	Not Solar-Ready	DSNY	Queens Borough Repair Shop	52-07 58th St	Queens		134,408 GSF	Between Fair and Poor	Unknown		
30	Not Solar-Ready	DOE	Q153	60-02 60 LANE	Queens		138,004 GSF	Fair	15 to 19 years		
30	Not Solar-Ready	DOE	Q058	72-24 GRAND AVENUE	Queens		141,261 GSF	Fair	15 to 19 years		
30	Not Solar-Ready	DOE	Q093	6656 FOREST AVENUE	Queens		150,000 GSF	Under construction	Under construction		
30	Not Solar-Ready	DOE	Q073	70-02 54 AVENUE	Queens		177,928 GSF	Between Good and Fair	10 to 14 years		
30	Solar-Ready	DOE	Q485	21-27 HIMROD STREET	Queens		528,000 GSF	Between Good and Fair	5 to 9 years	Yes	
30	Not Solar-Ready	DSNY	Queens West 2,3,4 District Garages; Central Repair Shop	52-35 58th St	Queens		759,046 GSF	Between Fair and Poor	> 20 years	Yes	
31	Not Solar-Ready	DPR	Sorrentino Recreation Center	18-48 Cornaga Ave	Queens	EJZ	12,240 GSF	Fair	> 20 years		
31	Not Solar-Ready	DOE	Q907	98 BEACH 28TH STREET	Queens	EJZ	13,260 GSF	Fair	10 to 14 years		
31	Not Solar-Ready	FDNY	Engine Co. 264 and Ladder Co. 134, Engine Co. 328	16-17 Central Ave	Queens	EJZ	16,550 GSF	Between Fair and Poor	> 20 years		
31	Solar-Ready	NYPD	101st Precinct	16-12 Mott Ave	Queens	EJZ	18,680 GSF	Good	5 to 9 years		
31	Not Solar-Ready	NYPD	Queens South Task Force	244-04 North Conduit Ave	Queens	EJZ	19,024 GSF	Between Fair and Poor	Unknown		
31	Not Solar-Ready	DOE	Q106	180 BEACH 35 STREET	Queens	EJZ	19,385 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
31	Not Solar-Ready	FDNY	Engine Co. 265 and Ladder 121, Batt. 47, EMS 47	303 Beach 49th St	Queens	EJZ	19,958 GSF	Fair	10 to 14 years		
31	Solar-Ready	DHS	Springfield Family Residence	146-80 Guy R. Brewer Blvd	Queens	EJZ	21,000 GSF	Good	5 to 9 years		
31	Not Solar-Ready	ACS	Blanche Community Progress Day Care Center 2	44-22 Beach Channel Dr	Queens	EJZ	27,700 GSF	Between Fair and Poor	15 to 19 years		
31	Not Solar-Ready	DOE	Q038	135-21 241 STREET	Queens	EJZ	35,363 GSF	Fair	> 20 years		
31	Not Solar-Ready	DOE	Q132	132-15 218th St	Queens	EJZ	57,553 GSF	Under construction	Under construction		
31	Not Solar-Ready	DOE	Q052	178-37 146 TERRACE	Queens	EJZ	68,867 GSF	Fair	15 to 19 years		
31	Solar-Ready	DSNY	Queens 14 District Garage	51-10 Almeda Ave	Queens	EJZ	72,663 GSF	Good	5 to 9 years		
31	Not Solar-Ready	DOE	Q104	26-01 MOTT AVENUE	Queens	EJZ	82,900 GSF	Fair	15 to 19 years		
31	Not Solar-Ready	DOE	Q181	148-15 230 STREET	Queens	EJZ	86,480 GSF	Between Fair and Poor	> 20 years		
31	Not Solar-Ready	DOE	Q197	825 HICKSVILLE ROAD	Queens		92,500 GSF	Poor	> 20 years		
31	Not Solar-Ready	DOE	Q138	251-11 Weller Ave	Queens	EJZ	92,639 GSF	Fair	15 to 19 years		
31	Not Solar-Ready	DOE	Q156	229-02 137 AVENUE	Queens	EJZ	95,971 GSF	Between Fair and Poor	> 20 years		
31	Not Solar-Ready	DOE	Q253	1307 CENTRAL AVENUE	Queens		98,366 GSF	Between Good and Fair	10 to 14 years		
31	Not Solar-Ready	DOE	Q105	420 BEACH 51 STREET	Queens	EJZ	103,325 GSF	Fair	15 to 19 years		
31	Solar-Ready	DOE	Q270	233-15 MERRICK BOULEVARD	Queens	EJZ	104,400 GSF	Good	< 2 years		
31	Not Solar-Ready	DOE	Q195	253-50 149 AVENUE	Queens	EJZ	110,417 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
31	Solar-Ready	DOE	Q333	365 BEACH 56 STREET	Queens	EJZ	139,325 GSF	Between Good and Fair	5 to 9 years		
31	Solar-Ready	DOE	Q042	488 BEACH 66 STREET	Queens	EJZ	145,200 GSF	Between Good and Fair	5 to 9 years		
31	Solar-Ready	DOE	Q231	145-00 SPRINGFIELD BLVD	Queens	EJZ	146,400 GSF	Between Good and Fair	5 to 9 years	Yes	
31	Not Solar-Ready	DOE	Q053	10-45 NAMEOKE STREET	Queens	EJZ	196,975 GSF	Under construction	Under construction		
31	Not Solar-Ready	DOE	Q465	821 BEACH 25TH STREET	Queens	EJZ	272,600 GSF	Under construction	Under construction		
31	Not Solar-Ready	DOE	Q420	143-10 SPRINGFIELD BLVD.	Queens	EJZ	326,600 GSF	Poor	10 to 14 years	Yes	
32	Not Solar-Ready	FDNY	Engine Co. 268 and Ladder Co. 137	257 Beach 116th St	Queens		10,089 GSF	Unknown	15 to 19 years		
32	Not Solar-Ready	DEP	Return & Waste Sludge Pump Bldg: 1st Floor	Rockaway WPCP	Queens		10,552 GSF	Poor	> 20 years		
32	Not Solar-Ready	FDNY	Engine Co. 266	92-20 Rockaway Beach Blvd	Queens	EJZ	11,960 GSF	Fair	10 to 14 years		
32	Not Solar-Ready	DEP	P&C Bldg Upper Basement	Rockaway WPCP	Queens		13,578 GSF	Poor	> 20 years		
32	Not Solar-Ready	NYPD	106th Precinct	103-53 101st St	Queens	EJZ	19,044 GSF	Between Fair and Poor	15 to 19 years		
32	Not Solar-Ready	DEP	P&C Bldg 1st Floor	Rockaway WPCP	Queens		19,690 GSF	Poor	> 20 years		
32	Not Solar-Ready	NYPD	100th Precinct	92-24 Rockaway Beach Blvd	Queens	EJZ	20,710 GSF	Between Fair and Poor	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
32	Not Solar-Ready	DOE	Q047	9 POWER ROAD	Queens		24,000 GSF	Between Fair and Poor	15 to 19 years		
32	Not Solar-Ready	DOE	Q066	85-11 102 STREET	Queens	EJZ	37,008 GSF	Fair	10 to 14 years		
32	Solar-Ready	DOE	Q262	95-16 89TH AVE.	Queens	EJZ	38,078 GSF	Good	5 to 9 years		
32	Solar-Ready	DOE	Q273	88-07 102ND STREET	Queens	EJZ	41,234 GSF	Between Good and Fair	5 to 9 years		
32	Not Solar-Ready	DOE	Q056	86-10 114th St	Queens	EJZ	45,595 GSF	Fair	10 to 14 years		
32	Not Solar-Ready	DOE	Q064	82-01 101 AVENUE	Queens	EJZ	68,908 GSF	Fair	10 to 14 years		
32	Not Solar-Ready	DOE	Q114	134-01 CRONSTON AVENUE	Queens		80,400 GSF	Fair	15 to 19 years		
32	Not Solar-Ready	DOE	Q225	190 BEACH 110 STREET	Queens		84,100 GSF	Between Good and Fair	10 to 14 years		
32	Not Solar-Ready	DOE	Q097	85-52 85 STREET	Queens	EJZ	90,665 GSF	Fair	15 to 19 years		
32	Not Solar-Ready	DOE	Q060	91-02 88 AVENUE	Queens		94,917 GSF	Fair	> 20 years		
32	Not Solar-Ready	DOE	Q090	86-50 109 STREET	Queens	EJZ	96,125 GSF	Fair	> 20 years		
32	Not Solar-Ready	DOE	Q146	98-01 159 AVENUE	Queens		96,405 GSF	Fair	10 to 14 years		
32	Not Solar-Ready	DOE	Q254	84-40 101ST STREET	Queens	EJZ	98,346 GSF	Under construction	Under construction		
32	Not Solar-Ready	DOE	Q232	153-23 83 STREET	Queens		99,102 GSF	Fair	15 to 19 years		
32	Not Solar-Ready	DOE	Q207	159-15 88 STREET	Queens		105,050 GSF	Fair	15 to 19 years		
32	Not Solar-Ready	DOE	Q063	90-15 SUTTER AVENUE	Queens		118,965 GSF	Between Fair and Poor	15 to 19 years		
32	Not Solar-Ready	DOE	Q180	320 BEACH 104 STREET	Queens		146,400 GSF	Poor	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
32	Not Solar-Ready	DOE	Q202	138-30 LAFAYETTE STREET	Queens		180,175 GSF	Fair	> 20 years		
32	Solar-Ready	DOE	Q137	109-15 98TH STREET	Queens	EJZ	186,000 GSF	Good	2 to 4 years		
32	Not Solar-Ready	DOE	Q480	101-01 ROCKAWAY BLVD.	Queens	EJZ	299,292 GSF	Fair	10 to 14 years	Yes	
33	Not Solar-Ready	DCAS	Office of Transportation Service Building	Brooklyn Navy Yard	Brooklyn		10,000 GSF	Unknown	Unknown		
33	Not Solar-Ready	DEP	Cm Office	267 Greenpoint Ave	Brooklyn		10,001 GSF	Fair	15 to 19 years		
33	Not Solar-Ready	DEP	Disinfection Bldg	277 Greenpoint Ave	Brooklyn		10,001 GSF	Good	10 to 14 years		
33	Not Solar-Ready	DEP	N Control Bg	279 Greenpoint Ave	Brooklyn		10,001 GSF	Good	10 to 14 years		
33	Solar-Ready	DEP	Cntr Residuals Bg	353 Greenpoint Ave	Brooklyn		10,001 GSF	Between Good and Fair	5 to 9 years		
33	Solar-Ready	DEP	S Control Bg	281 Greenpoint Ave	Brooklyn		10,001 GSF	Good	2 to 4 years		
33	Not Solar-Ready	FDNY	Engine Co. 238 and Ladder Co. 106	205 Greenpoint Ave	Brooklyn		10,262 GSF	Fair	10 to 14 years		
33	Solar-Ready	NYPD	Tow Pound Operations Building	Brooklyn Navy Yard	Brooklyn		11,000 GSF	Between Good and Fair	5 to 9 years		
33	Not Solar-Ready	FDNY	Engine Co. 229 and Ladder Co. 146	75 Richardson St	Brooklyn		13,500 GSF	Fair	10 to 14 years		
33	Not Solar-Ready	DOT	Clay Street Storage (Under Bridge)	130 Clay St	Brooklyn		16,000 GSF	Unknown	Unknown		
33	Not Solar-Ready	DPR	McCarren Park Recreation Center	776 Lorimer St	Brooklyn		16,000 GSF	Fair	> 20 years		
33	Not Solar-Ready	DEP	Centrifuge Building	281 Greenpoint Ave	Brooklyn		16,250 GSF	Good	10 to 14 years		
33	Not Solar-Ready	FDNY	Marine Co. 6	Grand St at East Riv	Brooklyn		16,500 GSF	Unknown	Unknown		
33	Not Solar-Ready	DOT	Williamsburg Bridge Carpenter Shop	352 Kent Ave	Brooklyn		16,716 GSF	Between Fair and Poor	Unknown		
33	Not Solar-Ready	HHC	Bedford Stuyvesant Alcohol Treatment Center	722 Myrtle Ave	Brooklyn	EJZ	17,400 GSF	Between Good and Fair	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
33	Solar-Ready	NYPD	94th Precinct	100 Meserole Ave	Brooklyn		18,500 GSF	Good	5 to 9 years		
33	Solar-Ready	DEP	Main Building Area 2	281 Greenpoint Ave	Brooklyn		20,000 GSF	Good	< 2 years		
33	Not Solar-Ready	BPL	Williamsburg Branch Library	240 Division Ave	Brooklyn	EJZ	24,118 GSF	Between Fair and Poor	15 to 19 years		
33	Not Solar-Ready	DOT	Williamsburg Bridge Repair Shops	372 Kent Ave	Brooklyn		27,729 GSF	Between Fair and Poor	Unknown		
33	Not Solar-Ready	FDNY	Engine Co. 211 & Ladder Co. 119	26 Hooper St	Brooklyn	EJZ	28,285 GSF	Between Fair and Poor	15 to 19 years		
33	Not Solar-Ready	DOT	Williamsburg Bridge Lighting and Shop	424 Wythe Ave	Brooklyn		30,873 GSF	Unknown	Unknown		
33	Not Solar-Ready	DOE	K778	250 HOOPER ST	Brooklyn	EJZ	31,110 GSF	Poor	> 20 years		
33	Solar-Ready	DOE	K034	131 NORMAN AVENUE	Brooklyn	EJZ	38,400 GSF	Good	2 to 4 years		
33	Not Solar-Ready	DEP	1 Wallabout St	Red Hook WPCP	Brooklyn		39,600 GSF	Unknown	Unknown		
33	Not Solar-Ready	DOE	K369	383-387 STATE STREET	Brooklyn		39,600 GSF	Under construction	Under construction		
33	Not Solar-Ready	DCAS	Brooklyn Appellate Court	45 Monroe Pl	Brooklyn		49,500 GSF	Fair	> 20 years		
33	Not Solar-Ready	DOT	Bridges ERB Iron Shop	59 Adams St	Brooklyn		50,000 GSF	Between Fair and Poor	Unknown		
33	Not Solar-Ready	DEP	Existing Main Building	Red Hook WPCP	Brooklyn		50,400 GSF	Unknown	Unknown		
33	Solar-Ready	DOE	K806	362 SCHERMERHORN ST.	Brooklyn		55,200 GSF	Between Good and Fair	5 to 9 years		
33	Not Solar-Ready	NYPD	Service Shop #1	11 Front St	Brooklyn		58,400 GSF	Good	10 to 14 years		
33	Not Solar-Ready	DSNY	Greenpoint Marine Transfer Station	1 Kingsland Ave	Brooklyn		59,882 GSF	Fair	> 20 years		
33	Not Solar-Ready	DCAS	Brooklyn Borough Hall	209 Joralemon St	Brooklyn		64,000 GSF	Good	10 to 14 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
33	Not Solar-Ready	DSNY	Greenpoint Incinerator/Garage	459 North Henry Street	Brooklyn		65,550 GSF	Fair	> 20 years		
33	Not Solar-Ready	DCAS	OEM Headquarters	165 Cadman Plz East	Brooklyn		66,245 GSF	Good	10 to 14 years		
33	Solar-Ready	DOE	K008	37 HICKS STREET	Brooklyn		72,000 GSF	Good	5 to 9 years		
33	Not Solar-Ready	DOE	K110	124 MONITOR STREET	Brooklyn		80,400 GSF	Between Good and Fair	> 20 years		
33	Not Solar-Ready	DEP	Shaft Maintenance/Kent Avenue Machine Shop	356 Flushing Ave	Brooklyn	EJZ	94,810 GSF	Unknown	Unknown		
33	Solar-Ready	DOE	K054	195 SANFORD STREET	Brooklyn	EJZ	96,000 GSF	Good	5 to 9 years		
33	Not Solar-Ready	DOE	K031	75 MESEROLE AVENUE	Brooklyn		102,000 GSF	Fair	10 to 14 years		
33	Not Solar-Ready	DOE	K038	450 PACIFIC STREET	Brooklyn		104,400 GSF	Between Good and Fair	10 to 14 years		
33	Solar-Ready	DEP	Main Building Area 1	281 Greenpoint Ave	Brooklyn		106,250 GSF	Good	< 2 years		
33	Not Solar-Ready	DCAS	Construction Shops	390 Kent Ave	Brooklyn		107,450 GSF	Fair	> 20 years		
33	Not Solar-Ready	DOE	K261	314 PACIFIC STREET	Brooklyn		107,628 GSF	Between Fair and Poor	> 20 years		
33	Solar-Ready	DOE	K307	209 YORK STREET	Brooklyn		111,600 GSF	Good	< 2 years		
33	Not Solar-Ready	DOE	K656	500 PACIFIC STREET	Brooklyn		112,800 GSF	Fair	> 20 years		
33	Not Solar-Ready	DOE	K519	347 BALTIC STREET	Brooklyn		115,466 GSF	Fair	15 to 19 years		
33	Not Solar-Ready	DOE	K016	157 WILSON STREET	Brooklyn	EJZ	121,200 GSF	Fair	> 20 years		
33	Not Solar-Ready	DOE	K157	850 KENT AVENUE	Brooklyn	EJZ	122,400 GSF	Fair	15 to 19 years		
33	Not Solar-Ready	DEP	Building 268	Red Hook WPCP	Brooklyn		123,000 GSF	Unknown	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
33	Solar-Ready	DOE	K313	283 ADAMS STREET	Brooklyn		133,200 GSF	Between Good and Fair	5 to 9 years		
33	Solar-Ready	DOE	K802	131 LIVINGSTON STREET	Brooklyn		147,725 GSF	Good	5 to 9 years		
33	Solar-Ready	DOE	K126	424 LEONARD STREET	Brooklyn		149,046 GSF	Fair	5 to 9 years	Yes	
33	Not Solar-Ready	DOC	Brooklyn House of Detention #129	275 Atlantic Ave	Brooklyn		161,765 GSF	Fair	15 to 19 years		
33	Not Solar-Ready	DOE	K610	50 BEDFORD AVE	Brooklyn		172,800 GSF	Between Fair and Poor	15 to 19 years		
33	Solar-Ready	DOE	K117	300 WILLOUGHBY AVENUE	Brooklyn	EJZ	176,400 GSF	Good	2 to 4 years	Yes	
33	Not Solar-Ready	DOE	K318	101 WALTON STREET	Brooklyn	EJZ	181,200 GSF	Fair	> 20 years		
33	Solar-Ready	DOE	K497	284 BALTIC STREET	Brooklyn		189,600 GSF	Good	< 2 years		
33	Not Solar-Ready	DOE	K071	215 HEYWARD	Brooklyn	EJZ	202,800 GSF	Fair	15 to 19 years	Yes	
33	Solar-Ready	DOE	K650	257 NORTH 6TH ST.	Brooklyn		218,400 GSF	Good	< 2 years		
33	Not Solar-Ready	DCAS	Brooklyn Criminal Court	120 Schermerhorn St	Brooklyn		264,100 GSF	Fair	15 to 19 years		
33	Not Solar-Ready	DOE	K801	65 COURT ST	Brooklyn		288,200 GSF	Between Good and Fair	10 to 14 years		
33	Not Solar-Ready	DOE	K580	105 JOHNSON ST.	Brooklyn		292,800 GSF	Fair	> 20 years		
33	Not Solar-Ready	DEP	Skimmings Building	307 Greenpoint Ave	Brooklyn		453,617 GSF	Good	10 to 14 years		
33	Not Solar-Ready	DCAS	Brooklyn Supreme Court	360 Adams St	Brooklyn		621,817 GSF	Good	> 20 years		
33	Solar-Ready	DEP	Main Building	329 Greenpoint Ave	Brooklyn		1,306,271 GSF	Good	< 2 years		
34	Not Solar-Ready	FDNY	Engine Co. 206	1201 Grand St	Brooklyn		10,180 GSF	Fair	10 to 14 years		
34	Solar-Ready	BPL	Leonard Branch Library	82 Devoe St	Brooklyn		10,699 GSF	Good	< 2 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
34	Not Solar-Ready	BPL	Bushwick Branch Library	340 Bushwick Ave	Brooklyn	EJZ	10,757 GSF	Between Fair and Poor	15 to 19 years		
34	Solar-Ready	BPL	DeKalb Branch Library	790 Bushwick Ave	Brooklyn	EJZ	12,584 GSF	Good	2 to 4 years		
34	Not Solar-Ready	DOE	K319	360 KEAP STREET	Brooklyn	EJZ	13,200 GSF	Poor	15 to 19 years		
34	Not Solar-Ready	DHS	Stockholm Street Family Residence	103 Stockholm St	Brooklyn	EJZ	17,800 GSF	Unknown	Unknown		
34	Solar-Ready	DOE	Q848	511 SENECA AVENUE	Queens		18,000 GSF	Good	5 to 9 years		
34	Not Solar-Ready	DPR	Metropolitan Pool and Fitness Center	261 Bedford Ave	Brooklyn		18,200 GSF	Fair	> 20 years		
34	Solar-Ready	FDNY	Greenpoint EMT Station	332 Metropolitan Ave	Brooklyn		18,758 GSF	Good	5 to 9 years		
34	Not Solar-Ready	DOHMH	Williamsburg Health Center	151 Maujer St	Brooklyn		27,172 GSF	Unknown	10 to 14 years		
34	Solar-Ready	DEP	BWS Storehouse (GS1)	1201 Metropolitan Ave	Brooklyn		27,800 GSF	Between Good and Fair	5 to 9 years		
34	Not Solar-Ready	DOE	K018	101 MAUJER STREET	Brooklyn		34,800 GSF	Fair	> 20 years		
34	Solar-Ready	DOE	Q245	378 SENECA AVE.	Queens		38,500 GSF	Between Good and Fair	5 to 9 years		
34	Not Solar-Ready	NYPD	90th Precinct and Engine Company 216	211 Union Ave	Brooklyn		39,345 GSF	Good	15 to 19 years		
34	Not Solar-Ready	DOE	K075	95 GROVE STREET	Brooklyn	EJZ	64,800 GSF	Between Good and Fair	15 to 19 years		
34	Not Solar-Ready	DOE	Q075	1666 HANCOCK STREET	Queens	EJZ	70,860 GSF	Fair	15 to 19 years		
34	Not Solar-Ready	DOE	Q081	559 CYPRESS AVENUE	Queens	EJZ	75,039 GSF	Fair	15 to 19 years		
34	Solar-Ready	DOE	K132	320 MANHATTAN AVENUE	Brooklyn		86,400 GSF	Good	5 to 9 years		
34	Not Solar-Ready	DOE	K162	1390 WILLOUGHBY AVENUE	Brooklyn		88,800 GSF	Under construction	Under construction		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
34	Solar-Ready	DOE	K017	208 NORTH 5 STREET	Brooklyn		91,200 GSF	Good	2 to 4 years		
34	Not Solar-Ready	DOE	K299	88 WOODBINE	Brooklyn	EJZ	97,200 GSF	Fair	> 20 years		
34	Not Solar-Ready	DHS	Barbara Kleinman Residence	269 Skillman Ave	Brooklyn	EJZ	97,780 GSF	Fair	10 to 14 years		
34	Not Solar-Ready	DOE	K250	108 MONTROSE AVENUE	Brooklyn		102,000 GSF	Fair	15 to 19 years		
34	Solar-Ready	DOE	K123	100 IRVING AVENUE	Brooklyn	EJZ	103,200 GSF	Good	2 to 4 years		
34	Not Solar-Ready	DOE	K257	60 COOK STREET	Brooklyn		106,800 GSF	Fair	15 to 19 years		
34	Not Solar-Ready	DOE	K865	797 BUSHWICK AVENUE	Brooklyn	EJZ	106,925 GSF	Between Good and Fair	> 20 years		
34	Not Solar-Ready	DOE	K274	800 BUSHWICK AVENUE	Brooklyn	EJZ	109,200 GSF	Between Good and Fair	10 to 14 years		
34	Not Solar-Ready	DOE	K019	325 S. 3RD ST.	Brooklyn	EJZ	111,600 GSF	Fair	15 to 19 years		
34	Not Solar-Ready	DOE	K120	18 BEAVER STREET	Brooklyn	EJZ	116,400 GSF	Between Fair and Poor	> 20 years		
34	Not Solar-Ready	DOE	Q239	17-15 WEIRFIELD STREET	Queens	EJZ	117,126 GSF	Fair	10 to 14 years		
34	Not Solar-Ready	DOE	K145	100 NOLL STREET	Brooklyn	EJZ	134,400 GSF	Fair	15 to 19 years		
34	Not Solar-Ready	DOE	K050	183 SOUTH 3RD STREET	Brooklyn		138,000 GSF	Fair	> 20 years		
34	Solar-Ready	DOE	Q849	976 SENECA AVENUE	Queens		165,600 GSF	Fair	5 to 9 years		
34	Not Solar-Ready	DOE	K147	325 BUSHWICK AVENUE	Brooklyn		170,400 GSF	Between Fair and Poor	> 20 years		
34	Solar-Ready	DOE	K049	223 GRAHAM AVENUE	Brooklyn	EJZ	186,000 GSF	Good	2 to 4 years	Yes	

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
34	Not Solar-Ready	DOE	K111	35 STARR STREET	Brooklyn		193,200 GSF	Fair	> 20 years		
34	Not Solar-Ready	DSNY	Brooklyn North 1 District & 4 District Garage	161 Varick Ave	Brooklyn		202,480 GSF	Good	10 to 14 years	Yes	
34	Not Solar-Ready	DOE	K450	850 GRAND STREET	Brooklyn	EJZ	504,000 GSF	Between Fair and Poor	> 20 years		
35	Not Solar-Ready	FDNY	Engine Co. 219 and Ladder Co. 105	492 Dean St	Brooklyn		10,300 GSF	Poor	> 20 years		
35	Not Solar-Ready	FDNY	Engine Co. 234 and Ladder Co. 123, Batt. 38	1352 St. John's Pl	Brooklyn	EJZ	10,355 GSF	Poor	> 20 years		
35	Solar-Ready	FDNY	Brooklyn Central Office	35 Empire Blvd	Brooklyn		10,826 GSF	Good	5 to 9 years		
35	Solar-Ready	DEP	Hazmat Citywide Field Operations	82 Emerson Pl	Brooklyn	EJZ	11,500 GSF	Between Good and Fair	5 to 9 years		
35	Not Solar-Ready	NYPD	77th Precinct Annex	653 Grand Ave	Brooklyn	EJZ	12,623 GSF	Poor	> 20 years		
35	Solar-Ready	BPL	Eastern Parkway Branch Library and Learning Center	1044 Eastern Pkwy	Brooklyn	EJZ	16,024 GSF	Good	< 2 years		
35	Not Solar-Ready	DHS	BRC Women's Shelter	85 Lexington Ave	Brooklyn		17,000 GSF	Good	Unknown		
35	Not Solar-Ready	BPL	Bedford Branch Library and Learning Center	496 Franklin Ave	Brooklyn	EJZ	17,184 GSF	Between Fair and Poor	> 20 years		
35	Solar-Ready	DOE	K813	355 PARK PLACE	Brooklyn		17,340 GSF	Between Good and Fair	5 to 9 years		
35	Not Solar-Ready	NYPD	88th Precinct	298 Classon Ave	Brooklyn	EJZ	18,600 GSF	Unknown	15 to 19 years		
35	Not Solar-Ready	DCLA	Brooklyn Botanic Garden Palm House	1000 Washington Ave	Brooklyn		21,000 GSF	Good	Unknown		
35	Not Solar-Ready	DCLA	Visitor Center	1000 Washington Ave	Brooklyn		21,000 GSF	Good	Unknown		
35	Not Solar-Ready	NYPD	71st Precinct	421 Empire Blvd	Brooklyn	EJZ	24,300 GSF	Good	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
35	Not Solar-Ready	DOE	K874	227 STERLING PLACE	Brooklyn		25,715 GSF	Between Good and Fair	10 to 14 years		
35	Not Solar-Ready	NYPD	78th Precinct	65 6th Ave	Brooklyn		34,500 GSF	Between Fair and Poor	Unknown		
35	Not Solar-Ready	DOHMH	Fort Greene Health Center	295 Flatbush Ave Ext	Brooklyn		41,800 GSF	Good	10 to 14 years		
35	Not Solar-Ready	DCLA	Brooklyn Botanic Garden Service Garage	1000 Washington Ave	Brooklyn		42,000 GSF	Good	Unknown		
35	Solar-Ready	DCLA	Brooklyn Academy of Music (BAM Richard B. Fisher Building)	321 Ashland Pl	Brooklyn		42,022 GSF	Good	5 to 9 years		
35	Solar-Ready	DCLA	Brooklyn Botanic Garden Administrative Building	1000 Washington Ave	Brooklyn		43,600 GSF	Good	5 to 9 years		
35	Not Solar-Ready	DCLA	Comfort Station	1000 Washington Ave	Brooklyn		45,000 GSF	Unknown	Unknown		
35	Not Solar-Ready	NYPD	84th Precinct (and Engine Company 207)	301 Gold St	Brooklyn		50,000 GSF	Between Fair and Poor	10 to 14 years		
35	Not Solar-Ready	DOE	K824	402 EASTERN PKWY.	Brooklyn	EJZ	57,580 GSF	Fair	> 20 years		
35	Not Solar-Ready	DOE	K085	510 CLERMONT AVE.	Brooklyn	EJZ	61,200 GSF	Fair	15 to 19 years		
35	Solar-Ready	DCLA	Brooklyn Botanic Garden Conservatory	1000 Washington Ave	Brooklyn		70,000 GSF	Good	< 2 years		
35	Not Solar-Ready	DOE	K241	976 PRESIDENT STREET	Brooklyn	EJZ	79,453 GSF	Fair	15 to 19 years		
35	Not Solar-Ready	DOE	K270	241 EMERSON PLACE	Brooklyn	EJZ	86,400 GSF	Fair	> 20 years		
35	Not Solar-Ready	DOE	K167	1025 EASTERN PKWY	Brooklyn	EJZ	90,000 GSF	Under construction	Under construction		
35	Not Solar-Ready	DOE	K161	330 CROWN STREET	Brooklyn	EJZ	93,600 GSF	Between Fair and Poor	15 to 19 years		
35	Not Solar-Ready	DCLA	BAM Harvey Theater (Majestic Theater)	651 Fulton St	Brooklyn		94,765 GSF	Fair	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
35	Not Solar-Ready	DOE	K011	419 WAVERLY AVENUE	Brooklyn		99,600 GSF	Fair	15 to 19 years		
35	Not Solar-Ready	DOE	K316	750 CLASSON AVENUE	Brooklyn		99,600 GSF	Poor	> 20 years		
35	Not Solar-Ready	DOE	K056	170 GATES AVENUE	Brooklyn	EJZ	100,800 GSF	Between Fair and Poor	> 20 years		
35	Solar-Ready	DOE	K287	50 NAVY STREET	Brooklyn	EJZ	106,800 GSF	Between Good and Fair	5 to 9 years		
35	Solar-Ready	DOE	K020	225 ADELPHI STREET	Brooklyn		110,400 GSF	Good	2 to 4 years		
35	Not Solar-Ready	DCAS	Brooklyn Armory	1579 Bedford Ave	Brooklyn	EJZ	116,900 GSF	Fair	> 20 years		
35	Not Solar-Ready	DOE	K590	1186 CARROLL	Brooklyn	EJZ	126,000 GSF	Fair	15 to 19 years		
35	Not Solar-Ready	DOE	K067	51 SAINT EDWARDS STREET	Brooklyn	EJZ	138,125 GSF	Between Good and Fair	10 to 14 years		
35	Not Solar-Ready	DOE	K009	80 UNDERHILL AVENUE	Brooklyn		139,200 GSF	Between Fair and Poor	> 20 years		
35	Not Solar-Ready	HHC	Cumberland Diagnostic and Treatment Center	100 North Portland Ave	Brooklyn	EJZ	154,800 GSF	Between Fair and Poor	Unknown		
35	Solar-Ready	DHS	Atlantic Avenue Men's Shelter (Armory)	1322 Bedford Ave	Brooklyn	EJZ	164,320 GSF	Good	2 to 4 years		
35	Not Solar-Ready	DOE	K265	101 PARK AVENUE	Brooklyn	EJZ	166,800 GSF	Fair	> 20 years		
35	Not Solar-Ready	DCLA	BAM Peter Jay Sharp Theater (Opera House)	30 Lafayette Ave	Brooklyn		170,000 GSF	Between Good and Fair	10 to 14 years		
35	Not Solar-Ready	DOE	K113	300 ADELPHI STREET	Brooklyn		176,400 GSF	Fair	> 20 years		
35	Not Solar-Ready	DOE	K320	46 MCKEEVER PLACE	Brooklyn	EJZ	189,600 GSF	Fair	> 20 years		
35	Solar-Ready	DHS	Auburn Family Residence	39 Auburn Place	Brooklyn	EJZ	198,000 GSF	Good	5 to 9 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
35	Solar-Ready	DOE	K805	49 FLATBUSH AVE. EXT.	Brooklyn		207,775 GSF	Good	2 to 4 years		
35	Solar-Ready	DOE	K600	901 CLASSON AVE	Brooklyn	EJZ	240,000 GSF	Good	< 2 years		
35	Not Solar-Ready	DOE	K440	883 CLASSON AVE.	Brooklyn	EJZ	324,000 GSF	Under construction	Under construction		
35	Solar-Ready	BPL	Central Library and Learning Center	10 Grand Army Plz	Brooklyn		350,000 GSF	Good	< 2 years		
35	Not Solar-Ready	DCLA	Brooklyn Museum	188 Eastern Pkwy	Brooklyn		554,736 GSF	Between Good and Fair	> 20 years		
35	Solar-Ready	DOE	K430	29 FORT GREENE PL.	Brooklyn		712,800 GSF	Between Good and Fair	5 to 9 years		
36	Not Solar-Ready	BPL	Macon Branch Library	361 Lewis Ave	Brooklyn	EJZ	10,540 GSF	Unknown	Unknown		
36	Not Solar-Ready	DOE	K867	960 PROSPECT PLACE	Brooklyn	EJZ	10,800 GSF	Fair	15 to 19 years		
36	Solar-Ready	DOE	K853	234 HERKIMER STREET	Brooklyn	EJZ	13,200 GSF	Fair	5 to 9 years		
36	Not Solar-Ready	DPR	Kosciuszko Pool House	670 Marcy Ave	Brooklyn	EJZ	13,400 GSF	Fair	> 20 years		
36	Not Solar-Ready	HRA	DeKalb Avenue Residence	970-972 Dekalb Ave	Brooklyn	EJZ	14,720 GSF	Between Good and Fair	Unknown		
36	Not Solar-Ready	DOHMH	Crown Heights Health Center	1218 Prospect Pl	Brooklyn	EJZ	15,805 GSF	Unknown	15 to 19 years		
36	Not Solar-Ready	HRA	Safe Star - Transitional Housing	217-223 Hart St	Brooklyn	EJZ	30,720 GSF	Fair	> 20 years		
36	Not Solar-Ready	DSNY	Brooklyn North 8 District Garage	1760 Atlantic Ave	Brooklyn	EJZ	31,000 GSF	Poor	> 20 years		
36	Not Solar-Ready	NYPD	79th Precinct	263 Tompkins Ave	Brooklyn	EJZ	33,540 GSF	Good	10 to 14 years		
36	Solar-Ready	DPR	St. Johns Recreation Center	1251 Prospect Pl	Brooklyn	EJZ	35,736 GSF	Good	2 to 4 years		Green Roof
36	Not Solar-Ready	DOHMH	Bedford Health Center	485 Throop Ave	Brooklyn	EJZ	37,766 GSF	Unknown	15 to 19 years		
36	Not Solar-Ready	NYPD	77th Precinct	127 Utica Ave	Brooklyn	EJZ	45,102 GSF	Unknown	10 to 14 years		
36	Not Solar-Ready	DOE	K308	616 QUINCY STREET	Brooklyn	EJZ	70,800 GSF	Fair	> 20 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
36	Not Solar-Ready	DOE	K743	475 NOSTRAND AVE	Brooklyn	EJZ	86,575 GSF	Poor	> 20 years		
36	Not Solar-Ready	DOE	K093	31 NEW YORK AVENUE	Brooklyn	EJZ	92,400 GSF	Fair	> 20 years		
36	Not Solar-Ready	DOE	K297	700 PARK AVENUE	Brooklyn	EJZ	94,800 GSF	Fair	> 20 years		
36	Not Solar-Ready	DOE	K262	500 MACON STREET	Brooklyn	EJZ	98,400 GSF	Between Good and Fair	15 to 19 years		
36	Solar-Ready	DOE	K003	50 JEFFERSON AVE.	Brooklyn	EJZ	100,800 GSF	Between Good and Fair	5 to 9 years	Yes	
36	Not Solar-Ready	DOE	K148	185 ELLERY ST.	Brooklyn	EJZ	104,400 GSF	Fair	15 to 19 years		
36	Not Solar-Ready	DOE	K256	114 KOSCIUSKO STREET	Brooklyn	EJZ	106,800 GSF	Between Good and Fair	> 20 years		
36	Not Solar-Ready	DOE	K305	344 MONROE STREET	Brooklyn	EJZ	106,800 GSF	Fair	> 20 years		
36	Not Solar-Ready	DOE	K021	180 CHAUNCEY STREET	Brooklyn	EJZ	109,200 GSF	Fair	> 20 years		
36	Not Solar-Ready	DOE	K304	280 HART STREET	Brooklyn	EJZ	109,200 GSF	Under construction	Under construction		
36	Not Solar-Ready	DOE	K243	1580 DEAN STREET	Brooklyn	EJZ	110,400 GSF	Fair	> 20 years		
36	Not Solar-Ready	DOE	K059	211 THROOP AVENUE	Brooklyn	EJZ	115,200 GSF	Fair	15 to 19 years		
36	Not Solar-Ready	DOE	K289	900 ST. MARKS AVENUE	Brooklyn	EJZ	115,200 GSF	Fair	10 to 14 years		
36	Solar-Ready	DOE	K023	545 WILLOUGHBY AVENUE	Brooklyn	EJZ	117,600 GSF	Fair	5 to 9 years		
36	Not Solar-Ready	DOE	K025	787 LAFAYETTE AVENUE	Brooklyn	EJZ	122,400 GSF	Under construction	Under construction	Yes	

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
36	Solar-Ready	DOE	K210	188 ROCHESTER AVENUE	Brooklyn	EJZ	129,600 GSF	Between Good and Fair	5 to 9 years	Yes	
36	Not Solar-Ready	DOE	K081	990 DEKALB AVENUE	Brooklyn	EJZ	130,800 GSF	Fair	15 to 19 years		
36	Not Solar-Ready	DOE	K035	272 MACDONOUGH STREET	Brooklyn	EJZ	135,600 GSF	Under construction	Under construction		
36	Not Solar-Ready	DOE	K258	141 MACON STREET	Brooklyn	EJZ	170,400 GSF	Fair	> 20 years		
36	Not Solar-Ready	DOE	K033	70 TOMPKINS AVENUE	Brooklyn	EJZ	175,200 GSF	Fair	15 to 19 years		
36	Not Solar-Ready	DOE	K625	150 ALBANY AVE	Brooklyn	EJZ	175,200 GSF	Under construction	Under construction		
36	Not Solar-Ready	DOE	K138	760 Prospect Place	Brooklyn	EJZ	177,600 GSF	Between Fair and Poor	> 20 years		
36	Not Solar-Ready	DOE	K390	1224 PARK PLACE	Brooklyn	EJZ	180,000 GSF	Fair	10 to 14 years		
36	Not Solar-Ready	DOE	K458	832 MARCY AVE	Brooklyn	EJZ	213,600 GSF	Fair	> 20 years		
36	Not Solar-Ready	DHS	Pamoja House Shelter	357 Sumner Ave	Brooklyn	EJZ	235,200 GSF	Fair	> 20 years		
36	Not Solar-Ready	HHC	Woodhull Medical and Mental Health Center	760 Broadway	Brooklyn		1,071,600 GSF	Between Fair and Poor	> 20 years		
37	Not Solar-Ready	FDNY	Engine Co. 271 and Ladder Co. 124, Batt. 28	392 Himrod St	Brooklyn		13,108 GSF	Between Fair and Poor	> 20 years		
37	Not Solar-Ready	FDNY	Engine Co. 233 and Ladder Co. 176	25 Rockaway Ave	Brooklyn	EJZ	13,519 GSF	Between Fair and Poor	15 to 19 years		
37	Not Solar-Ready	FDNY	Engine Co. 277 and Ladder Co. 112	582 Knickerbocker Ave	Brooklyn	EJZ	15,000 GSF	Between Fair and Poor	> 20 years		
37	Not Solar-Ready	NYPD	Brooklyn North Boro Command	179 Wilson Ave	Brooklyn	EJZ	15,205 GSF	Between Fair and Poor	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
37	Solar-Ready	BPL	Arlington Branch Library	203 Arlington Ave	Brooklyn	EJZ	16,385 GSF	Good	< 2 years		
37	Not Solar-Ready	ACS	Labor and Industry for Education Inc.	1375 Bushwick Ave	Brooklyn	EJZ	27,100 GSF	Poor	Unknown		
37	Not Solar-Ready	DHS	Bushwick Family Residence	1675 Broadway	Brooklyn	EJZ	27,528 GSF	Fair	15 to 19 years		
37	Solar-Ready	NYPD	Facilities Management Division	127 Pennsylvania Ave	Brooklyn	EJZ	29,940 GSF	Good	5 to 9 years		
37	Not Solar-Ready	NYPD	83rd Precinct	480 Knickerbocker Ave	Brooklyn	EJZ	31,729 GSF	Between Fair and Poor	10 to 14 years		
37	Not Solar-Ready	DOHMH	Bushwick Health Center	335 Central Ave	Brooklyn	EJZ	35,640 GSF	Unknown	> 20 years		
37	Solar-Ready	DOE	K086	220 IRVING AVENUE	Brooklyn	EJZ	44,400 GSF	Good	2 to 4 years		
37	Not Solar-Ready	HRA	Bushwick Multi Service Center	1420 Bushwick Ave	Brooklyn	EJZ	52,000 GSF	Between Good and Fair	> 20 years		
37	Not Solar-Ready	DHS	HELP Women's Center Shelter	116 Williams Ave	Brooklyn	EJZ	55,976 GSF	Fair	15 to 19 years		
37	Not Solar-Ready	DOE	K116	515 KNICKERBOCKER AVENUE	Brooklyn		60,000 GSF	Good	15 to 19 years		
37	Not Solar-Ready	NYPD	Brooklyn North Narcotics	245 Glenmore Ave	Brooklyn	EJZ	60,000 GSF	Poor	Unknown		
37	Solar-Ready	DOE	K814	265 WARWICK	Brooklyn	EJZ	61,075 GSF	Good	5 to 9 years		
37	Solar-Ready	DOE	K151	763 KNICKERBOCKER AVENUE	Brooklyn	EJZ	67,200 GSF	Fair	5 to 9 years		
37	Not Solar-Ready	DOE	K290	135 SCHENCK AVENUE	Brooklyn	EJZ	74,022 GSF	Under construction	Under construction		
37	Not Solar-Ready	DOE	K108	200 LINWOOD STREET	Brooklyn		78,000 GSF	Between Good and Fair	15 to 19 years		
37	Not Solar-Ready	DOE	K155	1355 HERKIMER STREET	Brooklyn	EJZ	81,600 GSF	Fair	10 to 14 years	Yes	

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
37	Solar-Ready	DOE	K073	251 MAC DOUGAL STREET	Brooklyn	EJZ	90,000 GSF	Good	< 2 years		
37	Not Solar-Ready	DOE	K376	194 HARMAN STREET	Brooklyn	EJZ	90,100 GSF	Between Good and Fair	> 20 years		
37	Not Solar-Ready	DOE	K106	1328 PUTNAM AVENUE	Brooklyn	EJZ	99,600 GSF	Between Fair and Poor	15 to 19 years		
37	Not Solar-Ready	DOE	K158	400 ASHFORD STREET	Brooklyn	EJZ	102,000 GSF	Fair	15 to 19 years		
37	Not Solar-Ready	DOE	K171	528 RIDGEWOOD AVENUE	Brooklyn	EJZ	103,200 GSF	Under construction	Under construction		
37	Solar-Ready	DOE	K798	696 JAMAICA AVENUE	Brooklyn	EJZ	105,825 GSF	Between Good and Fair	5 to 9 years		
37	Solar-Ready	DOE	K345	111 BERRIMAN STREET	Brooklyn	EJZ	108,000 GSF	Between Good and Fair	5 to 9 years		
37	Not Solar-Ready	DOE	K007	858 JAMAICA AVE.	Brooklyn	EJZ	110,515 GSF	Between Fair and Poor	15 to 19 years		
37	Solar-Ready	DOE	K377	200 WOODBINE STREET	Brooklyn	EJZ	126,000 GSF	Good	< 2 years		
37	Not Solar-Ready	DOE	K045	84 SCHAEFER STREET	Brooklyn	EJZ	141,600 GSF	Fair	10 to 14 years		
37	Not Solar-Ready	DOE	K384	242 COOPER STREET	Brooklyn	EJZ	147,600 GSF	Between Good and Fair	> 20 years		
37	Not Solar-Ready	DOE	K660	145 PENNSYLVANIA AVE.	Brooklyn	EJZ	180,000 GSF	Between Good and Fair	10 to 14 years		
37	Not Solar-Ready	DOE	K296	125 COVERT STREET	Brooklyn	EJZ	188,400 GSF	Between Good and Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
37	Not Solar-Ready	DOE	K383	1300 GREENE AVENUE	Brooklyn	EJZ	211,200 GSF	Fair	15 to 19 years		
37	Not Solar-Ready	DOE	K615	1 WELLS STREET	Brooklyn	EJZ	212,400 GSF	Fair	> 20 years		
37	Not Solar-Ready	DOE	K480	400 IRVING AVE.	Brooklyn	EJZ	242,400 GSF	Under construction	Under construction	Yes	
37	Not Solar-Ready	DOE	K291	231 PALMETTO STREET	Brooklyn	EJZ	247,200 GSF	Fair	15 to 19 years		
38	Not Solar-Ready	FDNY	Engine Co. 279 and Ladder Co. 131	252 Lorraine St	Brooklyn	EJZ	10,548 GSF	Unknown	10 to 14 years		
38	Not Solar-Ready	BPL	Sunset Park Branch Library	5108 4th Ave	Brooklyn	EJZ	12,174 GSF	Between Fair and Poor	15 to 19 years		
38	Not Solar-Ready	NYPD	Harbor Unit Charlie	140 58th St Dock	Brooklyn		16,000 GSF	Between Fair and Poor	Unknown		
38	Not Solar-Ready	DPR	Sunset Park Recreation Center and Pool House	4213-4215 7th Ave	Brooklyn		17,000 GSF	Fair	> 20 years		
38	Not Solar-Ready	FDNY	Engine Co. 201 and Ladder 114, Batt. 40	5113 4th Ave	Brooklyn	EJZ	17,772 GSF	Unknown	> 20 years		
38	Not Solar-Ready	DOE	K231	360 36 STREET	Brooklyn	EJZ	26,400 GSF	Between Good and Fair	10 to 14 years		
38	Not Solar-Ready	DOT	Hamilton Ave Asphalt Plant	448 Hamilton Ave	Brooklyn		31,302 GSF	Poor	15 to 19 years		
38	Not Solar-Ready	NYPD	42nd Street Warehouse	234 41st St	Brooklyn	EJZ	31,569 GSF	Good	> 20 years		
38	Solar-Ready	DOE	K971	6214 4TH AVE.	Brooklyn	EJZ	36,300 GSF	Between Good and Fair	5 to 9 years		
38	Solar-Ready	NYPD	68th Precinct	333 65th St	Brooklyn		39,050 GSF	Good	5 to 9 years		
38	Not Solar-Ready	NYPD	Applicant Processing Division	4201 4th Ave	Brooklyn	EJZ	44,625 GSF	Good	Unknown		
38	Not Solar-Ready	NYPD	72nd Precinct	830 4th Ave	Brooklyn	EJZ	53,600 GSF	Good	15 to 19 years		
38	Not Solar-Ready	DOE	K172	825 4TH AVE.	Brooklyn	EJZ	56,400 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
38	Not Solar-Ready	NYPD	Marine Terminal Storage	23rd St	Brooklyn		64,811 GSF	Poor	Unknown		
38	Solar-Ready	DOE	K371	355 37 STREET	Brooklyn	EJZ	80,400 GSF	Between Good and Fair	5 to 9 years		
38	Not Solar-Ready	DSNY	Brooklyn South 7 and 10 District Garage	5100 1st Ave	Brooklyn		81,268 GSF	Between Fair and Poor	> 20 years	Yes	
38	Not Solar-Ready	DOE	K010	511 7TH AVE.	Brooklyn		92,400 GSF	Fair	15 to 19 years		
38	Solar-Ready	DOE	K486	1171 65TH STREET	Brooklyn	EJZ	93,600 GSF	Good	2 to 4 years		
38	Not Solar-Ready	DOE	K015	71 SULLIVAN STREET	Brooklyn	EJZ	96,000 GSF	Between Good and Fair	> 20 years		
38	Not Solar-Ready	DOE	K845	330 18 STREET	Brooklyn	EJZ	102,125 GSF	Fair	15 to 19 years		
38	Not Solar-Ready	DOE	K027	27 Huntington St	Brooklyn		110,400 GSF	Fair	> 20 years		
38	Not Solar-Ready	DOE	K024	435 38 STREET	Brooklyn	EJZ	110,400 GSF	Between Good and Fair	> 20 years		
38	Not Solar-Ready	DOE	K069	6302 9TH AVENUE	Brooklyn	EJZ	110,400 GSF	Between Good and Fair	15 to 19 years		
38	Not Solar-Ready	DSNY	Hamilton Avenue Marine Transfer Station	500 Hamilton Ave	Brooklyn		110,946 GSF	Between Fair and Poor	Unknown		
38	Not Solar-Ready	DOE	K169	4305 7TH AVE.	Brooklyn	EJZ	123,600 GSF	Fair	> 20 years		
38	Not Solar-Ready	DOE	K105	1031 59 STREET	Brooklyn	EJZ	130,800 GSF	Poor	15 to 19 years	Yes	
38	Solar-Ready	DOE	K220	4812 9TH AVE.	Brooklyn	EJZ	130,800 GSF	Good	2 to 4 years		
38	Not Solar-Ready	DOE	K136	4004 4TH AVENUE	Brooklyn	EJZ	136,300 GSF	Fair	> 20 years		
38	Not Solar-Ready	DOE	K227	6500 16TH AVE.	Brooklyn	EJZ	146,400 GSF	Poor	> 20 years		
38	Not Solar-Ready	DOE	K088	544 7TH AVENUE	Brooklyn	EJZ	170,400 GSF	Fair	15 to 19 years	Yes	
38	Not Solar-Ready	DOE	K314	330 59 STREET	Brooklyn	EJZ	176,400 GSF	Fair	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
38	Solar-Ready	DOE	K564	153 35TH STREET	Brooklyn	EJZ	188,400 GSF	Between Good and Fair	5 to 9 years		
39	Not Solar-Ready	DPR	Litchfield Villa	95 Prospect Park West	Brooklyn		12,000 GSF	Fair	> 20 years		
39	Not Solar-Ready	FDNY	Engine Co. 282 and Ladder Co. 148	4210 12th Ave	Brooklyn	EJZ	13,756 GSF	Unknown	15 to 19 years		
39	Not Solar-Ready	BPL	Carroll Gardens Branch Library	396 Clinton St	Brooklyn		14,779 GSF	Between Fair and Poor	15 to 19 years		
39	Not Solar-Ready	NYPD	76th Precinct	191 Union St	Brooklyn		14,984 GSF	Good	> 20 years		
39	Not Solar-Ready	BPL	Pacific Branch Library	25 4th Ave	Brooklyn	EJZ	15,758 GSF	Unknown	Unknown		
39	Solar-Ready	BPL	Park Slope Branch Library	431 6th Ave	Brooklyn		15,868 GSF	Good	2 to 4 years		
39	Not Solar-Ready	BPL	Borough Park Branch Library	1265 43rd St	Brooklyn	EJZ	19,594 GSF	Between Fair and Poor	> 20 years		
39	Not Solar-Ready	DOE	K781	1053 41ST STREET	Brooklyn	EJZ	27,660 GSF	Fair	10 to 14 years	Yes	
39	Solar-Ready	DOE	K039	417 6TH AVENUE	Brooklyn		31,200 GSF	Good	2 to 4 years		
39	Solar-Ready	DPR	Prospect Park Maintenance Facility	Prospect Park West at 7th st	Brooklyn		34,100 GSF	Good	2 to 4 years		Green Roof
39	Not Solar-Ready	DOE	K124	515 4TH AVENUE	Brooklyn		39,600 GSF	Between Fair and Poor	> 20 years		
39	Not Solar-Ready	DPR	Prospect Park Zoo	450 Flatbush Ave	Brooklyn		47,600 GSF	Fair	15 to 19 years		
39	Not Solar-Ready	DPR	LeFrak Center at Lakeside, Recreation Center and Ice Rink	171 East Dr	Brooklyn		48,590 GSF	Fair	> 20 years		
39	Solar-Ready	DOE	K154	1625 11th Ave	Brooklyn		52,800 GSF	Good	2 to 4 years		
39	Not Solar-Ready	DOE	K130	70 OCEAN PARKWAY	Brooklyn		60,000 GSF	Poor	15 to 19 years		
39	Solar-Ready	DSNY	Brooklyn South 6 District Garage	129 2nd Ave	Brooklyn		66,000 GSF	Good	5 to 9 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
39	Not Solar-Ready	DOE	K230	1 ALBEMARLE ROAD	Brooklyn	EJZ	87,440 GSF	Fair	15 to 19 years		
39	Not Solar-Ready	DOE	K179	202 AVENUE C	Brooklyn	EJZ	87,946 GSF	Fair	15 to 19 years		
39	Solar-Ready	DOE	K077	62 PARK PLACE	Brooklyn		92,480 GSF	Good	< 2 years		
39	Solar-Ready	DOE	K029	425 HENRY STREET	Brooklyn		93,600 GSF	Good	2 to 4 years		
39	Not Solar-Ready	DOE	K321	180 7TH AVENUE	Brooklyn		103,109 GSF	Between Fair and Poor	> 20 years		
39	Not Solar-Ready	DOE	K131	4305 FT HAMILTON PKWY	Brooklyn	EJZ	103,200 GSF	Under construction	Under construction		
39	Not Solar-Ready	DOE	K282	180 6TH AVENUE	Brooklyn	EJZ	104,400 GSF	Fair	15 to 19 years		
39	Not Solar-Ready	DHS	Park Slope Armory Shelter	1402 8th Ave	Brooklyn		109,556 GSF	Fair	> 20 years		
39	Not Solar-Ready	DOE	K051	350 5TH AVENUE	Brooklyn		135,600 GSF	Fair	15 to 19 years		
39	Solar-Ready	DOE	K142	610 HENRY STREET	Brooklyn		165,600 GSF	Good	5 to 9 years	Yes	
39	Not Solar-Ready	DOE	K460	237 SEVENTH AVE	Brooklyn		314,400 GSF	Between Fair and Poor	10 to 14 years		
40	Not Solar-Ready	FDNY	Engine Co. 281 and Ladder Co. 147	1210 Cortelyou Rd	Brooklyn	EJZ	10,106 GSF	Between Fair and Poor	15 to 19 years		
40	Not Solar-Ready	NYPD	BSTF	397 Coney Island Ave	Brooklyn		14,300 GSF	Between Good and Fair	15 to 19 years		
40	Not Solar-Ready	DOE	K877	35 SNYDER AVENUE	Brooklyn	EJZ	21,660 GSF	Fair	15 to 19 years		
40	Solar-Ready	BPL	Flatbush Branch Library and Learning Center	22 Linden Blvd	Brooklyn	EJZ	21,790 GSF	Good	< 2 years		
40	Not Solar-Ready	HHC	Kings County Hospital Building Z	604 Wintrop St	Brooklyn	EJZ	25,215 GSF	Between Good and Fair	> 20 years		
40	Not Solar-Ready	DSNY	Brooklyn North 9 District Garage	690 New York Ave	Brooklyn	EJZ	25,725 GSF	Unknown	Unknown		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
40	Not Solar-Ready	DOE	K397	490 FENIMORE STREET	Brooklyn	EJZ	38,400 GSF	Between Good and Fair	10 to 14 years		
40	Not Solar-Ready	DOE	K399	2707 ALBEMARLE ROAD	Brooklyn	EJZ	38,400 GSF	Between Good and Fair	> 20 years		
40	Not Solar-Ready	OCME	Chief Medical Examiner	599 Winthrop St	Brooklyn	EJZ	40,950 GSF	Good	10 to 14 years		
40	Not Solar-Ready	HHC	Kings County Hospital Food Service	599 Kingston Ave	Brooklyn	EJZ	50,000 GSF	Between Good and Fair	> 20 years		
40	Not Solar-Ready	HHC	Kings County Hospital Support Office	591 Kingston Ave	Brooklyn	EJZ	50,000 GSF	Between Good and Fair	10 to 14 years		
40	Not Solar-Ready	NYPD	67th Precinct and Engine Company 248	2820 Snyder Ave	Brooklyn	EJZ	54,056 GSF	Between Fair and Poor	5 to 9 years		
40	Solar-Ready	DOE	K245	249 E. 17TH STREET	Brooklyn	EJZ	61,710 GSF	Fair	5 to 9 years		
40	Not Solar-Ready	HHC	Kings County Hospital Building K	648 Albany Ave	Brooklyn	EJZ	61,915 GSF	Between Good and Fair	> 20 years		
40	Not Solar-Ready	DOE	K006	43 SNYDER AVE.	Brooklyn	EJZ	81,600 GSF	Fair	> 20 years		
40	Not Solar-Ready	DOE	K139	330 RUGBY RD.	Brooklyn	EJZ	108,000 GSF	Between Good and Fair	10 to 14 years		
40	Not Solar-Ready	DOE	K246	72 VERONICA PLACE	Brooklyn	EJZ	129,665 GSF	Fair	> 20 years		
40	Solar-Ready	DOE	K217	1100 NEWKIRK AVE.	Brooklyn		132,000 GSF	Between Good and Fair	5 to 9 years		
40	Not Solar-Ready	HHC	Kings County Hospital Central Laundry	645 Kingston Ave	Brooklyn	EJZ	132,355 GSF	Fair	> 20 years		
40	Solar-Ready	DOE	K092	601 PARKSIDE AVENUE	Brooklyn	EJZ	134,400 GSF	Fair	5 to 9 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
40	Solar-Ready	DOE	K249	18 MARLBOROUGH ROAD	Brooklyn	EJZ	138,240 GSF	Good	2 to 4 years		
40	Not Solar-Ready	DOE	K141	655 PARKSIDE AVENUE	Brooklyn	EJZ	157,200 GSF	Fair	> 20 years		
40	Not Solar-Ready	DOE	K062	700 CORTELYOU ROAD	Brooklyn		159,600 GSF	Fair	15 to 19 years		
40	Not Solar-Ready	DOE	K061	400 EMPIRE BOULEVARD	Brooklyn	EJZ	168,000 GSF	Between Fair and Poor	> 20 years		
40	Not Solar-Ready	HHC	Dr. Susan Smity McKinney Nursing and Rehabilitation Center	594 Albany Ave	Brooklyn	EJZ	175,193 GSF	Between Good and Fair	> 20 years		
40	Not Solar-Ready	HHC	Kings County Hospital Building T	689 New York Ave	Brooklyn	EJZ	218,710 GSF	Fair	> 20 years		
40	Not Solar-Ready	DOE	K465	911 FLATBUSH AVENUE	Brooklyn	EJZ	460,800 GSF	Fair	15 to 19 years		
40	Solar-Ready	DOE	K470	600 KINGSTON AVE.	Brooklyn	EJZ	540,672 GSF	Between Good and Fair	5 to 9 years	Yes	
40	Solar-Ready	HHC	Kings County Hospital Buildings A, B, C	451 Clarkson Ave	Brooklyn	EJZ	658,920 GSF	Between Good and Fair	5 to 9 years		
41	Not Solar-Ready	BPL	Saratoga Branch Library	8 Thomas S. Boyland St	Brooklyn	EJZ	10,040 GSF	Unknown	Unknown		
41	Not Solar-Ready	BPL	Brownsville Branch Library	61 Glenmore Ave	Brooklyn	EJZ	10,838 GSF	Between Fair and Poor	< 2 years		
41	Not Solar-Ready	FDNY	Engine Co. 283 and Division 15	885 Howard Ave	Brooklyn	EJZ	11,898 GSF	Unknown	15 to 19 years		
41	Not Solar-Ready	BPL	Stone Avenue Branch Library	581 Mother Gaston Blvd	Brooklyn	EJZ	14,258 GSF	Unknown	2 to 4 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
41	Not Solar-Ready	DPR	Betsy Head Pool House	694 Thomas S Boyland St	Brooklyn	EJZ	15,000 GSF	Fair	15 to 19 years		
41	Not Solar-Ready	DOHMH	Brownsville Health Center	259 Bristol St	Brooklyn	EJZ	32,472 GSF	Unknown	10 to 14 years		
41	Solar-Ready	DOE	K135	684 LINDEN BLVD	Brooklyn	EJZ	34,800 GSF	Good	5 to 9 years		
41	Not Solar-Ready	NYPD	81st Precinct (and Engine Company 222)	30 Ralph Ave	Brooklyn	EJZ	39,700 GSF	Good	> 20 years		
41	Solar-Ready	HRA	Brownsville Multi Service Center	444 Thomas Boyland St	Brooklyn	EJZ	43,726 GSF	Between Good and Fair	5 to 9 years		
41	Not Solar-Ready	NYPD	73rd Precinct	1470 East New York Ave	Brooklyn	EJZ	50,020 GSF	Between Good and Fair	10 to 14 years		
41	Not Solar-Ready	DOE	K137	121 SARATOGA AVENUE	Brooklyn	EJZ	55,200 GSF	Between Good and Fair	10 to 14 years		
41	Solar-Ready	DHS	East New York Ave SRO Residence	1385 East New York Ave	Brooklyn	EJZ	60,000 GSF	Between Good and Fair	5 to 9 years		
41	Not Solar-Ready	DOE	K396	110 CHESTER STREET	Brooklyn	EJZ	85,800 GSF	Fair	15 to 19 years		
41	Not Solar-Ready	DOE	K268	133 EAST 53RD STREET	Brooklyn	EJZ	86,067 GSF	Fair	15 to 19 years		
41	Not Solar-Ready	DOE	K191	1600 PARK PLACE	Brooklyn	EJZ	86,400 GSF	Under construction	Under construction	Yes	
41	Solar-Ready	DOE	K091	532 ALBANY AVENUE	Brooklyn	EJZ	88,615 GSF	Between Good and Fair	5 to 9 years		
41	Not Solar-Ready	DOE	K178	1784 PARK PLACE	Brooklyn	EJZ	93,600 GSF	Under construction	Under construction		
41	Not Solar-Ready	DOE	K012	430 Howard Ave	Brooklyn	EJZ	97,200 GSF	Fair	> 20 years		
41	Not Solar-Ready	DOE	K175	226 BRISTOL ST.	Brooklyn	EJZ	106,800 GSF	Fair	> 20 years		
41	Solar-Ready	DOE	K309	794 MONROE STREET	Brooklyn	EJZ	106,800 GSF	Between Good and Fair	5 to 9 years	Yes	

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
41	Not Solar-Ready	DOE	K189	1100 EAST NEW YORK AVENUE	Brooklyn	EJZ	107,749 GSF	Fair	15 to 19 years		
41	Solar-Ready	DOE	K005	820 HANCOCK STREET	Brooklyn	EJZ	108,000 GSF	Between Good and Fair	5 to 9 years	Yes	
41	Not Solar-Ready	DOE	K252	1084 Lenox Rd	Brooklyn	EJZ	110,400 GSF	Under construction	Under construction		
41	Not Solar-Ready	DOE	K284	213 Osborn St	Brooklyn	EJZ	110,400 GSF	Poor	15 to 19 years	Yes	
41	Not Solar-Ready	DOE	K219	1060 CLARKSON AVE.	Brooklyn	EJZ	112,800 GSF	Fair	> 20 years		
41	Not Solar-Ready	HRA	Bedford Multi Service Center	1958 Fulton St	Brooklyn	EJZ	113,668 GSF	Between Fair and Poor	> 20 years		
41	Not Solar-Ready	DOE	K150	364 SACKMAN STREET	Brooklyn	EJZ	114,000 GSF	Fair	10 to 14 years		
41	Solar-Ready	DOE	K232	905 WINTHROP STREET	Brooklyn	EJZ	117,120 GSF	Fair	5 to 9 years	Yes	
41	Solar-Ready	DOE	K391	790 EAST NEW YORK AVENUE	Brooklyn	EJZ	120,520 GSF	Between Good and Fair	10 to 14 years	Yes	
41	Not Solar-Ready	DOE	K040	265 RALPH AVENUE	Brooklyn	EJZ	121,200 GSF	Fair	10 to 14 years		
41	Solar-Ready	DHS	Dean Street Family Residence	2155 Dean Street	Brooklyn	EJZ	124,500 GSF	Good	5 to 9 years		
41	Not Solar-Ready	DOE	K323	210 CHESTER STREET	Brooklyn	EJZ	157,200 GSF	Between Good and Fair	> 20 years		
41	Not Solar-Ready	DOE	K356	104 SUTTER AVENUE	Brooklyn	EJZ	187,200 GSF	Fair	15 to 19 years		
41	Not Solar-Ready	DOE	K055	2021 BERGEN STREET	Brooklyn	EJZ	196,800 GSF	Fair	15 to 19 years		
41	Not Solar-Ready	ACS	Crossroads Juvenile Center	17 Bristol St	Brooklyn	EJZ	210,444 GSF	Between Good and Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
41	Not Solar-Ready	DOE	K271	1137 HERKIMER STREET	Brooklyn	EJZ	228,000 GSF	Between Good and Fair	15 to 19 years		
42	Not Solar-Ready	DHS	Linden Family Residence	501 New Lots Ave	Brooklyn	EJZ	12,000 GSF	Poor	> 20 years		
42	Not Solar-Ready	BPL	East Flatbush Branch Library	9612 Church Ave	Brooklyn	EJZ	12,329 GSF	Between Fair and Poor	> 20 years		
42	Not Solar-Ready	NYPD	69th Precinct	9720 Foster Ave	Brooklyn	EJZ	15,792 GSF	Between Fair and Poor	10 to 14 years		
42	Not Solar-Ready	DHS	Rose McCarthy Family Residence 2	882 Dumont Ave	Brooklyn	EJZ	18,000 GSF	Good	Unknown		
42	Not Solar-Ready	DOHMH	Animal Shelter - Brooklyn	2336 Linden Blvd	Brooklyn	EJZ	20,500 GSF	Unknown	15 to 19 years		
42	Not Solar-Ready	DHS	Rose McCarthy Family Residence 1	900 Dumont Ave	Brooklyn	EJZ	21,600 GSF	Good	Unknown		
42	Not Solar-Ready	BPL	New Lots Branch Library	655 New Lots Ave	Brooklyn	EJZ	24,558 GSF	Between Fair and Poor	15 to 19 years		
42	Not Solar-Ready	DHS	Samaritan Forbell Residence	338-344 Forbell St	Brooklyn	EJZ	24,900 GSF	Poor	> 20 years		
42	Not Solar-Ready	DHS	Flatlands Avenue Residence	10875 Ave D	Brooklyn	EJZ	28,545 GSF	Fair	15 to 19 years		
42	Not Solar-Ready	NYPD	75th Precinct	1000 Sutter Ave	Brooklyn	EJZ	30,160 GSF	Unknown	15 to 19 years		
42	Not Solar-Ready	DSNY	Brooklyn South 16 District Garage	922 Georgia Ave	Brooklyn	EJZ	41,800 GSF	Between Fair and Poor	Unknown		
42	Solar-Ready	DEP	Brooklyn Repair - Remsen Yard	855 Remsen Ave	Brooklyn		47,000 GSF	Between Good and Fair	2 to 4 years		
42	Not Solar-Ready	DSNY	Cioffe Borough Repair Shop	10601 Ave D	Brooklyn	EJZ	59,260 GSF	Poor	> 20 years		
42	Solar-Ready	DOE	K159	2781 PITKIN AVENUE	Brooklyn	EJZ	63,462 GSF	Good	5 to 9 years		
42	Not Solar-Ready	DHS	Fannie Barnes (Urban Transitional Housing)	829 Saratoga Ave	Brooklyn	EJZ	72,000 GSF	Unknown	Unknown		
42	Solar-Ready	DPR	Brownsville Recreation Center	1555 Linden Blvd	Brooklyn	EJZ	72,000 GSF	Fair	5 to 9 years		Green Roof

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
42	Not Solar-Ready	HHC	East New York Diagnostic & Treatment Center	2094 Pitkin Ave	Brooklyn	EJZ	72,755 GSF	Between Good and Fair	15 to 19 years		
42	Solar-Ready	DOE	K165	76 LOTT AVENUE	Brooklyn	EJZ	74,400 GSF	Good	5 to 9 years		
42	Not Solar-Ready	DEP	Supplemental Cake Storage Facility	122-66 Flatlands Ave	Brooklyn	EJZ	81,760 GSF	Unknown	10 to 14 years		
42	Solar-Ready	DOE	K213	580 HEGEMAN AVE.	Brooklyn	EJZ	82,314 GSF	Between Good and Fair	5 to 9 years		
42	Not Solar-Ready	DOE	K260	875 WILLIAMS AVENUE	Brooklyn	EJZ	85,200 GSF	Fair	> 20 years		
42	Not Solar-Ready	DOE	K183	76 RIVERDALE AVE.	Brooklyn	EJZ	93,600 GSF	Fair	10 to 14 years		
42	Solar-Ready	DOE	K190	590 SHEFFIELD AVENUE	Brooklyn	EJZ	93,600 GSF	Good	5 to 9 years		
42	Not Solar-Ready	DOE	K184	273 NEWPORT STREET	Brooklyn	EJZ	94,800 GSF	Between Fair and Poor	15 to 19 years		
42	Not Solar-Ready	DOE	K328	330 ALABAMA AVENUE	Brooklyn	EJZ	108,000 GSF	Fair	> 20 years		
42	Solar-Ready	DOE	K149	700 SUTTER AVENUE	Brooklyn	EJZ	111,600 GSF	Between Good and Fair	5 to 9 years		
42	Not Solar-Ready	DOE	K306	970 VERMONT STREET	Brooklyn	EJZ	112,800 GSF	Between Fair and Poor	> 20 years		
42	Not Solar-Ready	DOE	K233	9301 AVENUE B	Brooklyn	EJZ	115,200 GSF	Under construction	Under construction		
42	Not Solar-Ready	DHS	Help 1	515 Blake Ave	Brooklyn	EJZ	123,910 GSF	Fair	> 20 years		
42	Not Solar-Ready	DOE	K066	881 EAST 96TH STREET	Brooklyn	EJZ	127,200 GSF	Between Good and Fair	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
42	Not Solar-Ready	DOE	K202	982 HEGEMAN AVE.	Brooklyn	EJZ	130,832 GSF	Between Fair and Poor	15 to 19 years		
42	Not Solar-Ready	DOE	K013	557 PENNSYLVANIA AVENUE	Brooklyn	EJZ	144,000 GSF	Fair	> 20 years		
42	Not Solar-Ready	DOE	K346	1400 PENNSYLVANIA AVENUE	Brooklyn	EJZ	147,600 GSF	Fair	10 to 14 years		
42	Not Solar-Ready	DSNY	Brooklyn South 17 and 18 District Garage	10502 Ave D	Brooklyn	EJZ	148,473 GSF	Poor	> 20 years		
42	Not Solar-Ready	DOE	K072	605 SHEPHERD AVENUE	Brooklyn	EJZ	148,800 GSF	Fair	15 to 19 years		
42	Not Solar-Ready	DEP	Dewatering Building	122-66 Flatlands Ave	Brooklyn	EJZ	151,256 GSF	Unknown	10 to 14 years		
42	Not Solar-Ready	DOE	K422	1065 ELTON STREET	Brooklyn	EJZ	155,875 GSF	Poor	5 to 9 years	Yes	
42	Not Solar-Ready	DOE	K218	370 FOUNTAIN AVENUE	Brooklyn	EJZ	181,200 GSF	Poor	> 20 years		
42	Not Solar-Ready	DOE	K292	300 WYONA STREET	Brooklyn	EJZ	195,600 GSF	Fair	15 to 19 years		
42	Solar-Ready	DOE	K275	985 ROCKAWAY AVENUE	Brooklyn	EJZ	196,402 GSF	Between Good and Fair	5 to 9 years	Yes	
42	Not Solar-Ready	DOE	K435	400 PENNSYLVANIA AVE.	Brooklyn	EJZ	274,800 GSF	Between Fair and Poor	10 to 14 years		
42	Not Solar-Ready	FDNY	10110 Foster Avenue	10110 Foster Ave	Brooklyn	EJZ	348,000 GSF	Fair	15 to 19 years		
43	Not Solar-Ready	FDNY	Engine Co. 284 and Ladder Co. 149	1157 79th St	Brooklyn		10,350 GSF	Between Fair and Poor	15 to 19 years		
43	Not Solar-Ready	BPL	Dyker Branch Library	8202 13th Ave	Brooklyn		10,521 GSF	Between Fair and Poor	< 2 years		
43	Not Solar-Ready	DEP	Odor Control & Gas Compressor	Owl's Head WPCP	Brooklyn		15,625 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
43	Not Solar-Ready	BPL	Bay Ridge Branch Library	7223 Ridge Blvd	Brooklyn		16,506 GSF	Between Fair and Poor	15 to 19 years		
43	Not Solar-Ready	DEP	Pump and Power House 2	Owl's Head WPCP	Brooklyn		17,188 GSF	Fair	> 20 years		
43	Not Solar-Ready	BPL	New Utrecht Branch Library	1743 86th St	Brooklyn	EJZ	22,557 GSF	Unknown	15 to 19 years		
43	Not Solar-Ready	NYPD	62nd Precinct	1925 Bath Ave	Brooklyn	EJZ	25,000 GSF	Unknown	15 to 19 years		
43	Not Solar-Ready	DEP	Pump and Power House 1	Owl's Head WPCP	Brooklyn		25,313 GSF	Fair	> 20 years		
43	Not Solar-Ready	DOE	K127	7805 7 AVENUE	Brooklyn		42,000 GSF	Between Fair and Poor	15 to 19 years		
43	Not Solar-Ready	DOE	K112	7115 15 AVENUE	Brooklyn	EJZ	52,516 GSF	Fair	15 to 19 years		
43	Not Solar-Ready	DOE	K185	8601 RIDGE BLVD	Brooklyn		64,800 GSF	Fair	> 20 years		
43	Not Solar-Ready	DOE	K163	1664 BENSON AVENUE	Brooklyn	EJZ	66,000 GSF	Between Good and Fair	10 to 14 years		
43	Not Solar-Ready	DOE	K485	350 67TH STREET	Brooklyn		72,150 GSF	Fair	> 20 years		
43	Not Solar-Ready	DEP	Sludge Processing Complex	Owl's Head WPCP	Brooklyn		91,875 GSF	Fair	> 20 years		
43	Solar-Ready	DOE	K807	109 BAY 14 STREET	Brooklyn	EJZ	106,700 GSF	Between Good and Fair	5 to 9 years		
43	Not Solar-Ready	DOE	K176	1225 69th St	Brooklyn	EJZ	110,400 GSF	Fair	10 to 14 years		
43	Solar-Ready	DOE	K204	8101 15TH AVE.	Brooklyn		111,600 GSF	Good	< 2 years		
43	Not Solar-Ready	DOE	K102	211 72 STREET	Brooklyn		116,400 GSF	Under construction	Under construction		
43	Not Solar-Ready	DOE	K104	9115 5TH AVENUE	Brooklyn		116,400 GSF	Under construction	Under construction		
43	Not Solar-Ready	DOE	K170	7109 6TH AVE.	Brooklyn		117,409 GSF	Fair	10 to 14 years		
43	Not Solar-Ready	DOE	K229	1400 BENSON AVENUE	Brooklyn	EJZ	121,200 GSF	Between Fair and Poor	15 to 19 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
43	Not Solar-Ready	DOE	K200	1940 BENSON AVENUE	Brooklyn	EJZ	122,400 GSF	Under construction	Under construction		
43	Not Solar-Ready	DOE	K201	8010 12TH AVE.	Brooklyn		128,400 GSF	Under construction	Under construction		
43	Solar-Ready	DOE	K259	7305 FT HAMILTON PKWY	Brooklyn		153,600 GSF	Good	< 2 years		
43	Not Solar-Ready	DSNY	Brooklyn 11 District Garage; BK Boro Office; SW MTS	380 Bay 41st St	Brooklyn	EJZ	190,000 GSF	Between Fair and Poor	Unknown	Yes	
43	Not Solar-Ready	DOE	K490	8301 SHORE RD	Brooklyn		323,331 GSF	Under construction	Under construction		
43	Not Solar-Ready	DEP	Main Building	6700 Shore Rd	Brooklyn		669,680 GSF	Unknown	Unknown		
44	Solar-Ready	DOE	K134	4001 18 AVE.	Brooklyn	EJZ	12,707 GSF	Between Good and Fair	5 to 9 years		
44	Not Solar-Ready	BPL	Midwood Branch Library	975 East 16th St	Brooklyn		15,210 GSF	Unknown	5 to 9 years		
44	Not Solar-Ready	NYPD	70th Precinct	154 Lawrence Ave	Brooklyn	EJZ	18,000 GSF	Good	> 20 years		
44	Solar-Ready	BPL	Kensington Branch Library	4209 18th Ave	Brooklyn	EJZ	18,500 GSF	Good	2 to 4 years		
44	Not Solar-Ready	BPL	Mapleton Branch Library	1703 60th St	Brooklyn	EJZ	19,821 GSF	Unknown	15 to 19 years		
44	Not Solar-Ready	DSNY	Brooklyn South 12 District Garage	5602 19th Ave	Brooklyn	EJZ	36,010 GSF	Under construction	Under construction		
44	Not Solar-Ready	DOE	K121	5301 20 AVENUE	Brooklyn	EJZ	42,000 GSF	Poor	> 20 years		
44	Solar-Ready	DOE	K160	5105 FT. HAMILTON PKWY	Brooklyn	EJZ	66,000 GSF	Good	5 to 9 years		
44	Solar-Ready	DOE	K048	6015 18TH AVE.	Brooklyn	EJZ	72,000 GSF	Good	5 to 9 years		
44	Not Solar-Ready	DOE	K164	4211 14th Ave	Brooklyn	EJZ	90,000 GSF	Between Fair and Poor	> 20 years		
44	Solar-Ready	DOE	K192	4715 18 AVENUE	Brooklyn		91,200 GSF	Fair	5 to 9 years		
44	Not Solar-Ready	DOE	K099	1120 EAST 10 STREET	Brooklyn		94,800 GSF	Under construction	Under construction		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
44	Not Solar-Ready	DOE	K238	1633 EAST 8 STREET	Brooklyn		105,600 GSF	Fair	15 to 19 years		
44	Not Solar-Ready	DOE	K177	346 AVENUE P	Brooklyn		108,000 GSF	Between Good and Fair	10 to 14 years		
44	Not Solar-Ready	DOE	K226	6006 23 AVENUE	Brooklyn		112,800 GSF	Fair	> 20 years		
44	Solar-Ready	DOE	K686	50 AVENUE P	Brooklyn		133,624 GSF	Between Good and Fair	5 to 9 years		
44	Not Solar-Ready	DOE	K180	5601 16th Ave	Brooklyn	EJZ	145,200 GSF	Fair	15 to 19 years		
44	Not Solar-Ready	DOE	K223	4200 16 AVENUE	Brooklyn	EJZ	145,200 GSF	Fair	10 to 14 years		
44	Not Solar-Ready	DOE	K096	99 AVENUE P	Brooklyn	EJZ	147,600 GSF	Fair	15 to 19 years		
44	Not Solar-Ready	DOE	K525	1600 AVENUE L	Brooklyn	EJZ	450,000 GSF	Fair	15 to 19 years	Yes	
45	Not Solar-Ready	BPL	Flatlands Branch Library	2065 Flatbush Ave	Brooklyn	EJZ	11,903 GSF	Between Fair and Poor	15 to 19 years		
45	Not Solar-Ready	NYPD	63rd Precinct	1844 Brooklyn Ave	Brooklyn	EJZ	11,904 GSF	Unknown	15 to 19 years		
45	Solar-Ready	DOE	K729	3920 FLATLANDS AVENUE	Brooklyn		36,000 GSF	Between Good and Fair	5 to 9 years		
45	Not Solar-Ready	DOE	K119	3829 AVENUE K	Brooklyn	EJZ	62,400 GSF	Between Good and Fair	> 20 years		
45	Not Solar-Ready	DOE	K864	3109 NEWKIRK AVENUE	Brooklyn	EJZ	66,426 GSF	Fair	15 to 19 years		
45	Solar-Ready	DOE	K198	4105 FARRAGUT ROAD	Brooklyn	EJZ	77,261 GSF	Good	< 2 years		
45	Not Solar-Ready	DOE	K208	4801 AVENUE D	Brooklyn	EJZ	83,693 GSF	Between Fair and Poor	> 20 years		
45	Not Solar-Ready	DOE	K193	2515 AVENUE L	Brooklyn		91,664 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
45	Not Solar-Ready	DOE	K285	5905 BEVERLY ROAD	Brooklyn	EJZ	144,000 GSF	Fair	> 20 years		
45	Not Solar-Ready	DOE	K395	1001 EAST 45TH STREET	Brooklyn	EJZ	150,000 GSF	Under construction	Under construction		
45	Solar-Ready	DOE	K181	1023 NEW YORK AVENUE	Brooklyn	EJZ	153,600 GSF	Good	2 to 4 years		
45	Solar-Ready	DOE	K244	5404 TILDEN AVENUE	Brooklyn	EJZ	154,800 GSF	Good	< 2 years		
45	Not Solar-Ready	DOE	K240	2500 NOSTRAND AVENUE	Brooklyn	EJZ	169,200 GSF	Fair	> 20 years		
45	Solar-Ready	DOE	K405	2839 BEDFORD AVENUE	Brooklyn	EJZ	282,690 GSF	Good	5 to 9 years		
46	Solar-Ready	NYPD	Highway District Unit 2	2900 Flatbush Ave	Brooklyn		23,700 GSF	Between Good and Fair	5 to 9 years		
46	Not Solar-Ready	NYPD	NYPD Warehouse	Gateway National Recreation Area	Brooklyn		36,920 GSF	Between Good and Fair	15 to 19 years		
46	Not Solar-Ready	DEP	Paerdegat Sewage Screening, Odor, and Pump Back Facility	1065 Bergen Ave	Brooklyn	EJZ	46,631 GSF	Unknown	Unknown		
46	Not Solar-Ready	DOE	K277	2529 GERRITSEN AVE.	Brooklyn		62,400 GSF	Fair	10 to 14 years		
46	Solar-Ready	DOE	K366	965 EAST 107TH STREET	Brooklyn	EJZ	65,203 GSF	Good	5 to 9 years		
46	Solar-Ready	DOE	K207	4011 FILLMORE AVE.	Brooklyn		84,000 GSF	Good	2 to 4 years		
46	Solar-Ready	DOE	K194	3117 Avenue W	Brooklyn		86,003 GSF	Good	< 2 years		
46	Solar-Ready	DOE	K276	1070 EAST 83 STREET	Brooklyn	EJZ	93,034 GSF	Good	2 to 4 years		
46	Not Solar-Ready	DOE	K236	6302 AVENUE U	Brooklyn		95,186 GSF	Under construction	Under construction		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
46	Not Solar-Ready	DOE	K242	100-01 FLATLANDS AVENUE	Brooklyn	EJZ	96,000 GSF	Between Fair and Poor	15 to 19 years		
46	Solar-Ready	DOE	K272	101-24 SEAVIEW AVENUE	Brooklyn	EJZ	96,114 GSF	Good	2 to 4 years		
46	Solar-Ready	DOE	K203	5101 AVENUE M	Brooklyn	EJZ	111,600 GSF	Between Good and Fair	5 to 9 years		
46	Solar-Ready	DOE	K222	3301 QUENTIN ROAD	Brooklyn		112,800 GSF	Good	5 to 9 years		
46	Not Solar-Ready	DOE	K279	1070 EAST 104 STREET	Brooklyn	EJZ	123,600 GSF	Fair	15 to 19 years		
46	Not Solar-Ready	DOE	K114	1077 REMSEN AVENUE	Brooklyn	EJZ	124,800 GSF	Between Good and Fair	10 to 14 years		
46	Solar-Ready	DOE	K211	1001 EAST 100 STREET	Brooklyn	EJZ	168,000 GSF	Fair	5 to 9 years	Yes	
46	Not Solar-Ready	DOE	K068	956 EAST 82 STREET	Brooklyn	EJZ	184,800 GSF	Between Good and Fair	10 to 14 years		
46	Not Solar-Ready	DOE	K078	1420 EAST 68 STREET	Brooklyn	EJZ	187,200 GSF	Between Good and Fair	> 20 years		
46	Not Solar-Ready	DOT	Fleet Services, BK Street Maintenance	6080 Flatlands Ave	Brooklyn	EJZ	188,071 GSF	Poor	15 to 19 years		
46	Not Solar-Ready	DOE	K724	1600 ROCKAWAY PKWY	Brooklyn	EJZ	297,600 GSF	Fair	15 to 19 years		
47	Not Solar-Ready	DPR	Poseidon Playground Maintenance Building	3010 West 25th St	Brooklyn	EJZ	10,464 GSF	Fair	> 20 years		
47	Solar-Ready	DCLA	Aquatic Animal Health Center	600 Surf Ave	Brooklyn	EJZ	10,800 GSF	Good	5 to 9 years		
47	Not Solar-Ready	DCLA	NY Aquarium Campus: Cafe	508 Surf Ave	Brooklyn	EJZ	11,620 GSF	Good	10 to 14 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
47	Solar-Ready	HHC	New Ida G. Israel Community Health Center	2925 West 19th St	Brooklyn	EJZ	13,000 GSF	Good	2 to 4 years		
47	Not Solar-Ready	DCLA	Osborn Laboratories of Marine Sciences	502 Surf Ave	Brooklyn	EJZ	16,945 GSF	Fair	15 to 19 years		
47	Not Solar-Ready	DCLA	Aqua Theater	520 Surf Ave	Brooklyn	EJZ	18,720 GSF	Unknown	Unknown		
47	Not Solar-Ready	DCLA	Operations Building	820 Surf Ave	Brooklyn	EJZ	21,037 GSF	Fair	15 to 19 years		
47	Not Solar-Ready	DCLA	Conservation Hall	506 Surf Ave	Brooklyn	EJZ	29,491 GSF	Fair	> 20 years		
47	Not Solar-Ready	DCLA	Explore the Shore/Alien Stingers	510 Surf Ave	Brooklyn	EJZ	35,883 GSF	Good	15 to 19 years		
47	Solar-Ready	DOE	K728	2865 W. 19TH STREET	Brooklyn	EJZ	37,362 GSF	Between Good and Fair	5 to 9 years		
47	Not Solar-Ready	DCLA	Sea Cliffs	504 Surf Ave	Brooklyn	EJZ	38,000 GSF	Fair	Unknown		
47	Solar-Ready	DPR	Abe Stark Ice Rink	1902 West 19th St	Brooklyn	EJZ	51,900 GSF	Between Good and Fair	5 to 9 years		Green Roof
47	Solar-Ready	DCLA	Ocean Wonders	514 Surf Ave	Brooklyn	EJZ	57,500 GSF	Good	< 2 years		
47	Solar-Ready	DOE	K128	2075 84 STREET	Brooklyn	EJZ	63,600 GSF	Between Good and Fair	5 to 9 years		
47	Not Solar-Ready	DOE	K247	7000 21 AVENUE	Brooklyn	EJZ	66,000 GSF	Between Fair and Poor	15 to 19 years		
47	Solar-Ready	DOE	K097	1855 STILLWELL AVE.	Brooklyn	EJZ	79,680 GSF	Good	2 to 4 years		
47	Solar-Ready	DOE	K101	2360 BENSON AVE.	Brooklyn	EJZ	80,400 GSF	Good	2 to 4 years		
47	Solar-Ready	DOE	K090	2840 WEST 12 STREET	Brooklyn	EJZ	88,800 GSF	Good	< 2 years		
47	Not Solar-Ready	DOE	K215	415 AVENUE S	Brooklyn		92,400 GSF	Fair	10 to 14 years		
47	Not Solar-Ready	DOE	K216	350 AVENUE X	Brooklyn		92,400 GSF	Between Good and Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
47	Solar-Ready	DOE	K186	7601 19 AVENUE	Brooklyn	EJZ	92,400 GSF	Between Good and Fair	5 to 9 years		
47	Not Solar-Ready	DOE	K212	87 BAY 49 STREET	Brooklyn		96,000 GSF	Under construction	Under construction		
47	Not Solar-Ready	DOE	K188	3314 NEPTUNE AVENUE	Brooklyn	EJZ	96,000 GSF	Fair	> 20 years		
47	Not Solar-Ready	DOE	K288	2950 WEST 25 STREET	Brooklyn	EJZ	98,400 GSF	Under construction	Under construction		
47	Not Solar-Ready	DOE	K095	345 VAN SICKLEN ST.	Brooklyn		102,316 GSF	Under construction	Under construction		
47	Not Solar-Ready	DOE	K205	6701 20 AVENUE	Brooklyn	EJZ	129,600 GSF	Under construction	Under construction		
47	Not Solar-Ready	DOE	K228	228 AVENUE S	Brooklyn		145,200 GSF	Fair	15 to 19 years		
47	Not Solar-Ready	DOE	K303	501 WEST AVENUE	Brooklyn		182,400 GSF	Between Good and Fair	> 20 years	Yes	
47	Not Solar-Ready	DOE	K281	8787 24 AVENUE	Brooklyn	EJZ	183,600 GSF	Fair	15 to 19 years		
47	Not Solar-Ready	DOE	K239	2401 NEPTUNE AVENUE	Brooklyn	EJZ	186,000 GSF	Between Good and Fair	> 20 years		
47	Not Solar-Ready	DOE	K540	50 AVENUE X	Brooklyn		211,500 GSF	Between Fair and Poor	15 to 19 years	Yes	
47	Solar-Ready	DOE	K410	2800 OCEAN PARKWAY	Brooklyn		305,046 GSF	Good	2 to 4 years	Yes	
47	Not Solar-Ready	DOE	K400	2630 BENSON AVE.	Brooklyn		320,322 GSF	Poor	10 to 14 years	Yes	
48	Not Solar-Ready	CUNY	Temporary Building #3	2055 Oriental Blvd	Brooklyn		10,200 GSF	Poor	Unknown		
48	Not Solar-Ready	FDNY	Engine Co. 276 and Ladder Co. 156, Batt. 33	1635 East 14th St	Brooklyn		10,227 GSF	Unknown	10 to 14 years		
48	Not Solar-Ready	DEP	Skimming Enclosure Building	Coney Island WPCP	Brooklyn		10,469 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
48	Not Solar-Ready	NYPD	MTD Troop E	2801 Brighton 3rd St	Brooklyn	EJZ	10,580 GSF	Between Good and Fair	15 to 19 years		
48	Not Solar-Ready	CUNY	Temporary Building #6	2105 Oriental Blvd	Brooklyn		12,070 GSF	Poor	Unknown		
48	Solar-Ready	BPL	Brighton Beach Branch Library	16 Brighton 1st Rd	Brooklyn		12,166 GSF	Good	< 2 years		
48	Not Solar-Ready	DEP	Primary Settling Tanks Odor Control Building	Coney Island WPCP	Brooklyn		14,221 GSF	Poor	> 20 years		
48	Not Solar-Ready	BPL	Kings Bay Branch Library	3651 Nostrand Ave	Brooklyn		14,885 GSF	Between Fair and Poor	> 20 years		
48	Not Solar-Ready	DEP	Return Sludge Pump Station	Coney Island WPCP	Brooklyn		16,375 GSF	Fair	> 20 years		
48	Not Solar-Ready	CUNY	Temporary Building #5	2100 Oriental Blvd	Brooklyn		17,852 GSF	Poor	Unknown		
48	Not Solar-Ready	DOHMH	Homecrest Health Center	1601 Ave S	Brooklyn		17,919 GSF	Unknown	5 to 9 years		
48	Solar-Ready	CUNY	Temporary Building #8	2101 Oriental Blvd	Brooklyn		18,187 GSF	Good	5 to 9 years		
48	Not Solar-Ready	DEP	Pump & Power House A1	Coney Island WPCP	Brooklyn		18,750 GSF	Fair	> 20 years		
48	Not Solar-Ready	CUNY	Temporary Building #1 (UAPC)	2085 Oriental Blvd	Brooklyn		19,200 GSF	Poor	Unknown		
48	Not Solar-Ready	DEP	Sludge & Digester Gas Storage Facility A1	Coney Island WPCP	Brooklyn		21,250 GSF	Fair	> 20 years		
48	Not Solar-Ready	DEP	Plant Admin & Support Facility A1	Coney Island WPCP	Brooklyn		21,563 GSF	Fair	> 20 years		
48	Not Solar-Ready	DEP	Interim Resident Engineering Plant Personnel Building	Coney Island WPCP	Brooklyn		22,500 GSF	Fair	> 20 years		
48	Not Solar-Ready	CUNY	Temporary Building #7	2131 Oriental Blvd	Brooklyn		27,072 GSF	Between Fair and Poor	Unknown		
48	Not Solar-Ready	DEP	Digester Building A1	Coney Island WPCP	Brooklyn		27,422 GSF	Fair	> 20 years		
48	Not Solar-Ready	NYPD	61st Precinct	2575 Coney Island Ave	Brooklyn		31,429 GSF	Good	15 to 19 years		
48	Not Solar-Ready	CUNY	Administration Building	2001 Oriental Blvd	Brooklyn		32,126 GSF	Poor	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
48	Not Solar-Ready	NYPD	60th Precinct and Engine Company 245	2951 West 8th St	Brooklyn		32,400 GSF	Between Fair and Poor	5 to 9 years		
48	Not Solar-Ready	CUNY	West Academic Cluster	1950 Oriental Blvd	Brooklyn		33,130 GSF	Poor	Unknown		
48	Not Solar-Ready	CUNY	West Academic Cluster - Wing E	1950 Oriental Blvd	Brooklyn		33,130 GSF	Poor	Unknown		
48	Not Solar-Ready	CUNY	West Academic Cluster - Wing D	1950 Oriental Blvd	Brooklyn		35,362 GSF	Poor	Unknown		
48	Not Solar-Ready	CUNY	West Academic Cluster - Wing F	1950 Oriental Blvd	Brooklyn		35,362 GSF	Poor	Unknown		
48	Not Solar-Ready	CUNY	Temporary Building #2 (T-2)	2065 Oriental Blvd	Brooklyn		36,000 GSF	Poor	Unknown		
48	Not Solar-Ready	DEP	Main Sewage Pump Station	Coney Island WPCP	Brooklyn		40,625 GSF	Fair	> 20 years		
48	Not Solar-Ready	DEP	Ave Z	Ave Z	Brooklyn		45,000 GSF	Between Fair and Poor	> 20 years		
48	Solar-Ready	CUNY	Leon M. Goldstein Performing Arts Center	2001 Oriental Blvd	Brooklyn		46,768 GSF	Between Good and Fair	5 to 9 years		
48	Not Solar-Ready	DEP	Thickener Building	Coney Island WPCP	Brooklyn		49,805 GSF	Fair	> 20 years		
48	Not Solar-Ready	CUNY	Academic Village	1915 Oriental Blvd	Brooklyn		50,435 GSF	Good	10 to 14 years		
48	Not Solar-Ready	DOE	K370	3000 WEST 1ST STREET	Brooklyn		52,800 GSF	Fair	> 20 years		
48	Not Solar-Ready	CUNY	Temporary Building #4	2111 Oriental Blvd	Brooklyn		53,718 GSF	Poor	Unknown		
48	Not Solar-Ready	DOE	K195	131 IRWIN STREET	Brooklyn		56,400 GSF	Between Good and Fair	10 to 14 years		
48	Not Solar-Ready	DOE	K153	1970 HOMECREST AVENUE	Brooklyn	EJZ	64,800 GSF	Fair	15 to 19 years		
48	Not Solar-Ready	CUNY	Health and Physical Education Center	1925 Oriental Blvd	Brooklyn		72,282 GSF	Poor	Unknown		
48	Solar-Ready	DOE	K254	1801 AVENUE Y	Brooklyn		73,200 GSF	Good	2 to 4 years		
48	Not Solar-Ready	DOE	K209	2609 EAST 7 STREET	Brooklyn		79,793 GSF	Fair	> 20 years		



# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
48	Not Solar-Ready	DOE	K253	601 OCEAN VIEW AVENUE	Brooklyn		82,447 GSF	Under construction	Under construction		
48	Not Solar-Ready	DOE	K199	1100 ELM AVE.	Brooklyn	EJZ	82,800 GSF	Between Good and Fair	10 to 14 years		
48	Not Solar-Ready	DOE	K255	1866 EAST 17TH ST.	Brooklyn		91,200 GSF	Fair	> 20 years		
48	Not Solar-Ready	DOE	K535	1830 SHORE BLVD.	Brooklyn		92,400 GSF	Between Good and Fair	15 to 19 years		
48	Not Solar-Ready	DOE	K100	2951 WEST 3 STREET	Brooklyn	EJZ	93,600 GSF	Between Fair and Poor	15 to 19 years		
48	Not Solar-Ready	CUNY	College Center	1824 Oriental Blvd	Brooklyn		98,604 GSF	Poor	Unknown		
48	Not Solar-Ready	DEP	3002 Ave Z	3002 Ave Z	Brooklyn		99,000 GSF	Between Fair and Poor	> 20 years		
48	Not Solar-Ready	DOE	K286	2525 HARING STREET	Brooklyn		103,200 GSF	Fair	> 20 years		
48	Not Solar-Ready	CUNY	Arts and Sciences Center	2120 Oriental Blvd	Brooklyn		105,724 GSF	Between Fair and Poor	Unknown		
48	Solar-Ready	DOE	K052	2675 EAST 29TH ST.	Brooklyn		109,200 GSF	Good	2 to 4 years	Yes	
48	Solar-Ready	CUNY	Robert J. Kibbee Library and Media Center	2000 Oriental Blvd	Brooklyn		122,364 GSF	Fair	5 to 9 years		
48	Solar-Ready	DOE	K225	1075 OCEAN VIEW AVENUE	Brooklyn	EJZ	122,400 GSF	Good	< 2 years		
48	Solar-Ready	DOE	K197	1599 EAST 22 STREET	Brooklyn		128,400 GSF	Good	2 to 4 years	Yes	
48	Solar-Ready	DOE	K206	2200 GRAVESEND NECK ROAD	Brooklyn	EJZ	130,800 GSF	Between Good and Fair	2 to 4 years		
48	Not Solar-Ready	CUNY	Leon M. Goldstein High School for the Sciences	1830 Shore Blvd	Brooklyn		133,951 GSF	Unknown	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
48	Not Solar-Ready	CUNY	Marine and Academic Center	2110 Oriental Blvd	Brooklyn		204,000 GSF	Poor	Unknown		
48	Not Solar-Ready	DOE	K620	25 BRIGHTON 4TH	Brooklyn	EJZ	240,000 GSF	Fair	> 20 years		
48	Not Solar-Ready	DEP	2591 Knapp St	2591 Knapp St	Brooklyn		688,008 GSF	Between Fair and Poor	> 20 years		
48	Not Solar-Ready	HHC	Coney Island Hospital	2601 Ocean Pkwy	Brooklyn	EJZ	836,000 GSF	Fair	10 to 14 years		
49	Not Solar-Ready	DCLA	Snug Harbor Bldg O/SICM Barn	1000 Richmond Ter	Staten Island		10,000 GSF	Good	10 to 14 years		
49	Solar-Ready	NYPL	Mariner's Harbor Library	206 South Ave	Staten Island	EJZ	10,100 GSF	Good	2 to 4 years		
49	Not Solar-Ready	DCLA	Bldg J/Gazebo	1000 Richmond Ter	Staten Island		10,400 GSF	Unknown	Unknown		
49	Not Solar-Ready	DCLA	Bldg U	1000 Richmond Ter	Staten Island		10,400 GSF	Unknown	Unknown		
49	Not Solar-Ready	DCLA	Bldg V/Main Gate	1000 Richmond Ter	Staten Island		10,400 GSF	Unknown	Unknown		
49	Not Solar-Ready	DCAS	Staten Island Family Court	100 Richmond Ter	Staten Island	EJZ	10,400 GSF	Fair	10 to 14 years		
49	Not Solar-Ready	DCLA	Bldg L/Power Plant	1000 Richmond Ter	Staten Island		11,900 GSF	Poor	Unknown		
49	Not Solar-Ready	DEP	R-2 Water and Sewer Maintenance Yard	288 Clove Rd	Staten Island	EJZ	12,000 GSF	Unknown	Unknown		
49	Not Solar-Ready	FDNY	Staten Island Central Office	65 Slosson Ave	Staten Island		12,174 GSF	Fair	15 to 19 years		
49	Not Solar-Ready	DOT	DOT Sign Shop	34 Wave St	Staten Island	EJZ	12,800 GSF	Poor	Unknown		
49	Solar-Ready	DCLA	Staten Island Museum	75 Stuyvesant Pl	Staten Island	EJZ	13,022 GSF	Good	< 2 years		
49	Not Solar-Ready	DCLA	Bldg P/Admin	1000 Richmond Ter	Staten Island		13,100 GSF	Good	Unknown		
49	Not Solar-Ready	DCLA	Bldg M/SI Children's Museum	1000 Richmond Ter	Staten Island		15,456 GSF	Between Good and Fair	> 20 years		
49	Not Solar-Ready	NYPD	120th Precinct	78 Richmond Ter	Staten Island	EJZ	15,540 GSF	Good	> 20 years		
49	Not Solar-Ready	DPR	Staten Island War Memorial Ice Rink	1321 Victory Blvd	Staten Island		16,000 GSF	Fair	> 20 years		
49	Not Solar-Ready	DCAS	Staten Island Civil Court	927 Castleton Ave	Staten Island	EJZ	16,194 GSF	Fair	> 20 years		
49	Not Solar-Ready	DCLA	Bldg T/Music Hall	1000 Richmond Ter	Staten Island		16,250 GSF	Good	Unknown		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
49	Not Solar-Ready	DEP	Victory Boulevard Campus/Richmond North Facility	24 Ontario Ave	Staten Island		16,500 GSF	Fair	> 20 years		
49	Solar-Ready	DPR	Clove Lake Garage and Shops	21 Slosson Ave	Staten Island		16,500 GSF	Between Good and Fair	5 to 9 years		Green Roof
49	Not Solar-Ready	DCLA	Bldg C/Newhouse Center	1000 Richmond Ter	Staten Island		17,500 GSF	Poor	5 to 9 years		
49	Not Solar-Ready	DCLA	Bldg R/Great Hall	1000 Richmond Ter	Staten Island		18,900 GSF	Poor	Unknown		
49	Not Solar-Ready	DCLA	Snug Harbor Campus Bldg B	1000 Richmond Ter	Staten Island		19,200 GSF	Unknown	Unknown		
49	Not Solar-Ready	DCLA	B-C Hyphen	1000B Richmond Ter	Staten Island		20,000 GSF	Unknown	Unknown		
49	Not Solar-Ready	DCLA	Bldg D/Noble Collection	1000 Richmond Ter	Staten Island		20,000 GSF	Good	Unknown		
49	Not Solar-Ready	DCAS	Staten Island Supreme Court	18 Richmond Ter	Staten Island	EJZ	21,500 GSF	Fair	> 20 years		
49	Not Solar-Ready	DCAS	Staten Island Criminal Court	67 Targee St	Staten Island	EJZ	23,116 GSF	Fair	> 20 years		
49	Solar-Ready	DPR	Lyons Pool and Recreation Center	317 Bay St	Staten Island	EJZ	24,000 GSF	Between Good and Fair	5 to 9 years		Green Roof
49	Solar-Ready	DCLA	Bldg A/Staten Island Museum	1000 Richmond Ter	Staten Island		24,448 GSF	Good	2 to 4 years		
49	Not Solar-Ready	ACS	Childrens Aide Society Inc.	159 Broadway	Staten Island	EJZ	24,700 GSF	Poor	Unknown		
49	Not Solar-Ready	NYPL	St. George Library Center	10 Hyatt St	Staten Island		25,029 GSF	Poor	Unknown		
49	Not Solar-Ready	DCLA	Bldg E	1000 Richmond Ter	Staten Island		29,500 GSF	Good	Unknown		
49	Not Solar-Ready	DCLA	Bldg F	1000 Richmond Ter	Staten Island		30,000 GSF	Unknown	> 20 years		
49	Not Solar-Ready	DCLA	Building A	1000A Richmond Terr.	Staten Island		30,580 GSF	Good	15 to 19 years		
49	Not Solar-Ready	DSNY	Staten Island Lot Cleaning	66 Swan St	Staten Island	EJZ	31,190 GSF	Good	> 20 years		
49	Not Solar-Ready	DCLA	Bldg H	1000 Richmond Ter	Staten Island		31,250 GSF	Poor	Unknown		
49	Not Solar-Ready	DOE	R035	60 FOOTE AVE.	Staten Island		31,500 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
49	Not Solar-Ready	DOE	R470	109 RHINE AVE.	Staten Island	EJZ	32,460 GSF	Between Good and Fair	15 to 19 years		
49	Not Solar-Ready	DOT	Castleton Depot	5 Dubois Ave	Staten Island	EJZ	32,500 GSF	Unknown	> 20 years		
49	Not Solar-Ready	DEP	Building #1	1801 Richmond Ter	Staten Island	EJZ	32,800 GSF	Between Fair and Poor	> 20 years		
49	Solar-Ready	DOE	R040	91 HENDERSON AVENUE	Staten Island	EJZ	33,964 GSF	Good	5 to 9 years		
49	Not Solar-Ready	DOE	R020	161 PARK AVENUE	Staten Island	EJZ	34,880 GSF	Between Good and Fair	10 to 14 years		
49	Not Solar-Ready	DOE	R831	211 DANIEL LOW TERRACE	Staten Island	EJZ	37,260 GSF	Between Good and Fair	10 to 14 years		
49	Not Solar-Ready	DCLA	Bldg G/Newhouse Gallery	1000 Richmond Ter	Staten Island		38,400 GSF	Between Good and Fair	> 20 years		
49	Not Solar-Ready	DOE	R021	168 HOOKER PLACE	Staten Island		40,860 GSF	Between Fair and Poor	15 to 19 years		
49	Solar-Ready	DOE	R065	98 GRANT STREET	Staten Island	EJZ	46,206 GSF	Good	5 to 9 years		
49	Not Solar-Ready	DEP	Thickener Digester Complex Bldg	1801 Richmond Ter	Staten Island	EJZ	47,016 GSF	Between Fair and Poor	15 to 19 years		
49	Not Solar-Ready	DCLA	Main Zoo Building	614 Broadway	Staten Island		48,000 GSF	Between Fair and Poor	> 20 years		
49	Solar-Ready	NYPD	121st Precinct	970 Richmond Ave	Staten Island		48,797 GSF	Good	< 2 years		
49	Not Solar-Ready	DOE	R722	155 TOMPKINS AVENUE	Staten Island	EJZ	69,320 GSF	Fair	> 20 years		
49	Not Solar-Ready	DOE	R019	780 POST AVENUE	Staten Island	EJZ	72,225 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
49	Not Solar-Ready	DCAS	Staten Island Borough Hall	10 Richmond Ter	Staten Island	EJZ	81,538 GSF	Fair	> 20 years		
49	Not Solar-Ready	DOE	R031	55 LAYTON AVENUE	Staten Island	EJZ	92,600 GSF	Fair	15 to 19 years		
49	Not Solar-Ready	DOE	R018	221 BROADWAY	Staten Island	EJZ	104,525 GSF	Fair	15 to 19 years		
49	Solar-Ready	DOE	R861	280 REGIS DRIVE	Staten Island		107,918 GSF	Good	5 to 9 years		
49	Not Solar-Ready	DOE	R016	80 MONROE AVENUE	Staten Island	EJZ	110,600 GSF	Fair	15 to 19 years		
49	Not Solar-Ready	DSNY	Staten Island 1 District Garage	92 Brook St	Staten Island	EJZ	114,535 GSF	Poor	Unknown		
49	Solar-Ready	DOE	R044	80 MAPLE PARKWAY	Staten Island	EJZ	116,500 GSF	Good	< 2 years		
49	Not Solar-Ready	DOE	R022	1860 FOREST AVENUE	Staten Island		118,925 GSF	Fair	> 20 years		
49	Not Solar-Ready	DOE	R057	140 PALMA DRIVE	Staten Island	EJZ	129,725 GSF	Fair	15 to 19 years		
49	Not Solar-Ready	DCAS	130 Stuyvesant Place Office	130 Stuyvesant Pl	Staten Island	EJZ	150,300 GSF	Fair	15 to 19 years		
49	Not Solar-Ready	DOE	R049	101 WARREN STREET	Staten Island	EJZ	163,200 GSF	Fair	10 to 14 years		
49	Not Solar-Ready	DOE	R600	290 ST MARK'S PLACE	Staten Island	EJZ	175,202 GSF	Fair	> 20 years		
49	Not Solar-Ready	DOE	R027	11 CLOVE LAKE PLACE	Staten Island		192,175 GSF	Fair	> 20 years		
49	Not Solar-Ready	DOE	R061	445 CASTLETON AVENUE	Staten Island		206,500 GSF	Fair	> 20 years		
49	Solar-Ready	DOE	R450	105 HAMILTON AVE.	Staten Island	EJZ	242,998 GSF	Good	2 to 4 years		
50	Solar-Ready	DPR	Midland Beach Maintenance Facility	950 Father Capodanno Blvd	Staten Island		10,001 GSF	Good	5 to 9 years		Green Roof
50	Not Solar-Ready	DEP	Main Building	Oakwood Beach WPCP	Staten Island		10,266 GSF	Between Fair and Poor	> 20 years		
50	Not Solar-Ready	FDNY	Engine Co. 154 Communications Garage	3730 Victory Blvd	Staten Island		10,738 GSF	Fair	10 to 14 years		
50	Not Solar-Ready	NYPL	New Dorp Branch Library	309 New Dorp Ln	Staten Island		12,000 GSF	Poor	Unknown		
50	Not Solar-Ready	FDNY	Engine Co. 160 and Rescue 5, Division 8	1850 Clove Rd	Staten Island		13,200 GSF	Fair	15 to 19 years		
50	Solar-Ready	DPR	Greenbelt Native Plant Center	3808 Victory Blvd	Staten Island		15,180 GSF	Good	2 to 4 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
50	Solar-Ready	DPR	High Rock Park Buildings	200 Nevada Ave	Staten Island		15,600 GSF	Fair	5 to 9 years		
50	Not Solar-Ready	DEP	Dewatering Building	Oakwood Beach WPCP	Staten Island		29,722 GSF	Between Fair and Poor	> 20 years		
50	Not Solar-Ready	DOE	R026	4108 VICTORY BLVD.	Staten Island		33,660 GSF	Between Fair and Poor	15 to 19 years		
50	Not Solar-Ready	DOE	R048	1055 TARGEE STREET	Staten Island		40,800 GSF	Fair	15 to 19 years		
50	Not Solar-Ready	DOE	R011	50 JEFFERSON STREET	Staten Island		46,880 GSF	Fair	> 20 years		
50	Not Solar-Ready	DOE	R039	71 Sand Lane	Staten Island		51,680 GSF	Fair	15 to 19 years		
50	Not Solar-Ready	NYPD	122nd Precinct	2320 Hylan Blvd	Staten Island		53,200 GSF	Good	10 to 14 years		
50	Not Solar-Ready	DOE	R038	421 LINCOLN AVENUE	Staten Island		53,679 GSF	Fair	> 20 years		
50	Not Solar-Ready	DEP	Corridor TB-MB	Oakwood Beach WPCP	Staten Island		57,422 GSF	Between Fair and Poor	> 20 years		
50	Solar-Ready	DOE	R029	1581 VICTORY BLVD	Staten Island		74,400 GSF	Good	< 2 years		
50	Not Solar-Ready	DOE	R041	216 Clawson St	Staten Island		78,100 GSF	Fair	> 20 years		
50	Not Solar-Ready	DOE	R023	30 NATICK STREET	Staten Island		79,375 GSF	Fair	> 20 years		
50	Not Solar-Ready	DOE	R052	450 BUEL AVENUE	Staten Island		85,200 GSF	Fair	15 to 19 years		
50	Solar-Ready	DOE	R046	41 REID AVENUE	Staten Island	EJZ	87,660 GSF	Fair	10 to 14 years		
50	Solar-Ready	DOE	R054	1060 WILLOWBROOK ROAD	Staten Island		88,800 GSF	Good	5 to 9 years	Yes	
50	Not Solar-Ready	DOE	R030	200 Wardwell Ave	Staten Island		96,100 GSF	Under construction	Under construction		
50	Not Solar-Ready	DOE	R050	200 ADELAIDE AVENUE	Staten Island		99,700 GSF	Fair	> 20 years		
50	Solar-Ready	DOE	R880	715 Ocean Terrace	Staten Island	EJZ	102,000 GSF	Fair	10 to 14 years	Yes	
50	Not Solar-Ready	DOE	R060	55 MERRILL AVENUE	Staten Island		108,125 GSF	Fair	> 20 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
50	Not Solar-Ready	DOE	R002	333 MIDLAND AVENUE	Staten Island		182,575 GSF	Fair	10 to 14 years		
50	Not Solar-Ready	DEP	Treatment Building	Oakwood Beach WPCP	Staten Island		182,813 GSF	Between Fair and Poor	> 20 years		
50	Solar-Ready	DOE	R051	20 HOUSTON ST.	Staten Island		196,100 GSF	Between Good and Fair	10 to 14 years	Yes	
50	Solar-Ready	DOE	R440	485 CLAWSON ST.	Staten Island		197,467 GSF	Between Good and Fair	5 to 9 years		
50	Solar-Ready	DOE	R460	1200 MANOR RD	Staten Island	EJZ	316,000 GSF	Good	< 2 years		
50	Not Solar-Ready	DOE	R435	465 NEW DORP LANE	Staten Island		505,780 GSF	Fair	10 to 14 years		
50	Not Solar-Ready	HHC	Sea View Hospital Rehabilitation Center	460 Brielle Ave	Staten Island	EJZ	783,000 GSF	Fair	15 to 19 years		
51	Not Solar-Ready	NYPL	Richmondtown Branch Library	200 Clarke Ave	Staten Island		14,477 GSF	Poor	Unknown		
51	Solar-Ready	DOE	R848	25 AUGUSTA AVENUE	Staten Island		27,660 GSF	Between Good and Fair	5 to 9 years		
51	Not Solar-Ready	DOE	R005	348 Deisius St	Staten Island		41,460 GSF	Between Fair and Poor	> 20 years		
51	Not Solar-Ready	DOE	R001	58 SUMMIT STREET	Staten Island		54,000 GSF	Under construction	Under construction		
51	Not Solar-Ready	DOE	R042	380 GENESEE AVENUE	Staten Island		63,080 GSF	Fair	> 20 years		
51	Not Solar-Ready	DOE	R008	100 LINDENWOOD ROAD	Staten Island		72,060 GSF	Fair	15 to 19 years		
51	Not Solar-Ready	DSNY	Staten Island 3 District Garage	1323 West Service Rd	Staten Island		75,000 GSF	Poor	> 20 years		
51	Solar-Ready	DSNY	Staten Island 2 District Garage	2500 Richmond Ave	Staten Island		80,000 GSF	Good	2 to 4 years	Yes	
51	Not Solar-Ready	DOE	R053	330 DURANT AVENUE	Staten Island		80,500 GSF	Fair	15 to 19 years		

# Roof Assessment Findings\*

City Council District	2018 Solar-Ready Status	Agency	Site	Address	Borough	Environmental Justice Zone**	Total Gross Square Footage	Roof Condition	Roof Age	Solar-Readiness Assessment***	Other Sustainability Projects****
51	Not Solar-Ready	DOE	R055	54 OSBORNE STREET	Staten Island		80,825 GSF	Between Fair and Poor	> 20 years		
51	Solar-Ready	DOE	R036	255 Ionia Avenue	Staten Island		99,700 GSF	Good	2 to 4 years		
51	Not Solar-Ready	DOE	R058	77 MARSH AVENUE	Staten Island		107,125 GSF	Fair	10 to 14 years		
51	Not Solar-Ready	DOE	R032	32 ELVERTON AVENUE	Staten Island		110,400 GSF	Poor	> 20 years		
51	Not Solar-Ready	DOE	R056	250 KRAMER AVENUE	Staten Island		114,125 GSF	Fair	15 to 19 years		
51	Not Solar-Ready	DOE	R006	555 PAGE AVENUE	Staten Island		116,525 GSF	Between Good and Fair	15 to 19 years		
51	Not Solar-Ready	DOE	R034	528 Academy Ave	Staten Island		128,525 GSF	Between Fair and Poor	> 20 years		
51	Not Solar-Ready	DOE	R004	200 NEDRA LANE	Staten Island		159,775 GSF	Between Fair and Poor	> 20 years		
51	Solar-Ready	DOE	R043	100 ESSEX DRIVE	Staten Island		194,208 GSF	Good	5 to 9 years		
51	Not Solar-Ready	DOE	R024	225 CLEVELAND AVENUE	Staten Island		206,951 GSF	Fair	> 20 years		
51	Solar-Ready	DOE	R072	33 FERNDALE AVENUE	Staten Island		209,050 GSF	Between Good and Fair	10 to 14 years	Yes	

\*Buildings with solar systems can be found in Completed & In Progress Appendices

\*\* Environmental Justice Zone: as defined by Local Law 64 of 2017, a low-income community or minority community, as determined by U.S. Census Bureau, 2011 – 2015 American Community Survey.

\*\*\*Solar-Readiness Assessments: onsite technical inspection of roof, structural systems, and electrical service, preliminary solar PV system design fitting building’s technical constraints and code compliance.

\*\*\*\*Green Roof: roof covered with vegetation, provides improved building insulation, reduced GHG emissions, stormwater management, reduced heat island effect.

\*\*\*\*Cool Roof: roof with coating for solar reflection, provides lower cooling costs, reduced GHG emissions and heat island effect.