



*Vincent Sapienza, P.E.*  
*Commissioner*

**Paul V. Rush, P.E.**  
Deputy Commissioner  
Bureau of Water Supply  
prush@dep.nyc.gov

59-17 Junction Boulevard  
Flushing, NY 11373  
T: (845) 340-7800  
F: (845) 334-7175

August 12, 2019

Li Huang, P.E.  
New York City Department of Health and Mental Hygiene  
Environmental Sciences & Engineering  
42-09 28<sup>th</sup> Street, 14<sup>th</sup> Floor CN# 56  
Long Island City, NY 11101

Patrick Palmer  
New York State Department of Health  
Bureau of Water Supply Protection, NYC Watershed Section  
Empire State Plaza, Corning Tower, Room 1198  
Albany, NY 12237

Katie Lynch  
United States Environmental Protection Agency  
Clean Water Division - New York City Water Supply Protection Program  
290 Broadway, 24<sup>th</sup> Floor  
New York, New York 10007-1866

**RE: Monthly Water Quality Report for July 2019**

Dear Ms. Huang, Mr. Palmer and Ms. Lynch:

Enclosed, please find the New York City Water Quality report for the month of **July 2019**. There was no well pumpage to distribution in the Groundwater System this month. Croton water was not feeding into distribution the entire month. In addition to the following list of compliance reports, a disc of electronic files containing compliance and non-compliance data for this month is enclosed with this report.

- Raw Water Fecal Coliform Report
- Raw Water Turbidity Report
- Distribution Microbiological Compliance Reports
  - Summary
  - Positive Samples
  - Resamples
- Chlorine Residual Reports
  - Entry Point Online
  - Entry Point Daily Minimum
  - Heterotrophic Plate Count
  - Monthly Summary
- Distribution Turbidity Reports
  - Distribution Turbidity Report
  - Source Water > 1.49 NTU Table
- Color Entry Point Report

- Fluoride Reports
  - Fluoride Entry Point Report
  - Distribution Fluoride Report
- Quarterly Disinfection By-products Report

The reports are summarized as follows:

## FAD REQUIREMENTS

### **1. Raw Water Fecal Coliform Concentrations (Section 141.71(a)(1)):**

**Requirements met.** The Delaware Aqueduct effluent from Kensico Reservoir exhibited fecal coliform concentrations in water prior to disinfection at levels less than or equal to 20 CFU/100 mL in at least 90% of the samples collected in the six-month period from February 1, 2019 to July 31, 2019. The six month running percentage of samples collected with fecal coliform concentrations >20 CFU/100 mL was 0.00% for the Catskill/Delaware System for this time period.

### **2. Raw Water Turbidity (Section 141.71(a)(2)):**

**Requirements met.** The raw water leaving Kensico Reservoir via the Delaware Aqueduct in compliance samples collected at DEL18DT, just prior to disinfection, exhibited turbidity levels less than or equal to 5 NTU on an ongoing basis during the month. The highest reported turbidity value was 0.85 NTU on the Catskill/Delaware System for the month.

### **3. Entry Point Chlorine Residual (Section 141.71(b)(1)(iii) and 141.72(a)(3)):**

**Requirements met.** As required, continuous monitoring for free chlorine residual was maintained at the distribution entry points throughout the month and at no time did the concentration fall below 0.2 mg/L for more than four hours. The minimum daily free chlorine residual value for entry point readings for the Catskill/Delaware System from sites 1S03 (Tunnel 1) was 0.60 mg/L, 1S03A (Tunnel 2) was 0.80 mg/L, and 1S03B (Tunnel 3) was 0.44 mg/L.

The Croton Filtration Plant was offline and thus there was no operational Croton entry point for the month.

### **4. Distribution System Disinfection Residuals (Section 141.71(b)(1)(iv) and 141.72(a)(4)):**

**Requirements met.** All free chlorine residuals measured at compliance sites within the distribution system during the month were greater than or equal to 0.01 mg/L except for two samples that were 0.00 mg/L.

A total of 1356 distribution samples were tested for free chlorine residual this month. For all distribution sites free chlorine residual ranged from 0.00 mg/L to 1.16 mg/L, and averaged 0.57 mg/L for the month.

**5. Trihalomethane Monitoring / HAA5 Monitoring (Section 141.71(b)(6)):**

**Requirements met.** The results for the second quarter of 2019 were included in the report dated June 7, 2019 (for the May 2019 reporting period).

**6. Total Coliform Monitoring (Section 141.71(b)(5)):**

**Requirements met.** The results of monthly coliform monitoring performed in the distribution system are enclosed. A total of 822 compliance samples were tested for total coliform during this period. HPC were all  $\leq 500$  CFU/mL, equivalent to a measurable free chlorine residual. Zero percent of the samples had an undetectable free chlorine residual or HPC  $> 500$  CFU/mL. This meets the requirements that a free chlorine residual be maintained at representative points in the distribution system, and that no more than 5% of the free chlorine residual samples be undetectable in any two months. During the month, no samples tested positive for total coliform or for *E. coli*.

**OTHER WATER QUALITY MONITORING****7. Microbiological Monitoring:**

Coliform monitoring at distribution sites near first service connections, in response to source water having a turbidity  $> 1.49$  NTU, was not required this month, but all of these samples were negative for total coliform.

The analyses of 534 distribution Operational samples resulted in one (1) sample testing positive for total coliform. No *E. coli* were detected.

The analyses of 248 Pre-Finished samples resulted in eleven (11) samples testing positive for total coliform. No *E. coli* were detected.

The analyses of 620 Autosampler Pre-finished samples resulted in 11 (eleven) samples testing positive for total coliform. No *E. coli* were detected.

**8. Distribution Turbidity Monitoring:**

For distribution sites turbidity ranged from 0.30 to 3.57 NTU and averaged 0.62 NTU for the month. This meets the MCL of 5 NTU for the monthly average of all distribution samples.

**9. Color Monitoring:**

The MCL of 15 units for color was met at each Catskill/Delaware entry point for the month. Daily analyses of entry point samples (93 samples in total), produced monthly average color values of six (6) units for sites 1S03 (Tunnel 1), 1S03A (Tunnel 2), and 1S03B (Tunnel 3).

**10. Volatile Organic/TTHM/HAA5 Monitoring:**

**Monthly Results:** Twenty (22) distribution and three (3) entry point samples were collected for volatile organic contaminant (VOC) analysis. All VOC samples from distribution sites and entry points were below detection. Twenty (22) TTHM distribution samples were collected ranging from 30  $\mu\text{g/L}$  to 52  $\mu\text{g/L}$ . Three (3) TTHM entry point samples were collected ranging from 28  $\mu\text{g/L}$  to 54  $\mu\text{g/L}$ . Twenty-one (21) HAA5 distribution samples were collected ranging from 33  $\mu\text{g/L}$  to 55  $\mu\text{g/L}$ . Three (3) HAA5 entry point samples were collected ranging from 28  $\mu\text{g/L}$  to 34  $\mu\text{g/L}$ .

**11. Semivolatile and Other Organic Chemicals/parameters:**

EPA Method 525.3 monitoring for 112 compounds of specified and unspecified organic parameters was conducted on July 8, 2019 at the three Catskill/Delaware entry points (1S07, 1S03A, and 1S03B), at the Croton Low Service entry point (1SCL1) and Croton High Service entry point (1SCH3), which were receiving distribution water this month, and six (6) distribution points. A Catskill/Delaware entry point (1S03B) and the six (6) distribution points were resampled on July 18, 2019 due to the failure of laboratory fortified blanks (LFB) for dimethipin, disulfoton, and caffeine. All semi-volatile organic contaminant samples from distribution sites and entry points were below detection limits.

Quarterly monitoring for the two compounds 1,2-Dibromo-3-chloropropane and 1,2-Dibromoethane by EPA Method 524.3 SIM, determination of microextractables, replacing analysis by EPA Method 551.1, was conducted at five (5) entry points including the Croton Low Service and High Service (1SCL1 and 1SCH3), which were receiving distribution water this month, and one distribution sampling site (50250) on June 17, 2019 and July 29, 2019. All sites were below detection.

**12. Fluoride Monitoring:**

Daily analyses of entry point samples (93 samples in total), produced monthly average fluoride levels of 0.70 mg/L for sites 1S03 (Tunnel 1) and 1S03B (Tunnel 3), and 0.69 mg/L for site 1S03A (Tunnel 2). The fluoride levels at the entry points did not exceed the MCL of 2.2 mg/L at any time during the month.

**13. Other Monitoring:**

Sampling for Taste and Odor (T&O) compounds Geosmin and 2-Methylisoborneol (MIB) was conducted in June on four (4) Croton water samples at New Croton Reservoir. All results were ND. Contract laboratory reports of available data are included as pdf files on the disc of electronic files enclosed with this report.

Please feel free to contact me at (845) 340-7701 if you would like to discuss any of this information in greater detail.

Sincerely,



Steven C. Schindler  
Director, Water Quality

**Enclosure**

cc:

Mr. Andrew Brunsten, Inspector General for NYCDEP  
Mr. Kenneth Kosinski, NYSDEC  
Mr. David Kvinge, Westchester County Water Agency (by email only)  
Mr. Huan Li, NYCDOHMH  
Mr. Trevor McProud, NYCDOHMH  
Mr. Andy Tse, NYSDOH (by email only)  
Mr. Steven Zahn, NYSDEC – Region 2

bcc:

**Electronic file:**

*V. Sapienza, P.E., Commissioner*

*K. Alderisio*

*A. Bader*

*D. Borchert*

*K. Cipriano*

*K. Czarnogorski/file*

*S. Freud*

*C. Glaser*

*L. Janus, Ph.D.*

*K. Kane*

*L. Lu, Ph.D.*

*C. McCormack*

*D. Mulvihill*

*W. Melendez, P.E.*

*L. Occhiuto*

*A. Reaves*

*S. Riviere*

*D. Robinson*

*P. Rush, P.E.*

*S. Schindler (hard copy)*

*D. Warne*

*M. Warne*

*V. Xu*

***TABLE OF CONTENTS FOR CD FILES***

## July 2019 Monthly Water Quality Report

### Microbiological Reports:

Summary of Coliform Compliance Samples  
Coliform Positive Compliance Samples  
Coliform Resample for Positive Compliance Samples  
Summary of Coliform Operational Samples

(NYC\_Micro\_Summary\_Compliance\_201907.xls)  
(NYC\_Micro\_Compliance\_Positives\_201907.xls)  
(NYC\_Micro\_Compliance\_Resamples\_201907.xls)  
(NYC\_Micro\_Operational\_201907.pdf)  
(NYC\_Micro\_Summary\_Operational\_201907.xls)  
(NYC\_Micro\_Operational\_201907.pdf)  
(NYC\_Micro\_Operational\_Positives\_201907.xls)  
(NYC\_Micro\_Operational\_201907.pdf)  
(NYC\_Micro\_Operational\_Resamples\_201907.xls)  
(NYC\_EP\_Coliform\_For\_Source\_Turb\_GT\_149\_201907.snp)  
(NYC\_Monthly\_Alldata\_201907.xls|Micro)

Coliform Positive Operational Samples

Coliform Resample for Positive Distribution Operational Samples

Distribution Coliform Monitoring when Source Water Turbidity exceeds 1.49 NTU  
All Microbiological Results

### Free Chlorine Residual (FCR) Reports:

Entry Point FCR On-Line Monitoring Results  
Daily Minimum FCR at Entry Points

(Entry\_Shaf1\_Cl2\_Onln\_201907\_Fig.pdf)  
(Entry\_Shaf1\_Cl2\_Onln\_201907\_Tbl.pdf)  
(Croton\_Entry\_Point\_Cl2\_201907\_Tbl.pdf)

FCR and Heterotrophic Plate Count (HPC) Compliance Samples  
FCR and HPC of Operational Samples

(NYC\_Micro\_Summary\_FCR\_&HPC\_Compliance\_201907.xls)  
(NYC\_Micro\_Operational\_201907.pdf)  
(NYC\_FCR\_Monthly\_Summary\_201907.xls)  
(NYC\_FCR\_Monthly\_Alldata\_201907.xls)

Summary of FCR of Distribution Samples (Monthly)  
FCR of all Distribution Sites

### Turbidity Reports:

Summary of Turbidity of Distribution Samples  
Turbidity of all Distribution Sites

(NYC\_Turbidity\_Monthly\_Summary\_201907.xls)  
(NYC\_Turbidity\_Monthly\_Alldata\_201907.xls)

### Color Reports:

Color for Entry Point Samples

(Entry\_Point\_Color\_Monthly\_201907.xls)

### Fluoridation Reports:

Summary of Fluoride Levels of Distribution Samples  
Fluoride Daily Entry Point Report for Surface Water Systems  
Fluoride of all Distribution Sites

(NYC\_Fluoride\_Monthly\_Summary\_201907.xls)  
(Entry\_Point\_Fluoride\_Monthly\_201907.xls)  
(NYC\_Fluoride\_Monthly\_Alldata\_201907.xls)

### Volatile Organic Contaminant (VOC) and Disinfection By-products (DBP)

#### Reports:

Total Trihalomethanes (TTHM) & VOC Monthly Report  
Semivolatiles of EPA Method 525 Report  
Haloacetic Acids (HAA5) Monthly Report  
Microextractables of EPA Method 524.3/SIM Report for June and July  
Taste & Odor Sampling Reports from EEA Lab  
Summary of EPA Organic Method Reports

(NYC\_TTHM\_&VOC\_Rpt\_201907.xls)  
(NYC\_SOC\_Rpt\_201907.xls)  
(NYC\_HAA5\_Monthly\_Rpt\_201907.xls)  
(NYC\_524-3-SIM\_Rpt\_201906-07.xls)  
(813728\_T&O\_Sample\_2019701.pdf, 814626\_T&O\_Sample\_20190708.pdf, 816806\_T&O\_Sample\_2019717.pdf, 817359\_T&O\_Sample\_2019722.pdf)  
(NYC\_VOC\_524-3-Sim\_525\_HAA5\_Rpt\_201907.pdf)

### Inorganic (IOC), Specified Organic (SOC), Metals Monitoring:

All parameters for July 2019  
Mercury results from EEA LAB

(NYC\_Monthly\_Alldata\_201907.xls)  
(814244\_Monthly\_Hg\_201907.pdf, 818685\_Hillview\_Hg\_201907.pdf)



***RAW WATER FECAL COLIFORM CONCENTRATIONS***  
***(FAD Requirement)***



# NYCDEP Division of Watershed Water Quality Operations

## Catskill/Delaware System Raw Water Fecal Coliform Compliance Report

Hawthorne Laboratory, ELAP Lab ID No. 10771  
 15 Skyline Drive, Hawthorne, NY 10532

Deputy Chief: David Robinson  
 914-345-4973

**Catskill/Delaware Public Water System at Shaft 18 (DEL18DT) - Raw Water** **Period: 05/17 To: 07/19**

Date	Number of Fecal Coliform Samples Examined per Month	Number of Fecal Coliform Samples with >20 colonies per 100 mL	Percent of Monthly Fecal Coliform Samples with >20 colonies per 100 mL	Percent of Monthly Fecal Coliform Samples with >20 colonies per 100 mL for Previous Six Months
5-17	31	0	0.00	0.00
6-17	30	0	0.00	0.00
7-17	31	0	0.00	0.00
8-17	31	0	0.00	0.00
9-17	30	0	0.00	0.00
10-17	31	0	0.00	0.00
11-17	30	0	0.00	0.00
12-17	31	0	0.00	0.00
1-18	31	0	0.00	0.00
2-18	28	1	3.57	0.55
3-18	31	0	0.00	0.55
4-18	30	0	0.00	0.55
5-18	31	0	0.00	0.55
6-18	30	0	0.00	0.55
7-18	31	0	0.00	0.55
8-18	31	0	0.00	0.00
9-18	30	2	6.67	1.09
10-18	31	2	6.45	2.17
11-18	30	0	0.00	2.19
12-18	31	0	0.00	2.17
1-19	31	0	0.00	2.17
2-19	28	0	0.00	2.21
3-19	31	0	0.00	1.10
4-19	30	0	0.00	0.00
5-19	31	0	0.00	0.00
6-19	30	0	0.00	0.00
7-19	31	0	0.00	0.00

*David Robinson*

8/2/19

Reported by: David Robinson, Deputy Chief, Hawthorne Water Quality Operations

8/2/2019

***RAW WATER TURBIDITY***  
***(FAD Requirement)***



# NYCDEP Division of Watershed Water Quality Operations

## Water Systems Operation Report - Catskill/Delaware System

Hawthorne Laboratory, ELAP Lab ID No. 10771  
15 Skyline Drive, Hawthorne, NY 10532

Deputy Chief: David Robinson  
914-345-4973

**Catskill/Delaware Public Water System at Shaft 18 (DEL18DT) - Raw Water** Period: July, 2019

Date	Turbidity (NTU)						Total Coliform (Colonies per 100 mL)	Fecal Coliform
	12 AM	4 AM	8 AM	12 PM	4 PM	8 PM		
7/1/19	0.80	0.80	0.75	0.70	0.70	0.65	E20	E3
7/2/19	0.65	0.65	0.65	0.75	0.75	0.85	E30	E3
7/3/19	0.75	0.75	0.75	0.70	0.70	0.70	E55	E1
7/4/19	0.65	0.75	0.70	0.85	0.65	0.75	E85	<1
7/5/19	0.75	0.70	0.75	0.60	0.70	0.65	E70	E2
7/6/19	0.65	0.65	0.65	0.65	0.70	0.70	E80	E1
7/7/19	0.75	0.70	0.70	0.70	0.75	0.70	E80	<1
7/8/19	0.70	0.60	0.65	0.60	0.60	0.65	E90	E2
7/9/19	0.65	0.60	0.60	0.65	0.70	0.60	180	E1
7/10/19	0.65	0.70	0.65	0.65	0.60	0.70	E260	E2
7/11/19	0.60	0.60	0.65	0.55	0.60	0.60	E10	<1
7/12/19	0.60	0.65	0.65	0.60	0.60	0.60	330	E1
7/13/19	0.55	0.55	0.55	0.55	0.60	0.55	E120	E1
7/14/19	0.60	0.55	0.55	0.60	0.60	0.65	E220	<1
7/15/19	0.65	0.60	0.65	0.60	0.65	0.70	450	<1
7/16/19	0.60	0.65	0.55	0.70	0.75	0.70	E170	E1
7/17/19	0.70	0.60	0.75	0.70	0.55	0.65	260	<1
7/18/19	0.60	0.55	0.50	0.50	0.50	0.50	E140	<1
7/19/19	0.45	0.50	0.55	0.55	0.60	0.60	E130	<1
7/20/19	0.60	0.75	0.60	0.65	0.60	0.55	E120	E2
7/21/19	0.75	0.55	0.65	0.75	0.65	0.70	E160	E3
7/22/19	0.65	0.55	0.60	0.60	0.55	0.50	E70	<1
7/23/19	0.50	0.50	0.50	0.45	0.50	0.50	E180	E7
7/24/19	0.55	0.60	0.70	0.50	0.50	0.55	E50	<1
7/25/19	0.50	0.50	0.60	0.60	0.60	0.60	E30	E2
7/26/19	0.60	0.65	0.60	0.65	0.65	0.55	E20	E1
7/27/19	0.55	0.55	0.60	0.55	0.65	0.60	E100	<1
7/28/19	0.65	0.60	0.65	0.70	0.75	0.55	E20	<1
7/29/19	0.65	0.70	0.65	0.65	0.70	0.70	E30	E1
7/30/19	0.70	0.55	0.65	0.60	0.65	0.65	E10	<1
7/31/19	0.65	0.70	0.65	0.70	0.75	0.70	E20	<1

.: Aqueduct Shutdown, CONF: Confluent Growth (+ indicates positive coliform growth), LE: Lab Error, FE: Field Error,  
E: estimated count based on non-ideal plate, >=: plate count may be biased low based on heavy growth, >: observed count replaced with dilution based value

1. Does a raw water turbidity M & R violation exist?  Yes  No
2. Does the turbidity reading exceed 5 NTU at any time?  Yes  No  
*If yes, check for MCL violation, and notify state by the end of the next business day.*
3. Minimum number of microbiological samples required per week: 5
4. A daily microbiological sample is required every day the raw water turbidity exceeds 1 NTU.

Additional Comments:

*D.W. Robinson*

*8/2/19*

Reported by: David Robinson, Deputy Chief, Hawthorne Water Quality Operations

8/2/2019



# NYCDEP Division of Watershed Water Quality Operations

## Water Systems Operation Report - Qualifiers and Methods Addendum

Hawthorne Laboratory, ELAP Lab ID No. 10771  
15 Skyline Drive, Hawthorne, NY 10532

Deputy Chief: David Robinson  
914-345-4973

### Data Qualifiers and Additional Notes

Date/Time	Site	Analytes Affected	Qualifier
-----------	------	-------------------	-----------

### Analytical Methods

- Coliform, Fecal - SM 9222D (2006)
- Coliform, Total - SM 9222B (2006)
- Turbidity - SM 2130B (01)

***ENTRY POINT CHLORINE RESIDUAL***  
***(FAD Requirement)***

New York City Department of Environmental Protection  
Bureau of Water Supply


Daily Minimum Chlorine Readings Recorded at Tunnel Entry Shafts for Catskill/Delaware System

Tunnel No.1 (Catskill) at Shaft 3			Tunnel No.2 (Delaware) at Shaft 3A			Tunnel No.3 (Cat/Del) at Shaft 3B		
Date	MinCl_1DL	Remark 1	Date	MinCl_2DL	Remark 2	Date	MinCl_3DL	Remark 3
07/01/19	0.67		07/01/19	0.93		07/01/19	0.60	
07/02/19	0.66		07/02/19	0.88		07/02/19	0.68	
07/03/19	0.63		07/03/19	0.80		07/03/19	0.64	
07/04/19	0.63		07/04/19	0.85		07/04/19	0.64	
07/05/19	0.66		07/05/19	0.94		07/05/19	0.69	
07/06/19	0.65		07/06/19	0.89		07/06/19	0.66	
07/07/19	0.66		07/07/19	0.91		07/07/19	0.70	
07/08/19	0.65		07/08/19	0.95		07/08/19	0.63	
07/09/19	0.62		07/09/19	0.92		07/09/19	0.44	
07/10/19	0.65		07/10/19	0.93		07/10/19	0.67	
07/11/19	0.63		07/11/19	0.88		07/11/19	0.65	
07/12/19	0.63		07/12/19	0.94		07/12/19	0.67	
07/13/19	0.66		07/13/19	0.93		07/13/19	0.68	
07/14/19	0.64		07/14/19	0.94		07/14/19	0.68	
07/15/19	0.63		07/15/19	0.92		07/15/19	0.69	
07/16/19	0.65		07/16/19	0.92		07/16/19	0.66	
07/17/19	0.64		07/17/19	0.93		07/17/19	0.64	
07/18/19	0.60		07/18/19	0.97		07/18/19	0.65	
07/19/19	0.66		07/19/19	0.98		07/19/19	0.65	
07/20/19	0.66		07/20/19	0.94		07/20/19	0.64	
07/21/19	0.66		07/21/19	0.96		07/21/19	0.68	
07/22/19	0.68		07/22/19	0.96		07/22/19	0.68	
07/23/19	0.67		07/23/19	0.98		07/23/19	0.65	
07/24/19	0.67		07/24/19	0.93		07/24/19	0.69	
07/25/19	0.67		07/25/19	0.95		07/25/19	0.69	
07/26/19	0.65		07/26/19	0.95		07/26/19	0.66	
07/27/19	0.67		07/27/19	0.96		07/27/19	0.69	
07/28/19	0.65		07/28/19	0.96		07/28/19	0.68	
07/29/19	0.65		07/29/19	0.96		07/29/19	0.55	
07/30/19	0.66		07/30/19	0.95		07/30/19	0.63	
07/31/19	0.68		07/31/19	0.94		07/31/19	0.64	


Legend: MinCl\_1DL: Shaft 3's minimum chlorine level measured at the shaft and recorded at the location via data logger, in ppm.  
MinCl\_2DL: Shaft 3A's minimum chlorine level measured at the shaft and recorded at the location via data logger, in ppm.  
MinCl\_3DL: Shaft 3B's minimum chlorine level measured at the shaft and recorded at the location via data logger, in ppm.

### City Tunnel Entry Point Residual Chlorine Continuous Monitoring Results


#### Chlorine Levels at City Tunnel No.1 Entry Point, July 2019



#### Chlorine Levels at City Tunnel No.2 Entry Point, July 2019



#### Chlorine Levels at City Tunnel No.3 Entry Point, July 2019



Note: Continuous monitoring of free chlorine residual (FCR) at distribution entry points was maintained. FCR was maintained at or above 0.2 ppm at all times. Since 3/10/19, all online readings, grab and online dial-up readings were recorded in Eastern Daylight Saving Time.



***DISTRIBUTION SYSTEM DISINFECTION RESIDUAL***  
***(FAD Requirement)***

**REPORT**

**NEW YORK CITY DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF WATER SUPPLY, DISTRIBUTION LAB (NYSDOH ELAP #10770; USEPA #NY01351)**

**Residual Chlorine (mg/L) Distribution Samples  
July 2019**

All Distribution Sites			
Samples	Min	Max	Average
1356	0.00	1.16	0.57

Hach DPD Method (analyte is not ELAP certified)

SAMPLE NUMBER	SAMPLE DATE	SAMPLE SITE	LOCATION TYPE	RESIDUAL CHLORINE	COMMENT
20542	7/16/19	40200	Regular	1.16	Max
21577	7/25/19	15250	Regular	1.16	Max
20118	7/12/19	56200	Regular	0.00	Min
21563	7/25/19	77750	Regular	0.00	Min

A FCR is to be maintained at representative points in the distribution system and no more than 5% of the samples can be undetectable in any two months.

***TOTAL COLIFORM MONITORING***  
***(FAD Requirement)***

REPORT

NEW YORK CITY DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF WATER SUPPLY, DISTRIBUTION LAB (NYSDOH ELAP #10770; USEPA #NY01351)

Summary of Results for Microbiological Quality  
 Compliance Samples

7/1/2019 to 7/31/2019

Location	Number of Sampling Points	Number of Samples Collected	Number of Samples Tested	Number of Samples with Positive Coliform *	Number of Samples with Positive E. coli *	Percent of Samples with Positive Coliform **
Bronx	46	135	135	0	0	0.0%
Brooklyn	70	202	202	0	0	0.0%
Manhattan	57	171	171	0	0	0.0%
Queens ***	79	232	232	0	0	0.0%
Staten Island	28	82	82	0	0	0.0%
Ground Water Supply ***	-	-	-	-	-	-
Total	280	822	822	0	0	0.0%

- \* As determined by Colilert Quanti-Tray-18 Method (SM 9223 B).
- \*\* If more than 5.0 % of all monthly TCR compliance samples are positive for total coliform, a Level I Assessment must be conducted.
- \*\*\* There was no groundwater sample this month because no well was in operation to distribution.

Supervisor: Rupe Agnew Date: 08/08/19

Director: W. B. Date: 8/9/19





REPORT

NEW YORK CITY DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF WATER SUPPLY, DISTRIBUTION LAB (NYSDOH ELAP #10770; USEPA #NY01351)

Results for Microbiological Quality  
Free Chlorine Residual and Heterotrophic Plate Count  
Compliance Samples

7/1/2019 to 7/31/2019

Location	Number of Sampling Points	Number of Samples Collected	Number of Samples Tested (Free Chlorine Residual)	Number of Samples Tested (Heterotrophic Plate Count)	Number of Samples with Free Chlorine Residual *		Range of Heterotrophic Plate Count (CFU/mL) for Free Chlorine Residual of 0.00 mg/L **	Number of Samples with Free Chlorine Residual of 0.00 mg/L and HPC > 500 ***	Percent of Samples with Free Chlorine Residual of 0.00 mg/L and HPC > 500 ***
					< 0.20 mg/L	0.00 mg/L			
Bronx	46	135	135	95	0	0	-	0	0.0%
Brooklyn	70	202	202	147	10	0	--	0	0.0%
Manhattan	57	171	171	130	21	0	-	0	0.0%
Queens †	79	232	232	171	35	1	45	0	0.0%
Staten Island	28	82	82	63	10	0	-	0	0.0%
Ground Water Supply †	-	-	-	-	-	-	--	-	-
Total	280	822	822	606	76	1	45	0	0.0%

\* Free chlorine residual is determined by Hach DPD Method (analyte is not ELAP certified).  
 \*\* Heterotrophic plate count is determined by method SM 9215 B, PCA medium, 35°C, 48hrs. HPC result ≤ 500 CFU/mL is equivalent to a measurable FCR.  
 \*\*\* No more than 5 % of FCR samples shall be undetectable in any 2 consecutive months.

† There was no groundwater sample this month because no well was in operation to distribution.

Supervisor: Rupe Agnew Date: 08/08/19  
 Director: Nun Ban Date: 8/9/19

***MICROBIOLOGICAL MONITORING***



**REPORT**

**NEW YORK CITY DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF WATER SUPPLY, DISTRIBUTION LAB (NYSDOH ELAP #10770; USEPA #NY01351)**

**Coliform Monitoring Results at Sample Sites near the First Service Connection  
When Source Water Turbidity Exceeds 1.49 NTU**

**July 2019**

Source water		Distribution site near first service connection			
Date Turb>1.49 NTU	System	Sample Date	Sample Site	Coliform *	E.coli *

No official four-hour turbidity readings from Cat-Del source water were greater than 1.5 NTU this month.

\* As determined by Collert Quanti-Tray-18 Method (SM 9223B). Results expressed in "MPN /100mL."

***DISTRIBUTION TURBIDITY MONITORING***

REPORT

NEW YORK CITY DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF WATER SUPPLY, DISTRIBUTION LAB (NYSDOH ELAP #10770; USEPA #NY01351)

Turbidity (NTU) Distribution Samples

July 2019

All Distribution Sites			
Samples	Min	Max	Average
1356	0.30	3.57	0.62

Analytical Method SM 2130 B

SAMPLE NUMBER	SAMPLE DATE	SAMPLE SITE	LOCATION TYPE	TURBIDITY	COMMENT
18991	7/2/19	21750	Reg Stop	3.57	Max
22135	7/30/19	40600	Reg Stop	0.30	Min

The monthly average of all distribution samples is not to exceed 5 NTU.

***COLOR MONITORING***

REPORT

NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF WATER SUPPLY DISTRIBUTION LABORATORY (NYSDOH ELAP #10770; USEPA #NY01351)

Color (U) for Distribution Entry Points  
July 2019

DAY	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Catskill/Delaware 1S03 (Tunnel 1)	6	6	6	7	7	7	7	6	6	7	6	6	7	5	6	6	6	6	7	6	6	6	6	6	6	6	5	7	7	6	6
Catskill/Delaware 1S03A (Tunnel 2)	7	7	6	7	7	6	6	6	6	6	7	6	7	6	6	6	6	6	7	6	6	6	6	6	6	7	5	7	7	6	6
Catskill/Delaware 1S03B (Tunnel 3)	6	7	6	7	7	6	6	6	6	6	7	6	7	6	7	7	6	6	6	6	6	6	6	6	6	7	6	7	7	6	6
Croton System 1SCL1 (a)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Croton System 1SCH3 (a)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Analytical Method SM 2120 B. Apparent color.

The average of two consecutive samples from the same site is not to exceed the MCL of 15 color units.

(a) Croton System offline as of 6/4/19 at 1SCL1.

Entry Point	Samples	Minimum	Maximum	Average
Catskill/Delaware 1S03 (Tunnel 1)	31	5	7	6
Catskill/Delaware 1S03A (Tunnel 2)	31	5	7	6
Catskill/Delaware 1S03B (Tunnel 3)	31	6	7	6
Croton System 1SCL1 (a)	-	-	-	-
Croton System 1SCH3 (a)	-	-	-	-

Supervisor  Date 08/08/19

Director  Date 8/8/19

***FLUORIDE MONITORING***

REPORT

NYC DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF WATER SUPPLY DISTRIBUTION LABORATORY (NYSDOH ELAP #10770; USEPA #NY01351)

Fluoride (mg/L) for Distribution Entry Points

July 2019

DAY	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Catskill/Delaware 1S03 (Tunnel 1)	0.74	0.73	0.74	0.75	0.74	0.74	0.73	0.73	0.73	0.73	0.72	0.72	0.72	0.68	0.69	0.69	0.69	0.70	0.72	0.70	0.71	0.70	0.58	0.55	0.63	0.66	0.67	0.68	0.69	0.69	0.69
Catskill/Delaware 1S03A (Tunnel 2)	0.74	0.74	0.75	0.75	0.74	0.74	0.73	0.72	0.73	0.72	0.73	0.72	0.71	0.68	0.68	0.68	0.70	0.71	0.72	0.71	0.69	0.70	<0.30	0.67	0.69	0.69	0.69	0.69	0.69	0.69	0.69
Catskill/Delaware 1S03B (Tunnel 3)	0.74	0.73	0.75	0.74	0.74	0.74	0.73	0.73	0.73	0.73	0.73	0.72	0.72	0.69	0.68	0.69	0.70	0.71	0.72	0.70	0.71	0.70	0.52	0.59	0.63	0.68	0.69	0.69	0.68	0.68	
Croton System 1SCL1 (a)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
Croton System 1SCH3 (a)	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Analytical Method SM 4500 FC (97)

The average of two consecutive samples from the same distribution entry point site is not to exceed the MCL of 2.2 ppm.

(a) Croton System offline as of 6/4/19 at 1SCL1.

Entry Point	Samples	Minimum	Maximum	Average
Catskill/Delaware 1S03 (Tunnel 1)	31	0.55	0.75	0.70
Catskill/Delaware 1S03A (Tunnel 2)	31	<0.30	0.75	0.69
Catskill/Delaware 1S03B (Tunnel 3)	31	0.52	0.75	0.70
Croton System 1SCL1 (a)	-	-	-	-
Croton System 1SCH3 (a)	-	-	-	-

Supervisor  Date 08/08/19

Director  Date 8/8/19